Rethinking Electric Grid Design to Meet Beneficial Electrification and Enhanced Distributed Generation

A Portland Area Case Study



GridSolar, LLC May 2020

Copyright

© GridSolar, LLC 2020

Abstract

Maine's largest electric utility, Central Maine Power, has identified a need for improved reliability of its electric transmission grid in the greater Portland region and a solution for that need involves the construction of additional miles of 115 kV lines, new 34.5 kV substations and the reconductoring of a number of transmission circuits in the region. The total cost of the utility's proposed solution is in excess of \$200 million.

Simultaneously, Maine and an increasing number of municipalities have adopted policies of achieving near-zero carbon economies by 2050. These carbon reduction objectives can only be achieved through the conversion of transportation, space heating and commercial and industrial processes from distillate fuels and natural gas to electricity. Such conversion is only useful to reducing carbon emissions to the extent that new renewable generation is developed on a scale sufficient to meet the increased electricity demands.

This study presents a first look at the new and very significant electricity demands each of these processes – what have come to be called beneficial electrification and deep decarbonization – will impose on the region's electric transmission and distribution grid. Our analysis and modeling show that for this geographically small urban region alone the former will result in a more than doubling of the total amount of electricity that will flow to customers on the grid and a three-fold increase in peak loads, while the latter will require the interconnection of thousands of distributed solar generation systems on the rooftops of residential, commercial and industrial buildings in the region. These are well beyond the capacity of the current electric grid in the region.

Together, beneficial electrification and deep decarbonization will require nothing short of a new electric grid – one that is redesigned and capable of handling much larger volumes of electricity, multi-direction electricity flows across the entire grid and information, communication and control capabilities to manage hundreds of thousands of discrete loads and generation points on the grid. This new redesigned grid will not result from the current transmission and distribution planning processes. These processes have led to proposed upgrades to achieve at best modest increases in reliability at a cost of over \$200 million. Instead, Maine needs to develop new measures of electric grid performance and standards that will direct utilities to make investments that enable cities and states to achieve their zero-carbon futures within their established timeframes. Since the planning, design, development and commissioning cycle for transmission projects can exceed a decade, Maine is already behind the curve.

Table of Contents

Abstract	
Table of Contents	4
List of Figures	7
List of Tables	
Acknowledgements	9
Disclaimer	
Chapter 1 - Introduction and Overview	12
1.1 Project Origins	12
1.2 Project Development	13
1.3 Project Overview	15
Chapter 2 - The Portland Region	18
2.1 Geographic Representation	18
2.2 The Electrical Grid	18
2.2.1 Electricity Generation and Imports	
2.2.2 High Voltage Electric System	20
2.2.3 Distribution System	23
Chapter 3 - Current Energy Use	25
3.1 Introduction	25
3.2 Current Electricity Use	25
3.2.1 Data and Methodology	26
3.2.2 Results	
3.3 Transportation	
3.3.1 Passenger Vehicles	
3.3.2 Buses	
3.3.3 Trucks	
3.3.4 Other Transportation	
3.4 Space Heating/Commercial and Industrial Process Energy	35
3.5 Summary of Current Energy Use	
Chapter 4 - Beneficial Electrification	41

4.1	Overview	41
4.2	Transportation	41
4.2	1 Passenger Vehicles	42
4.2	2 Buses	45
4.2	3 Trucks	46
4.3	Space Heating	47
4.4	Residential Air Conditioning	49
4.5	Commercial and Industrial Processes	51
4.6	Summary	52
Chapter	5 - Distributed Solar Photovoltaic Generation	56
5.1	Introduction	56
5.2	Rooftop Solar PV – Modeling Results	57
Chapter	6 - Energy Balances	60
6.1	Introduction	60
6.2	Energy Balances	61
6.2	1 At the Building Level	61
6.2	2 At the Circuit Level	63
6.2	.3 At the Transformer/Substation Level	70
6.2	.4 At the Regional Level	76
6.3	Storage	76
Chapter	7 - Electric Grid Design	
7.1	Introduction	
7.2	Electricity Load Forecasting	81
7.3	Expanding the Distribution Grid	
7.4	Accommodating Multi-Directional Power Flows	
7.5	Addressing Regional Energy Balances	
Chapter	8 - Portland Area	91
8.1	The 345 kV Transmission Grid	
8.1	.1 The 345 kV Transmission Grid - 2020	
8.1	.2 The 345 kV Transmission Grid – Post 2050	94
8.1	.3 Estimated Costs of the 345 kV Grid Additions	97
8.2	The 115 kV Transmission Grid	

8.2.1	1 The 115 kV Grid – Post 2050	99
8.3	The 34.5 kV Subtransmission System	. 103
8.4	Summary	. 106
8.5	Concluding Thoughts	. 109

List of Figures

Figure 2-1	Geographic Map of The Portland Region
Figure 2-2	Electrical Representation of 115 kV System in the Portland Region21
Figure 2-3	Electrical Representation of the 34.5 kV System in the Portland Region22
Figure 2-4	Electrical Representation of the Distribution Circuits in the Portland Region24
Figure 3-1	Model Validation – by Month
Figure 3-2	Model Validation by Hour of the Day
Figure 3-3	Percent Energy Use by End-Use and Economic Sector40
Figure 4-1	California Study Results - Electric Charging Profiles for Passenger Vehicles44
Figure 4-2	Location of City and School Bus Depots46
Figure 4-3	Estimated Hourly Electric Heating Loads by End-Use Sector
Figure 4-4	Residential Air Conditioning – Hourly Loads
Figure 4-5	Estimated Hourly Electric Process Loads by End-Use Sector
Figure 4-6	Hourly Electricity Use by End-Use Sector Under Beneficial Electrification54
Figure 6-1	Distribution Circuit Peak Loads
Figure 6-2	Reverse Power Flows on Distribution Circuits
Figure 6-3	Max. Loads by 115/12.5 kV Transformer – $2020 - 2050$ as a Pct. of High Ratings72
Figure 6-4	Max. Loads by 34/12.5 kV Transformer - 2020 - 2050 as a Pct. of High Ratings74
Figure 6-5	Load Levels v. Capacity - No. 1 Bank - Bishop Street Substation75
Figure 6-6	Hourly Energy Balances for the Portland Area77
Figure 8-1	Electrical Representation of the 345 kV System - 2020
Figure 8-2	Electrical Representation of the 345 kV System - 205096
Figure 8-3	Electrical Representation of the 115 kV Grid – Post 2050 101
Figure 8-4	Two Options for 34.5 kV System Design Post 2050 105

List of Tables

Table 3-1	Summary of Buildings in the Portland Area
Table 3-2	Estimated Residential Electricity Use per Sq. Ft
Table 3-3	Heating Fuel by Building Types – South Portland
Table 3-4	Total Energy Use for the Portland Region by Class and End-Use
Table 4-1	Summary – Electricity Use by End-Use Sector Under Beneficial Electrification
Table 4-2	Energy Use by Fuel – 2020 - 2050
Table 5-1	Installed Solar PV Generation – Portland Area
Table 6-1	Annual Building Energy Balances – 2050
Table 6-2	Maximum and Minimum Hourly Loads by Distribution Circuit - 2020 - 205065
Table 8-1	Estimated Costs (2020\$) of 345 kV Grid Additions
Table 8-2	Estimate of Portland Region Cost Differential
Table 8-3	Load Assigned to Sub-Regions
Table 8-4	Estimated Costs (2020%) for 115 kV Grid Additions 102
Table 8-5	Estimated Costs – 34.5 kV System Post 2050 106
Table 8-6	Summary – Estimated Cost of Transmission/Subtransmission Upgrades - 2050 107
Table 8-7	Land-Use Consequences of Electric Grid Build-Out

Acknowledgements

GridSolar would like to extend its special thanks and appreciation to those organizations and individuals who collaborated and shared their valuable data, time, and input. The organizations are:

Participating Organizations:

- Central Maine Power (CMP)
- Competitive Energy Services (CES)
- City of Portland
- City of South Portland
- ReVision Energy
- The E4 Group:
 - o The Maine Office of the Public Advocate (OPA)
 - o Industrial Energy Consumers Group (IECG)
 - o Efficiency Maine Trust (EMT)
 - o The Conservation Law Foundation (CLF)
 - o The Acadia Center (Acadia)
 - o The Natural Resources Council of Maine (NRCM)

In addition, we offer our special thanks to the following individuals:

- Thorn Dickenson, President, NECEC, LLC
- Michael DeAngelo, Program Manager Non-Wires Alternatives /Asset Management and
 Planning at Avangrid
- Becca Austin, Engineering Assistant at ReVision Energy
- Tom Carrellas, Data Manager at City of South Portland
- *Nasir Shir*, GIS Manager at City of Portland.

Disclaimer

This report was prepared by GridSolar, LLC under a pilot project designed to explore Non-Transmission Alternatives (NTA) for the mid-coast and Portland regions of Maine funded by the E-4 Group through monies made available to it by the ratepayers of Central Maine Power Company. None of the members of the E-4 Group or Central Maine Power Company make any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, product or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation or favoring by any member of the E-4 Group or Central Maine Power Company. Neither the E-4 Group, Central Maine Power Company or GridSolar, LLC, nor any of their employees assume any legal liability or responsibility for the accuracy, precision, completeness, compatibility, or usefulness of any information or its associated products disclosed in this report. The views and opinions expressed herein do not necessarily state or reflect those of the E-4 Group or Central Maine Power.

This report was prepared using reasonable care and skill in applying methods of analysis consistent with normal industry practice, based on information available at the time such materials were created. To the extent these materials contain forecasts or forward-looking statements, such statements are inherently uncertain because of events or combinations of events that cannot reasonably be foreseen, including the actions of governments, individuals, third parties and market competitors.

This report is provided by GridSolar, LLC as is without any guarantees or warranty. In association with the product, GridSolar, LLC makes no representations or warranties of any kind, either express or implied, including but not limited to representations or warranties of merchantability, fitness for a particular purpose, of title, or of noninfringement of third-party rights. Use of the product by a user is at the user's sole risk.

This page was left blank intentionally

Chapter 1 - Introduction and Overview

1.1 **Project Origins**

The origins of this project date back to August 2008, when Central Maine Power (CMP) proposed its Maine Power Reliability Project ("MPRP") to the Maine Public Utilities Commission ("MPUC").¹ The MPRP was a more than \$1.5 billion upgrade to the state's high voltage transmission grid that CMP believed was necessary to meet federal electric grid reliability requirements. GridSolar argued that CMP's load assumptions were overstated and that the same degree of reliability could be achieved through the development of in-region distributed generation, energy conservation and demand management that could be called upon to support load in the event that components of the transmission system were out of service. GridSolar referred to these options collectively as "Non-Transmission Alternatives ("NTAs").²

The parties in the MPRP case reached a settlement that was adopted by the MPUC. A key part of the MPUC order carved out two sections of the CMP grid and components of the MPRP for specific study to determine whether NTA solutions could be fashioned that provided the same degree of reliability or better at a lower cost than the transmission options proposed in the MPRP. One of these areas is the Portland – South Portland region. This is the subject of an ongoing case at the MPUC – Docket No. 2011-00138.

CMP's initial filings in this case defined a variety of transmission solutions for the region. These solutions were reexamined in later CMP filings using updated load data and incorporating the full scope of the MPRP system build-out. Further activity in the case has been delayed as the parties are waiting for ISO New England (ISO-NE) to complete a long-awaited overall needs assessment update of the transmission grid for the entire State of Maine.

At the same time as these efforts were being undertaken, GridSolar has been focusing its attention on how the electric grid will need to be modified, restructured and expanded to

¹ See Maine Public Utilities Commission, Docket No. 2008-00255.

² These are also frequently referred to in the industry as Non-Wires Alternatives or NWAs. We use the terms NTA and MWA interchangeably in this report.

accommodate two critical components of any solution to the problem of climate change and global warming. The first of these is what is called "beneficial electrification". Beneficial electrification is a term used to describe the conversion of key sectors of the economy, specifically transportation, space heating and commercial and industrial processes, to electricity from fossil fuels, including coal, natural gas and oil. The second is "deep decarbonization". Deep decarbonization is the elimination of fossil fuels in the generation of electricity through the development of renewable, zero-carbon generation plants and storage technologies.

Work that GridSolar's principals have done demonstrates that beneficial electrification in Maine will increase total electricity consumption by a factor of three and increase peak loads on the grid by a factor of five. Simultaneously, the expansion of distributed generation and specifically rooftop solar photovoltaic (PV) and battery storage devices will require upgrades to the electric grid that convert the grid into a full-scale power network capable of accommodating multi-directional power flows across all aspects of the grid. As we demonstrate in this report, such a grid will look very different from today's electric grid. In addition to significant changes in its physical layout and various component parts, the grid must allow for vastly expanded communication flows that effectively interconnect, monitor and control hundreds of thousands, if not millions, of generation, end-use equipment and storage across the system.

1.2 Project Development

GridSolar believes that the current methodologies used in grid planning and the standards defining measures of grid reliability are inadequate to meet the needs, requirements and demands of our future electric grids, and further, that if these current methodologies continue to guide the development of the electric grid, they will yield highly inefficient results. A decade ago, the ISO-NE planning processes led CMP to design grid upgrades to meet ten-year load forecasts projecting large increases in electricity loads. Maine and the rest of New England had been investing in energy conservation and was about to expand those efforts to encourage the adoption of new technologies such as LED lighting and variable-speed drives to reduce electricity consumption. These and related technologies were reducing electric demands at the same time that overall economic conditions were deteriorating. The result has been essentially zero load growth over the past decade in Maine (and across New England).

Today, the same forecast models and planning processes direct CMP to design grid upgrades based on static loads and minimal expansion of distributed generation systems. Yet, Maine (and the other New England states) is actively encouraging the conversion of residential households from oil heat to electric air-source heat pumps and is accommodating the adoption of electric vehicles through the development of public charging stations across the state. In addition, across the country we are seeing strong interest in and growth of rooftop solar PV systems, primarily related to the falling price of solar PV. While Maine has been slower than many states with respect to distributed solar PV, there is considerable pent-up demand for these systems, and we can expect to see their rapid growth and expansions over the next decade.

A second very important factor reinforcing the idea that the electric sector will undergo significant changes over the next two to three decades is that cities around the country, including Portland and South Portland, are committing to decarbonizing their economies. While these commitments are long on aspiration and short on strategy, they appear to be increasingly serious and likely to rely on the twin pillars of beneficial electrification and deep decarbonization through renewable generation development to accomplish their objectives. As noted earlier, very little progress can be made in either effort without accompanying changes to the electric grid.

GridSolar believes there is a unique opportunity to build upon the commitments of the cities of Portland and South Portland to become carbon free and to use the open docket at the MPUC. This docket can be used to focus on the transmission grid in the Portland region to identify inadequacies in current grid planning and design methodologies and to incorporate beneficial electrification and renewable distributed energy development as critical factors that will drive future electric grid requirements. GridSolar received strong support from the city managers of both cities and their sustainability departments for this concept, support that has been echoed by environmental and other interests in Maine. GridSolar brought this support and a proposal for funding to the so-called "E4 Group", made up on the Office of Public Advocate, the Conservation Law Foundation, the Acadia Center, the Industrial Energy Consumers Group and the Natural Resources Council of Maine.³ The proposal was approved in late 2018. GridSolar began work on the project in January 2019.

³ GridSolar is also a member of the E4 Group, which takes its name from the section of the Settlement Agreement approved by the MPUC in the MPRP case.

1.3 Project Overview

This report is organized into eight chapters corresponding to the major components of the analysis and modeling performed. Chapter 2 describes the Portland Region, which for our purposes is defined by the structure of the electric grid and not by political boundaries. Chapters 3 and 4 utilize many of the same methodologies and present many of the same analyses used by Dr. Silkman in his 2019 "A New Energy Policy Direction for Maine: A Pathway to a Zero-Carbon Economy by 2050". In this report, our focus is more limited to only those buildings and activities located within the Portland Region. In addition, rather than the statewide aggregated approach used by Silkman, we have developed energy use at the building level to enable us to examine use from a geospatial perspective.

Chapter 3 focuses on current energy use within the region. We estimated four types of energy use – current electricity use, space heating (including domestic hot water), commercial and industrial processes and transportation. These uses are produced using a wide variety of fuels. We included electricity, heating oil, natural gas, propane, diesel and gasoline. Since we included electricity, we did not include any primary energy fuels used to generate that electricity. In addition, we did not include biomass. Biomass is a relatively small percent of total fuel used in the region. Rather than include it, we assumed that whatever biomass that is currently being used will continue to be used, since it is a zero-carbon, renewable fuel. Finally, we did not include any fuels used for aviation or marine use. We are not aware of any electrification technologies that are currently economically viable for these two sectors of the economy.

In Chapter 4, we assumed that all space heating, commercial and industrial processes and transportation (not including aviation and marine use) in the Portland Area are converted from their current fuels to electricity – what has come to be known as "beneficial electrification". Our focus is on the end-state – that is, the point in the future when 100% of this conversion has been accomplished. We assumed that there is no net change in the amount of energy used from today's current energy use to this point in the future, with one exception – we allowed for increased use of air conditioning in residential buildings that is enabled by the adoption of air source heat pumps to meet space heating requirements in these buildings. The net effect of beneficial electrification is a more than doubling of total electricity use and an increase in peak electricity use from 270 MW, which currently occurs during the summer months, to 1,086 MW, which occurs during the coldest

winter months.⁴ However, because of the efficiencies in energy use as a result of converting the transportation sector from internal combustion engines to electric motors and the space heating sector from boilers and furnaces to heat pumps, the total amount of energy consumed falls by 59%, from 34 trillion btu to 14.1 trillion btu.

Chapter 5 focuses on the development of renewable distributed energy generation in the Portland Area. Given the geography, urban and rural development patterns, underlying economics of generation technologies and political realities of this part of Maine, we identified rooftop solar PV as the only viable distributed generation technology.⁵ Using city tax maps, GIS mapping capabilities, LiDAR (Light Detection And Ranging) data and weather data, we developed a model that allows the estimation of the rooftop solar PV capacity and generation potential of every building in the region. We used this model, along with certain parameters defining those rooftops where the installation of solar PV systems would be economic, to estimate the hourly solar generation from all buildings. We assumed that all viable rooftop solar PV installations could be interconnected to the electric grid at no cost to the solar PV owner for any upgrades upstream of its point of interconnection.

Chapter 6 combines the results of Chapters 4 and 5. We define the term "energy balances" to measure the difference between the use of electricity under beneficial electrification, as estimated in Chapter 4, and the generation of electricity from the full buildout of distributed rooftop solar PV, as estimated in Chapter 5. We calculated energy balances for the region, and for each electricity distribution circuit and transformer/substation in the electrical grid system in the region. In addition, we identified those circuits where the total solar PV generation is larger than interconnected loads and will result in reverse power flows, and we consider the role storage may play in this context. The magnitudes of these energy balances must be met by importing electricity from outside the region (up to 1,100 MW) and exporting electricity to outside the region (up to 550 MW).

Chapter 7 discusses the impacts beneficial electrification, deep decarbonization and the resulting energy balances at all levels of the electric grid have on electricity load forecasting

⁴ The percentage increases are lower for the Portland Region than for the State of Maine, as a whole. This is due in part to differences in the makeup of the economic base, smaller housing unit sizes (more apartments) and lower miles driven by car due to the density of the region.

⁵ We recognize that ground-mounted distributed solar PV systems are likely to be built in the Portland region, especially in the less densely populated portions of the region. For simplicity, our analysis makes no changes in the physical landscape or building footprints in the Portland region. Accordingly, we did not include any ground-mounted solar PV.

methodologies and on the capacity and design of the electric grid in the region. We identify a number of weaknesses in current planning processes and offer recommendations to address these.

Finally, in Chapter 8 we return our focus to the Portland Region and the design of a transmission and subtransmission grid that is capable of providing reliable electric service in a post beneficial electrification period where peak loads are roughly 3-times higher than they are today. At a high level and without subjecting the proposed design to rigorous reliability and stability testing, we estimate that the cost of the expansion and upgrades necessary are in the \$2.5 billion range, measured in today's dollars. This amount does not include upgrades to and expansions of the distribution grid.

In addition, we have included six Technical Appendices that provide additional detail and discussion of key modeling assumptions are results for various components of our analysis. We strongly encourage the interested reader to review these carefully. To the best of our knowledge, this is the first time anyone has attempted to merge the concepts of a zero-carbon economy and electric grid design. We welcome all comments on and critiques of our efforts to improve analytical methodologies in this area.

Chapter 2 - The Portland Region

2.1 Geographic Representation

For the purposes of this report, the Portland Region is defined electrically using the boundaries established by CMP in its February 2, 2018 Portland Area Analysis – Solutions Assessment.⁶ We refer to this document as the "CMP Study". While this electrical region generally conforms to physical and political features of the greater Portland area, it is not tied to political boundaries or geographic features. The region is defined as the area generally south of Brunswick, north of Saco and west of Gorham that lies electrically downstream of CMP's major 345 KV substations at Surowiec (Pownal) and South Gorham (Gorham). The municipal boundaries are shown on the map in Figure 2-1. The electrical region is shown on Figure 2-4 later in this chapter.

2.2 The Electrical Grid

We provide the electrical representation of the region in a manner consistent with how it is defined and characterized in the CMP study by focusing on transmission and distribution grid infrastructures and current electric loads served. The figures and tables provided below are taken from the CMP study. They are categorized as Critical Energy Infrastructure Information ("CEII") and are therefore confidential and not for public release.

2.2.1 Electricity Generation and Imports

With the exception of a few very small-scale distributed generation facilities, all electricity consumed by end-use customers within the Portland Region derives from five power plants located in the region and from electricity imported into the region. The power plants are the three oil-fired

⁶ Maine Power Reliability Program: Portland Area Analysis – Solutions Assessment – Final Report, Central Maine Power Company/RLC Engineering, Maine Public Utilities Commission, Docket No. 2011-00138, February 2, 2018.

units at Wyman in Yarmouth (Wyman 1, 2 and 3)⁷, the three natural gas-fired units at Calpine in Westbrook, the four diesel-fired generating units at Cape Station (located in South Portland), the multi-fuel generating plant at the Sappi Westbrook plant and the municipal solid waste generating plant (ECO-Maine) located off outer Congress Street in Portland. The region is interconnected to the New England electric grid through two 345 kV substations located at Surowiec and South Gorham. These substations have 345 kV/115 kV auto transformers that permit electricity to be delivered into the region from the bulk power system in a way that maintains a balance between electricity supplies and demands at all times.





⁷ The largest unit at Wyman, Wyman 4, sends all of its generation along a 345 kV generator lead that interconnects with the larger electric grid at South Gorham. Accordingly, it is electrically equivalent to electricity imported into the region at South Gorham.

2.2.2 High Voltage Electric System

The high voltage or transmission system within the Portland Region consists of all 115 kV and 34.5 kV transmission lines and related substations. We have included electrical one-line representations of each voltage level separately in Figure 2-2 and Figure 2-3, respectively. Most of the region is served off the 115 kV loop formed by the Moshers, Cape, Pleasant Hill and South Gorham substations. The exception is the area north of Portland, including Falmouth, Cumberland, Yarmouth, Freeport and Gray. These areas are tied into the 115 kV loop at the Spring Street and Mosher substations. In addition, this part of the grid is capable of being back-fed from Wyman Units 1, 2 and 3 through the Elm Street substation in Yarmouth. However, since these generating units rarely operate given fuel prices and current electric market conditions, this portion of the region's electric grid is fed for all intents and purposes off the same 115 kV loop as the rest of the region.⁸

The underlying 34.5 kV system presents a more nuanced picture of electric service in the region. Most of the City of Portland and areas south within the region are served off looped 34.5 kV systems that allow for the areas to be served from any point on the loop. Nevertheless, outages of certain 115 kV lines or transformers in this part of the region can create reliability problems for the grid under certain load conditions. The area to the north of Portland is served at 34.5 kV off the Prides Corner substation in a radial fashion, with support at Elm Street in Yarmouth from the Wyman units referenced earlier either when they generate electricity or through the 115 kV system interties at Elm Street substation. A problem with this part of the grid is that outages of components of the 34.5 kV system at either Prides Corner or Elm Street can result in load flows on the 34.5 kV system in this part of the region that exceed the ratings of certain system components.

⁸ We understand that Wyman Units 1 and 2 cleared as delisted units in the recent FCM auction conducted by ISO-NE and will be decommissioned in the near future.

Figure 2-2 Electrical Representation of 115 kV System in the Portland Region

REDACTED - CEII

CONTAINS CONFIDENTIAL ENERGY INFRASTRUCUTRE INFORMATION

•

Figure 2-3 Electrical Representation of the 34.5 kV System in the Portland Region

REDACTED - CEII

CONTAINS CONFIDENTIAL ENERGY INFRASTRUCUTRE INFORMATION

2.2.3 Distribution System

The distribution system in the region consists of all parts of the electric grid with voltages below 34.5 kV. These include what are often referred to as "feeder circuits" or simply "circuits" and encompass the poles, conduits and wires that deliver electricity at 12.5 kV overhead or underground to end-users. CMP has 96 such feeder circuits in the region.

We have shown these circuits on a map of the region in Figure 2-4. As a general rule, these circuits extend in a radial fashion from one of the 29 CMP 34.5 kV substations across the region, although there are a few feeder circuits that come directly off the 115 kV system.⁹

While electricity flows in multiple directions on the 34.5 kV and 115 kV portions of the transmission system, the manner in which electricity flows on the distribution system is generally in one direction – from the substation out to the customers. Where distributed generation is interconnected to the distribution system and where the output of that generation exceeds the load behind the point of interconnection, excess generation will flow onto the distribution system. If this excess generation does not exceed the total of all loads that are downstream along the same circuit, the distributed generation will not alter the direction of the flows of electricity out from the substation. On the other hand, if this generation exceeds such load, the generation will reverse electricity flows at that point, so that those flows are upstream toward the substation. This could create reliability problems for the grid, depending on whether the grid is designed to accommodate such upstream flows.

Figure 2-4 illustrates the general mismatch between political boundaries, on the one hand, and the design of the electrical grid, on the other. While there are some distribution circuits that lie wholly (or virtually entirely) within a municipality, many of the distribution circuits cross municipal boundaries and serve residents and businesses in adjacent municipalities. This adds a level of complexity to modeling current energy use and the consequences of beneficial electrification within a fully integrated electrical grid that has evolved over the years in response to electrical use rather than the physical shapes of cities and towns. As the use of electricity expands as sectors such as

⁹ The map does not show any of the secondary distribution components. These are the parts of the distribution system that are downstream of distribution transformers – usually the service drops to individual customers. We have not included this part of the grid in our studies. Our focus is only on CMP's primary system.

transportation and space heating are converted from fossil fuels to electricity, the electric grid will need to expand to accommodate such use. New transmission lines, substations and distribution circuits will be required. While we might expect that some of this new capacity will lie within the same rights-of-way as the existing electric grid, it is quite likely that the requirements imposed by beneficial electrification, some of which we illustrate later in this report, as well as a few decades of economic changes as beneficial electrification occurs will result in an entirely new electric grid structure in the region. For this reason, we use the existing grid and load flows on that grid only to benchmark our modeling efforts and to illustrate the current grid's inadequacies.





Chapter 3 - Current Energy Use

3.1 Introduction

In this chapter, we discuss out estimates of current energy use for each building located in the Portland Area. Because our purpose is to assess current and future energy use in relation to the existing electric grid, our unit of analysis must be geospatial and capable of being mapped to the existing electric grid. Buildings serve this purpose well.

We focused on four types of energy use. The first is current electricity use. This includes all electricity that is delivered by CMP to each building in the region. The other three are non-electric. The first of these is energy used in the transportation sector. This includes gasoline and diesel fuel used by passenger vehicles, buses and trucks. While there is some very small amount of natural gas and propane used for transportation, we ignored this, effectively treating all such use as either gasoline or diesel fuel. The second non-electric form of energy is energy used to provide space heating and "domestic" hot water. The fuels used for this purpose include home heating oil, natural gas and propane. While there is some electric heat in the buildings in the Portland Area, the penetration is very low. We corrected for this in subsequent sections of the report. ¹⁰ The last form of energy is energy that is used in commercial and industrial processes. Where such processes are powered by electricity, this energy was included in current electricity use. The remainder of process energy use consists of fossil fuels, primarily natural gas and heating oil.

3.2 Current Electricity Use

There are two general approaches for estimating current electricity use. One approach is to obtain from CMP annual usage information for each service address. This information is available to CMP from the Advanced Metering Infrastructure ("AMI") and smart meters CMP has installed across its entire service territory. This data is confidential and generally not available for use in this type of research work. Even if it were available, however, it may not be the best option. Using

¹⁰ We did not consider wood fuels (e.g., cord wood and pellets) in this study. The amount of such fuel remains quite small and to the extent that it exists currently, we assumed that the same amount of such use will continue in the future. For example, South Portland reports that only 689 out of 13,205 buildings are heated with wood or coal.

existing usage by service address, in effect, fixes the use of each building and its occupancy to those that exist currently. This may be too constraining, especially for larger commercial and industrial buildings where the use of space is frequently changing as occupancy changes. Production space becomes warehouse space; warehouse space becomes production space; and different types of buildings undergo conversions to support entirely different end-uses.

As an alternative to relying on metered electric use, we modeled current annual electricity use for each building based on three factors – (i) the characterization of that building as either residential, commercial or industrial, (ii) our estimate of that building's square footage and (iii) the annual electricity consumption per square foot for each category of building based on EIA data and other sources. This approach locks in each building's classification as residential, commercial or industrial, but within each category, it uses average energy use characteristics. This approach loses some of the richness associated with specific end-uses that are far from the sector averages – e.g., industrial warehouses, arc-furnace operations, commercial laundries and data centers. This becomes less of a problem as the geographic area of focus increases and the effects of the law-of-largenumbers begins to dominate, driving aggregate energy use within each sector closer to the average for that sector.

3.2.1 Data and Methodology

The first step was to assign each building as a residential, commercial or industrial building. We did this using the building information contained in the tax databases for each municipality where available, and where not available based on zoning and visual inspection. We assumed that any building that shares the same parcel with another building for which there is descriptive information (e.g., heat fuel, heat type, building type) also shares the same attributes. We excluded parking lots, private lots, and the large oil fuel tanks (primarily concentrated along South Portland's waterfront) from this analysis, as the energy use of these buildings is small and not consistent with the energy use of buildings in the commercial and/or industrial categories.

The second step was to calculate the total square footage for each building. This was done by first taking each building's footprint, converting the footprint to square footage and multiplying it by the number of stories in the building. We obtained building footprints from Microsoft's various tools or directly from municipal databases. The number of stories was calculated by taking the raster dataset and subtracting each building's height above sea level (ASL) from the ground elevation ASL

to estimate each structure's true height. Then, each building's eave and peak roof height was calculated using ArcGIS's Roof Extraction tool.

Next, we divided each residential building's structural height (from the eave line whenever present) by 3 meters, commercial by 5 meters and industrial by 8 meters, which we assumed as the average building story heights by building classification, to obtain the number of stories per structure (we rounded down any fractions of stories). This number was then multiplied by the building's footprint to derive the total square footage for the entire structure. We only included buildings with a footprint greater than or equal to 500 square feet to eliminate detached garages, sheds and other outbuildings. Manual corrections were made for any structures that did not contain a building type designation by the city. We did this using Google Street View and aerial imagery as a form of verification.¹¹

The methodology for calculating the square footage of each building was field-tested by visual inspection of a random sample of residential, commercial and industrial buildings in the region. Using Google Street View and other detailed images of these buildings, we calculated total square footage and compared this calculation to our overall methodology. We found that our methodology overestimated residential building square footage by about 5% and commercial square footage by about 15%. It was pretty much spot-on for industrial building square footage. We then adjusted each building's square footage by these respective percentages.

Table 3-1 presents the results of this methodology. There a total of 73,000 residential buildings, 6,167 commercial buildings and 1,003 industrial buildings in the Portland Area, with a total of just under 300 million square feet.¹²

We relied on different data sources to estimate energy use per square foot for residential, commercial and industrial building types. Table 3-2 shows how our estimate for residential electricity use per square foot was derived. We divided total statewide residential electricity

¹¹ We found that we could not rely on the building square footage reported in the municipal datafiles, as the municipal data was inaccurate and/or not properly formatted to assign total square footage to each building's footprint. This was verified through ground truthing that was performed by conducting site visits as well as using aerial imagery, Google Street View, and comparing the city's data to the LiDAR derived results.

¹² We note that the number of residential buildings and the average square footage per building is not the same as the number of households and the average square footage of dwelling units. Our modeling focuses on the building footprint and its height. As a result, we treat multi-story residential apartment buildings, for example, as a single building even though they may include multiple apartment units. This does not impact the total amount of square footage in the building and therefore energy use, as discussed below.

consumption by estimated total residential square footage in Maine. The result is 3.724 kWh/square foot/year ("Residential Electric EUI").¹³

Table 3-1Summary of Buildings in the Portland Area

	Residential Buildings	Commercial Buildings	Industrial Buildings	Total
Number of Buildings	73,000	6,167	1,003	80,170
Total Square Footage	209,782,673	67,793,059	18,802,851	296,378,583
Average Square Footage per Building	2,874	10,993	18,747	10,871

Table 3-2Estimated Residential Electricity Use per Sq. Ft.

Total Annual Residential Electricity Consumption (1)	MWh	4,638,535
Type/Number of Residences (2)		
Single Family Homes	No.	517,613
Multi-Family Homes	No.	156,163
Mobile Homes	No.	61,935
		735,711
Type/Average Size of Residences (3)		
Single Family Homes	sq.ft.	2,000
Multi-Family Homes	sq.ft.	950
Mobile Homes	sq.ft.	1,000
Total Residential Square Footage	million sq.ft.	1,246
	kWh/sq.ft.	3.724

Sources

(1) Energy Information Agency - Maine 2017

(2) Maine State Housing Authority - 2008-2012 and 2013-2017 American Community Survey Table B25024; B25032

(3) Residential Energy Consumption Survey (RECS) - 2015, New England https://www.eia.gov/consumption/residential/data/2015/index.php?view=consumption#by%20fuel

¹³ As we note later in this section, we reduced this statewide average by 10% to 3.35 kWh/sq.ft. to better match actual loads we see in the Portland Area.

We estimated electricity usage per square foot for commercial space based on a detailed study performed on behalf of Efficiency Maine Trust in 2015.¹⁴ This study computed end-use electricity consumption for eight categories of commercial buildings. The results ranged from a low of 6.1 kWh/sq.ft. for warehouse buildings to a high of 60 kWh/sq.ft. for food sales and restaurants where there is significant refrigeration required. Office, retail, lodging and clinic facilities were all clustered in the 10 - 13 kWh/sq.ft. range. The study did not compute an average across all facilities. We have used a figure of 11 kWh/sq.ft. ("Commercial Electric EUI") for all commercial buildings in the region. We verified this figure using EIA data. Nationally, total energy use on average across all commercial buildings is about 80,000 btu/sq.ft., about 50,000 btu/sq.ft. of which is electricity. This equals just under 15 kWh/sq.ft. The comparable figure reported by EIA for New England is 12.1 kWh/sq.ft.¹⁵ We would expect New England to be a little less than the national figure, since air conditioning loads are lower, and Maine to be slightly lower still.

It is more difficult to develop a single estimate for industrial electricity use per square foot because of the wide range of process activities that occur within industrial facilities and their relative electricity use intensities. Buildings like the semiconductor plants in South Portland have very high electricity use per square foot, while other industrial facilities such as the boatyards in Portland have relatively low electricity use per square foot. One approach to address the heterogeneity in energy use intensities across industrial classified buildings is to use information about the nature of operations at these buildings or their North American Industry Classification System (NAISC) code where available. This methodology provides some diversity in electricity use intensities across circuits serving industrial buildings. On the other hand, it has the disadvantage of locking in the current use of that industrial space for the foreseeable future. Given the changes that have occurred in Maine's economy and those that are likely to occur over the next few decades, this may not be the best option, even for buildings housing the two major semiconductor operations in South Portland.

An alternative approach, and the one we adopted, is to use average electricity use values for all industrial buildings regardless of how the space is currently being used. This methodology locks in the building footprint but does not lock in current use. Instead, it has the effect of treating all

¹⁴ "Commercial Building Interval Meter Data Analytics Study – Final Report, submitted to Efficiency Maine Trust by Retroficiency and Cadmus, November 25, 2015, Table B1, page 25.

¹⁵ <u>https://www.eia.gov/consumption/commercial/reports/2012/energyusage/</u>

industrial buildings as essentially homogeneous space and assigns average energy use intensities to all spaces. We use 12 kWh/sq.ft. ("Industrial Electric EUI"). We note that the average industrial electricity EUI across all industries in the U.S. is 76 kWh/sq.ft. The range is from 11 kWh/sq.ft. for furniture making to over 2,000 kWh/sq.ft. for refineries and petro-chemicals.¹⁶ This figure, however, includes all electricity use, including electricity used for process purposes. Since we treat process use separately, see Section 3.4, we need to use a lower figure than the national average.

Multiplying the EUI for a building's category by the square footage of the building results in total annual electricity usage for each building in the region. To model the impact of electricity use on the transmission and distribution grid, this total annual usage must be apportioned to each of the 8,760 hours of the year. We did this by using the CMP residential class hourly load profiles for residential buildings and the CMP medium general service hourly load profiles for both commercial and industrial buildings. This resulted in an electricity usage matrix consisting of 73,000 residential buildings, 6,167 commercial buildings and 1,003 industrial buildings and for each building for 8,760 hours of estimated electricity use.

3.2.2 Results

The results of the calculations described above were tested by comparing these results to actual hourly loads provided by CMP for ten individual circuits in the region. These ten circuits were chosen because they were the only circuits for which CMP provided us with hourly electricity flows. The circuits include approximately 15,000 residential, 850 commercial and 175 industrial facilities with a total actual annual electricity usage of 240,000 MWhs. Figures 3.1 and 3.2 provide a comparison between CMP's actual hourly electricity flows across all ten circuits and our estimates of those flows. Figure 3.1 shows the data by month. Figure 3.2 shows the same comparison by hour of the day over the 12 month year. The graphs confirm the validity of the underlying electric load models. Across the range of circuits, our model predicts total electricity usage of 230,000 MWhs – or 4% below actual usage. (More detail on this validation can be found in Appendix A.)

¹⁶ https://www.eia.gov/consumption/manufacturing/data/2014/#r13.









We estimate that total current electricity usage across the region is about 1.8 million MWh. The breakdowns by residential, commercial and industrial customers for the region is shown later in this chapter in Table 3-3.

3.3 Transportation

Transportation is, by definition, mobile. This fact makes it very difficult to associate the actual use of energy with any specific geospatial location. There are three conventions that can be adopted for assigning fuel use to geographic locations, albeit often for very different purposes. First, there is the place where fossil fuels are purchased. This has the relatively attractive attribute that good spatial data is generally available for the delivery of fuel at wholesale and the sale of such fuel at retail. On the other hand, this method leads to an artificial concentration of use based on the assignment of fuel use to fuel delivery locations.

The second approach is based on miles travelled. States and various industry groups keep relatively good data on the number and types of vehicles using state road networks and the number of miles travelled by these vehicles. This measure is better for larger geographic areas such as a state that encompass most of the physical locations of a vehicle while that vehicle is in motion. It is less applicable for small geographic areas that may encompass only a fraction of total vehicle use.

The third method is where the vehicles are garaged or based. This has the useful feature of assigning energy use to the physical location of the owner or operator of the vehicle rather than the place where fuel is purchased or the state/city in which the vehicle is driven. As we note later in this report, we believe that this convention will be more applicable as we convert to electric vehicles. Electric vehicles are likely to charge at their base locations. This better matches the locations at which vehicles draw fuel off the electric grid with the use of that energy. Accordingly, we use this measure to assign current transportation related energy use geospatially across the region.

3.3.1 Passenger Vehicles

Passenger vehicles are defined by the Secretary of State in Maine to include cars, SUVs, and pickup trucks, where such vehicles are not commercially registered. There are reported to be just under 1 million such vehicles registered in Maine. The Secretary of State's Office provided registrations by municipality. We apportioned the number of passenger vehicles in each municipality by the total residential square footage to determine the geospatial location of each of the vehicles by residential building.

Passenger vehicles in the Portland Area log an average of 10,000 miles per year.¹⁷ Assuming an average fuel efficiency of 25 miles per gallon, total annual gasoline fuel consumption is about 400 gallons or roughly 47 mmbtu per year for each passenger vehicle.

3.3.2 Buses

The Maine Secretary of State reports that there are 4,455 buses registered in Maine, 3,000 of which are classified as school buses. These buses log about 120 million miles a year or approximately 28,000 miles per bus. If we assume that the 70% of the buses that are school buses operate only on weekdays while the remainder operate over the entire seven-day week, the average miles driven per day by bus is roughly 100 miles. If we further assume that buses average 6 miles per gallon, each bus will consume a little under 5,000 gallons of fuel per year, the majority of which will be diesel fuel. This fuel consumption has the energy equivalent of about 700 mmbtu/year.

We obtained from each municipality the number of school buses and city buses, where applicable, that are garaged in each municipality. Portland, for example, reported a total of 44 city buses and 32 school buses. South Portland's totals were reported as 7 and 26, respectively.¹⁸ These buses are garaged at specific locations within the region. We identified those locations and allocated the bus fleets to the buildings at these properties for purposes of assigning charging load to CMP circuits once they have been converted to electricity under beneficial electrification. We describe this process further in the next chapter.

3.3.3 Trucks

The category "trucks" includes vans, single-unit and combination trucks. There are roughly 76,000 registered trucks in Maine, about 7,600 (or 10%) of which are tractor trailer or combination units. Trucks log an estimated 1.2 billion miles in Maine for an average of just under 16,000 miles

¹⁷ This is different than what would be obtained by dividing the total number of passenger vehicle miles driven (as estimated by the Maine Department of Transportation) by the number of passenger vehicles registered. The numerator in this calculation is higher, because it includes miles driven by non-Maine registered vehicles. Given the tourism activity in Maine, most of which is tied to visitors driving into and around the state, the total energy used by all passenger vehicles regardless of state of registration is higher. Since most of this visitor travel is not located in the Portland Area, we have not included it in our energy modeling.

¹⁸ Portland and South Portland are the only municipalities that reported city buses. There are 356 school buses reported in the Portland Area.

per truck per year. Assuming the average fleet-wide efficiency of these trucks is 12 miles per gallon (this is based on the ratio of car registrations to tractor trailer registrations of roughly 10-to-1), the average truck uses approximately 1,330 gallons of diesel fuel a year. This is the energy equivalent of about 186 mmbtu/year.

The Secretary of State's Office provided registrations by truck class for each municipality. There are a reported 20,061 registered trucks and 1,495 registered tractor-trailers across all municipalities in the Portland Area. Given the wide variety of ownership of these trucks (e.g., the U.S. Post Office, FedEx, commercial establishments, individual contractors), it is difficult to know how many such vehicles are garaged or otherwise based in this region and then to know how to allocate these vehicles spatially across the region for purposes of assigning fuel use to specific buildings.

We use the same approach for allocating the non-tractor-trailers geospatially as we do for passenger vehicles – based on total residential building square footage. This is likely to reasonably approximate energy use for commercial vehicles owned by contractors or other businesses. It is less likely to capture accurately by geographic location the energy use of fleet vehicles.

We allocate the 1,495 tractor trailers in the region to specific areas of the region that currently support tractor terminals of one form or another. To do this, we divided the region into 483 squares of ¹/₄ mile by ¹/₄ mile in size and identified those squares that we believe appropriate for basing truck fleets. Next, we allocated the 1,495 tractor-trailer trucks proportionately to all commercial and industrial building locations within these squares. By assigning the trucks to buildings, we assign them to existing CMP distribution circuits so that charging loads for these vehicles could be sited under beneficial electrification.

3.3.4 Other Transportation

There are three additional transportation sector end-uses of fuel in the region – marine use, airplanes and railroads. Portland and South Portland, in particular, have major port facilities that support both commercial and recreational marine activities that consumes fossil fuels. In addition, the Portland Jetport is a regional air transportation hub that provides commercial and private passenger and air-freight services. Finally, there is commercial and passenger rail service that originates out of the South Portland and Amtrak facilities, respectively. The total amount of diesel, gasoline and jet fuels used across these facilities is not available in any public data. Rather than guess

34

at usage, we have omitted each of these end-use sectors from our study. Combined, these end-use sectors represent a small percent of total energy use and will have no appreciable effect on the results.

3.4 Space Heating/Commercial and Industrial Process Energy

We define energy used for "space heating" as inclusive of all energy used to heat interior space, provide hot water for domestic purposes and for cooking and related activities, but not for commercial or industrial processes. Buildings are generally heated with natural gas or distillate fuels (including heating oil, propane, kerosene and residual oil), although there are some larger industrial buildings that may be heated with coal. The number of buildings that are currently heated with electricity is small. Based on detailed data available for South Portland, less than 2% of residential buildings and less than 7% of commercial buildings are heated with electricity. (See Table 3-3.) For these buildings, electricity used for space heating is already included in current electricity use.

Table 3.	-3 Heating F	uel by Build	ing Types -	- South P	ortland			
	Heat Type	Resid	ential	Com	mercial	Ind	ustrial	Total
	Electric	206	1.7%	60	6.8%	21	11.1%	287
	Gas	3,282	27.1	366	41.3%	50	26.3%	3,698
	Oil	8,617	71.1%	428	48.3%	107	56.3%	9,152
	Wood or Coal	23	0.2%	33	3.7%	12	6.3%	68
	Total	12,128	100%	887	100%	190	100%	13,205

Values represent how many buildings use each type of heat as well as the percentage within each building category. There are 617 buildings that do not have a heat type designation.

EIA provides statewide data for monthly natural gas use in Maine by class of customer – residential, commercial, industrial, transportation and electric generation. The class usage is not further broken-down by end-use (e.g., space heating, hot water, processes). This is not a concern for the residential class, where we assume that all-natural gas is used for non-process purposes. However, as we note below, it does present a problem for the commercial and industrial customer classes, where some companies use natural gas for both space heating and process purposes. The discussion that follows describes how we have determined fuel used in each of the buildings for space heat, and how such usage is apportioned by hour over the course of a year. Ordinarily, this apportionment by hour of use is not of much analytical value. However, since fossil fuel used for

heating is to be replaced by electricity post beneficial electrification, the hourly consumption pattern of that electricity is critical for the sizing and design of electric grids.

We begin by computing a residential heating energy use intensity which we refer to as the "Residential Heating EUI". We define this as all energy used by residential buildings that is not electricity. We relied on the Maine Governor's Energy Office estimate of 50,000 btu/sq.ft. as the statewide average energy used to heat a Maine residence.¹⁹ If we multiply this EUI by the total square footage of each residential building, we obtain the annual energy used for space heating in that building. For a residential unit of 2,000 sq.ft., the total annual energy used is about 715 gallons of heating oil equivalent.

Next, we developed an hourly profile of residential building space heating use based on the ratio of the heating degree days, ("HDD") that hour to the total HDD for the year.²⁰ This results in an hourly profile across the 8,760 hours of the year that defines the percentage of annual energy used for residential heating purposes each hour. Multiplying each hour's percentage of total annual energy use by the total annual amount of fuel used by each residential building results in hourly fuel use for that building. Total residential space heating across the Portland Area is then computed by summing across all 73,000 residential building in the region.

The method for estimating energy used for space heating for commercial and industrial buildings is more complicated than for residential use. EIA reports that total energy consumption per square foot for all commercial buildings in New England is 85,500 btu/sq.ft.²¹ Of this amount, roughly 47% or 40,000 btu/sq.ft. is electricity. This equates to approximately 12 kWh/sq.ft., as noted in the previous section. The same data shows that roughly 36,000 btu/sq.ft. is used for space heating. We used this figure as the Commercial Heating EUI and allocated this annual total to each hour of the year based on HDD. We defined the remaining 10,000 btu/sq.ft. as Commercial

¹⁹ <u>https://www.maine.gov/energy/fuel_prices/heating-calculator.php.</u> This is the statewide average and does not include energy used for domestic hot water. We reduced the 50,000 btu/sq.ft. by 10%, since the region has fewer heating degree days ("HDD") than the statewide average. We then increased it by 10% to account for energy used for domestic hot water. This results in an estimated Residential Heating EUI at 50,000 btu/sq.ft. for residential buildings in the Portland Area.

²⁰ We use the hourly temperatures for Maine as reported by ISO-NE for calendar year 2017.

²¹ Source: U.S. Energy Information Administration, Office of Energy Consumption and Efficiency Statistics, Form EIA-871A of the 2012 Commercial Buildings Energy Consumption Survey.
Process EUI. We used these two EUI measures to estimate the amount of energy used by each commercial building for space heating and process end-uses.

EIA reports energy use for industrial buildings for total electricity used and for the total of all other fuels used. These values can be used to create EUIs for electricity and for all other energy sources. Unlike for commercial buildings, however, the EIA data does not distinguish between space heating and process end-uses for industrial buildings. This distinction can be important. Each end-use has different seasonal and daily patterns, and these patterns will become important as we look to replace fossil fuel use with electricity later in the report.

A further complicating factor is that the range of non-electric EUIs in the industrial sector is much larger than in the commercial sector. Total building EUIs across commercial sectors range from as low as 10,000 btu/sq.ft. for retail malls to as high as 125,000 btu/sq.ft. for inpatient hospital facilities. By comparison, industrial EUIs range from a low of about 40,000 btu/sq.ft. for "furniture and related products" to over 100 million btu/sq.ft. for "petrochemicals" (the national average across all industrial sectors is a little over 1 million btu/sq.ft.).²² We have used the 36,000 Commercial Heating EUI as an estimate for Industrial Heating EUI, on the assumption that energy used for space heating is not closely related to what goes on inside the space, and allocated this by hour using the same HDD methodology as we used for residential and commercial buildings. On the other hand, we have increased the Commercial Process EUI of 10,000 by a factor of 10 to 100,000 btu/sq.ft. as the Industrial Process EUI. This results in a total, all-energy industrial EUI of about 177,000 btu/sq.ft., which is 13.5% of the national average of 1.3 million btu/sq.ft.

We have no direct way to allocate total annual energy used by commercial or industrial buildings for process purposes by hour of the year. As a proxy, we used the hourly electric load profiles of commercial and industrial buildings to allocate process fuel use on the assumption that both are correlated with overall building activity. We multiply the Commercial Process EUI and Industrial Process EUI by the total square footage of each building to determine annual energy used for process purposes at that building. This is multiplied by the apportionment factor for each hour

²² Source: U.S. Energy Information Administration, Office of Energy Consumption and Efficiency Statistics, Form EIA-846, '2014 Manufacturing Energy Consumption Survey.'

for commercial and industrial buildings, as appropriate, to generate hourly fuel usage for process purposes in each of the commercial and industrial buildings.

3.5 Summary of Current Energy Use

We present estimated total energy used in the Portland Area in Table 3-4. This table shows the total energy used across all residential, commercial and industrial buildings in each city by the four end-uses of that energy – electricity, space heating, commercial and industrial processes and transportation. We show energy use represented in MWh for electricity and mmbtu for all other fuels We have divided total energy used for heating and process in each class by fuel - natural gas versus heating oil – based on our knowledge of the natural gas distribution system in each of the municipalities in the region. The relative shares of each fuel are shown in the column labeled "Load Share". This allocation does not impact any subsequent analysis of conversions of these fuels to electricity; the only effect is on current CO₂ emission levels, since natural gas and heating oil have different emission rates per mmbtu. Total energy use in the region is 34 trillion btu. Figure 3-8 presents the relative shares of energy consumed by each end-use and by each customer classification.

All energy use in Table 3-4 is measured at the electric meter or at the burner tip of the heating or process equipment. Using standard EPA figures for emissions per mmbtu for fossil fuels and an average emissions factor of 500 lbs/MWh for electricity,²³ total annual CO₂ emissions are a little over 2.5 million tons per year. [Comparable data for each of the municipalities in the region can be found in Appendix B.]

²³ Since the 500 lbs/MWh emissions figure for electricity is measured at the generator, we need to account for transmission losses. We estimate these losses at 8% for Portland and South Portland.

Table 3-4Total Energy Use for the Portland Region by Class and End-Use

Class / End-Use			
Residential		Share	2020
Electricity	MWh		703,152
Heating	mmbtu		10,489,261
Natural Gas	mmbtu	10%	2,529,060
Heating Oil	mmbtu	90%	7,960,201
Commercial			
Electricity	MWh		745,724
Heating	mmbtu		2,440,550
Natural Gas	mmbtu	20%	1,187,997
Heating Oil	mmbtu	80%	1,252,554
Process	mmbtu		677,931
Natural Gas	mmbtu	20%	336,140
Heating Oil	mmbtu	80%	341,790
Industrial			
Electricity	MWh		231,357
Heating	mmbtu		694,072
Natural Gas	mmbtu	30%	467,576
Heating Oil	mmbtu	70%	226,496
Process	mmbtu		1,927,978
Natural Gas	mmbtu	30%	1,298,821
Heating Oil	mmbtu	70%	629,157
Transportation			
Passenger Vehicles			
Gasoline	mmbtu		8,593,214
Electricity	MWh		0
Commercial Trucks			
Gasoline	mmbtu		2,583,087
Electricity	MWh		0
Buses			
Diesel	mmbtu		201,309
Electricity	MWh		0
Heavy-Duty Trucks			
Diesel	mmbtu		709,710
Electricity	MWh		0
Totals			
Electricity	MWh		1,680,233
Natural Gas	mmbtu		5,819,594
Heating Oil	mmbtu		10,410,198
Gasoline	mmbtu		11,176,300
Diesel	mmbtu		911,019
Total CO ₂ Emissions	tons		2,549,202



Figure 3-3Percent Energy Use by End-Use and Economic Sector

Chapter 4 - Beneficial Electrification

4.1 Overview

In the previous chapter, we estimated total energy use in the Portland Area as 34 trillion btu. The use of this energy creates an estimated 2.5 million tons of CO₂ emissions annually, roughly 36% of which is created by the transportation sector and 48% by space heating and commercial and industrial processes. By comparison, 16% of all emissions originate from the use of electricity. In order to eliminate all CO₂ emissions and achieve a zero-carbon economy across the region, all heating, transportation and process energy end-uses must be converted to electricity through beneficial electrification and that electricity must be generated from zero-emission generation technologies through deep decarbonization.

Our focus in this chapter is on the conversion of all passenger vehicles, buses and trucks in the two cities from gasoline and diesel fuels to electricity; on the conversion of all space heating across all buildings in the region from heating oil, natural gas and propane to electricity; and on the conversion of all distillate fuels and natural gas used for process purposes by commercial and industrial companies in the region to electricity.²⁴ We are not concerned with how long these conversions will take or how much they will cost residents and businesses. These are both certainly very important issues and ultimately will determine whether the conversions occur. Our focus is more limited to how much more electricity will be consumed and during which hours that consumption will occur as a result of beneficial electrification. In a later chapter, we will explore what this increased use means for electric system planning, the pace at which the electric needs to be built out and the capacity and design of electric grids.

4.2 Transportation

Electrification of the transportation sector has been the most visible and most discussed component of beneficial electrification in the U.S. and around the world. Most of the attention has

²⁴ In addition, because conversion of residential heating to electricity involves the replacement of home furnaces with air source heat pumps, we also include incremental electricity use that results from using these heat pumps to provide air conditioning.

focused on passenger vehicles. Increasingly, we are seeing attention spread to buses, as electric buses are being adopted by cities across the country. We are also beginning to see some attention by Tesla and Volvo, among others, pushing the sector forward with designs and prototypes for trucks, including long-haul tractor trailers. The speed with which the conversion of different classes of vehicles occurs will depend on many factors, including the life-cycle costs of ownership, the range of travel offered, the ubiquity of charging stations and the time it takes to recharge vehicles. We focused in this report on the end-state when all passenger vehicles, light trucks, buses and trucks in the region are converted to electricity. In addition, we made certain assumptions described below about the efficiencies of the different classes of motor vehicles, measured not in miles per gallon, but in miles per kWh of electricity used. Finally, we assumed that annual vehicle miles traveled for each class of vehicle remains the same under beneficial electrification as it is today. The only thing that changes is that the vehicles are powered 100% by electricity.

4.2.1 Passenger Vehicles

It is relatively straightforward to convert the total annual amount of gasoline and diesel fuel used to power passenger vehicles to an equivalent annual amount of electric energy required. All we need to do is make some assumptions about how many miles the vehicle travels each year and the vehicle's operating performance. The difficulty is determining when and where the electricity will be drawn off the grid and stored in the battery systems of these passenger vehicles. This is necessary to define the hourly profile of electricity use over the course of the year, and then, based on where the charging occurs, to evaluate the impact of this conversion on the electric grid. To the best of our knowledge, there have been no studies of how Maine electric passenger vehicles in the region will act. As a result, we were forced to rely on studies from other states and to modify the results of those studies to reflect Maine driving patterns and weather conditions.

One of the more detailed studies of driver charging behavior is a study done by the California Energy Commission and released in March 2018.²⁵ A major component of this study involved the survey of travel behavior of households. This survey was used to develop a simulation

²⁵ California Plug-In Electric Vehicle Infrastructure Projects: 2017-2025," California Energy Commission Staff Report, March 2018 | CEC-600-2018-001.

of passenger vehicle travel for 1.3 million passenger vehicles across California. These results were combined with assumptions about the number and location of electric vehicle chargers to create hourly charging profiles for typical weekdays and weekends. We extracted these profiles from that study and present them in Figure 4-1.

The study assumed that electric passenger vehicle charging is done at four types of chargers. The most widely used are Level 1 (L1) and Level 2 (L2) chargers located at each vehicle owner's residence. This charging generally occurs during the evening hours, extending into the overnight hours, as the required charging time increases. Some amount of charging is done during the day at L2 chargers located either at the workplace or at public facilities such as parking garages, shopping malls, and similar types of locations. This charging tends to be concentrated during morning workday hours for charging done at the workplace and during afternoon hours at the other locations. Fast chargers that are located on highways and other heavily traveled routes account for the remaining charging that occurs. This charging occurs during the day and evening hours. The charging pattern for weekdays and weekends is similar, with a few notable differences. The first difference is the electricity load shape for weekday charging is more peaked than for weekends. Second, there is less charging done at the workplace on weekends. Finally, there is more charging done at fast chargers and at public L2 charging locations on weekends.

These two graphs can be used to estimate the hourly electricity consumption required to charge all of the 250,000 passenger vehicles in the region. We have done this by applying the results of the California Study to Maine as a whole, after having made a number of modifications to reflect differences between the two states. First, we scaled the California results down based on the ratio of the number of Maine passenger vehicles (928,132) to the number of passenger vehicles in the study (1.3 million). Second, we scaled the results up slightly to reflect the fact that the number of miles driven per vehicle in Maine is higher than in California. Third, we adjusted the results to reflect differences in monthly travel in Maine, measured in vehicle miles driven per month, and for the fact that miles/kWh of electricity consumption tends to be lower in Maine during cold months when the battery in electric vehicles is called upon to provide heat to the passenger compartment. With respect to this latter adjustment, we assumed that passenger vehicles get 4 miles/kWh during the summer months, 3 miles/kWh during the months of January and February and somewhere in between for the other months. The average miles/kWh over the course of the year is 3.60. This is comparable to what is reported by owners of the Chevy Bolt in New England, but a bit higher than

the Tesla models achieve today. We used this higher value to account for improvements in vehicle efficiency over the next couple of decades as more and more electric vehicles are produced.



Figure 4-1 California Study Results – Electric Charging Profiles for Passenger Vehicles



Finally, since state level data indicates that passenger vehicles in the Portland Area put on fewer miles each year than Maine vehicles on average, we adjusted down the Maine level data to reflect this lower annual miles driven level. The adjustments result in total electricity usage of about 495,000 MWh per year region-wide, about 75% of which comes from charging at the residence.

4.2.2 Buses

As noted in the previous chapter, the Maine Secretary of State reports that there are 4,455 buses registered in Maine, 3,000 of which are classified as school buses. These buses drive over 120 million miles a year. This is just under 28,000 miles per bus per year. We assumed that the 70% of buses that are school buses operate only on weekdays, while the remainder of the buses operate over the entire seven-day week. This translates into an average of approximately 100 miles driven per day across the entire bus fleet. Based on the number of city and school buses noted in the prior section and assuming the average efficiency of electric buses is 0.465 miles/kWh,²⁶ the total annual electricity use of the bus fleet across both cities is calculated to be 7,700 MWhs.

To estimate the charging profile of the buses, we assumed that each bus charges overnight to replenish the electricity used the prior day in driving the 100 miles. We further assumed that the charging occurs during the hours from midnight to 5 am, and that the amount of electricity consumed is evenly distributed over these five hours.²⁷ Finally, we added a round-trip charging loss of 12.5%.

Figure 4.2 shows the spatial location of the city bus and school bus depots for each municipality as well as the number of buses at each location. The charging loads described above are assigned to each of these physical locations for determining which circuits are providing electric charging services. The total charging load of all the buses in the region is approximately 24,000 MWh per year once they have all been converted to electricity.

²⁶ See, for example, <u>http://www.nrel.gov/docs/fy17osti/67698.pdf</u>, Table ES-1.

²⁷ This charging schedule will require chargers with the capacity to deliver 43 kW per hour of charge. A longer charging window is available for school buses. We use this shorter 5-hour window to reduce the amount of overlap between charging buses and residential charging of passenger vehicles.



Figure 4-2 Location of City and School Bus Depots

4.2.3 Trucks

We have assumed that all non-tractor trailer trucks are garaged at residential units across the region and follow the same charging pattern as passenger vehicles. Based on data from the Secretary of State's Office, we adjusted the passenger charging profile upward by 20%, since these vehicles drive on average about 20% more miles per year than passenger vehicles. In addition, we assumed that these vehicles are half as efficient as passenger vehicles, so we adjusted the modified charging profile upward by a factor of 2. This resulted in total annual charging load of 39,000 MWh.

We used a different calculation for tractor-trailers. We assume that the average tractor-trailer uses 0.293 kWh per mile of travel. This is well below the 3.6 miles per kWh for passenger vehicles and also below the 0.465 miles/kWh assumed for buses. Next, we assumed that each tractor-trailer recharges over a 7-hour period from 11 pm through 6 am. As with buses, we assumed that the charging is evenly distributed across these 7 hours and that round-trip inefficiency of the charging/discharging cycle is 12.5%. The total amount of electricity used by tractor-trailers is calculated as 54,000 MWh. The electricity used to charge these commercial vehicles and tractor-trailers is allocated to buildings within the region as described above and in Section 3.3.3.

4.3 Space Heating

Beneficial electrification requires the elimination of all non-renewable fossil fuels used to provide space heating in all buildings and their replacement by electricity. As discussed in the previous section, a small percentage of homes, businesses and institutions in the region are heated with wood and wood pellets. We assumed that these buildings continue to use wood biomass. Since these fuels emit no CO₂ on a life-cycle basis, they do not need to be replaced by electrification. There are also a few buildings that use electric resistance heating. We ignored these. Because their total energy use is small and already included in current electricity consumption, this results in a small double-counting of this energy use. We assume these buildings convert to heat pumps and achieve some reduction in electricity consumed, which reduces somewhat the double-counting. Most of the energy used for space heating across all sectors is distillate fuel (heating oil, propane or kerosene) and natural gas.

To achieve beneficial electrification of this end-use, we have assumed that all residential units are converted to air source heat pumps and that all commercial and industrial facilities switch over to ground source heat pumps to meet their heating requirements. This assumption is for convenience; altering the relative percentages of each technology in each sector would not change total electric usage appreciably. It might, however, effect peak loads, since air-source units are less efficient than ground-source units when ambient air temperatures are low and heating demand is greatest.

We assume that air source heat pumps have a coefficient of performance (COP) that is a function of ambient air temperatures according to the following equation:

47

$$COP = (0.025 * T) + 1.75$$
 (1)

(where T is ambient air temperature each hour measured in Degrees F)²⁸

This means that at an outside air temperature of 50°F the COP is 3.0, and the heat pump uses one-third the amount of electricity as resistance heating would use to provide the same amount of heat. Based on a general review of the literature, we assumed that ground source heat pumps have a constant COP of 3.5 when providing heat, based on the fact that the temperature of the earth does not vary by season.²⁹

As homes and businesses electrify by converting to air and ground source heat pumps, these heat pumps are replacing furnaces, boilers and other equipment that burn distillate fuels or natural gas to generate heat. We assumed that existing residential, commercial and industrial heating systems operate at an average efficiency of 82.5%. The commercial and industrial levels are consistent with manufacturing specs for new equipment and for older equipment that is well maintained. The figure for residential heating systems reflects actual operating performance across all such systems.³⁰ Since the air source and ground source heat pumps deliver heat directly, the amount of electric energy required to provide the equivalent levels of heat provided by burning distillate and natural gas is equal to the quantity of those fuels used multiplied by the average efficiency value noted above. We performed this calculation on the hourly heating fuel use values calculated as described in Section 3.4 to obtain hourly electricity equivalents. The results are shown in Figure 4-3 for all residential, commercial and industrial buildings across the region.

Not surprisingly, electric load requirements for heating purposes are highly seasonal, with the highest loads occurring during the winter months and on the coldest hours during these months. The total electric load for heating end-use purposes is 1,140 GWh, which is 68% of current electricity usage in the region. Peak heating load is 737 MW, which occurs during the winter

²⁸ Source: "Natural Gas and Electric Positioning and Gas Technology Update," William E. Liss, gti, Gas Technology, May 2017, p. 33.

²⁹ Because the number of heating degree days in Maine is much larger than cooling degree days, ground-source heat pumps extract more heat from the ground during the winter than they discharge into the ground during the summer. Depending on the conductivity of the soils, this imbalance must be mitigated by the injection of additional heat into the ground-source heat pump wells over the course of the year.

³⁰ "Maine Single-Family Residential Baseline Study, NMR Group, Inc., submitted to Efficiency Maine Trust, September 14, 2015.

months.³¹ This is 276% of the current peak load of about 271 MW. This results in a low annual load factor for this end-use of about 18%.



Figure 4-3 Estimated Hourly Electric Heating Loads by End-Use Sector

4.4 Residential Air Conditioning

One of the important advantages that heat pumps offer residential consumers is the ability to operate them in reverse mode to provide cooling for interior spaces during summer months. Today, while most commercial and industrial facilities have air conditioning in areas that impact worker productivity, only about 25% of Maine's roughly 700,000 residences have some form of central air conditioning systems or window units.³² As all residences convert to air source heat

³¹ Peak heating loads occurred during the early morning hours on December 30th when temperatures in the Portland Region reached -13^o F. The coldest recorded temperature for Portland was -21^o F on February 11, 1983. Accordingly, this peak load is reasonably representative of peak loads going forward, though a bit above what could be referred to as "design conditions".

³² A survey of households performed on behalf of Efficiency Maine Trust in 2015 found that 13 out of the 41 homes visited in the survey had some form of cooling equipment, most of which was room air conditioners. We have reduced the percentage to 25% as an estimate of the households with full-house air conditioning and applied this statewide

pumps for space heat, they will gain central air conditioning as a side benefit. This represents a net increase in total electricity use by households during the summer months.

For the 25% of residential buildings that have air conditioning, the increased electricity usage due to air source heat pumps during the summer will offset the electricity use of their existing air conditioning systems and thus results in no incremental electricity usage.³³ For the remaining 75% of residential buildings, electric use will increase. We assumed that the average air conditioning requirement is for 1,500 sq.ft., requiring 2 tons of chiller capacity. The amount of electricity required to power these units is directly related to ambient air temperatures. Finally, we assumed that no air conditioning is used when ambient air temperatures are below 70°F. This relationship can be approximated using the following linear equation for ambient air temperatures between 70°F and 100°F:

Multiplier = .005 * T - 0.15 (2)

(where T is ambient air temperature each hour measured in Degrees F and the Multiplier is multiplied by 4 kW/hour to obtain predicted energy use based on ambient air temperature each hour)³⁴

The increase in residential electricity use for each unit is calculated as the ratio of that unit's sq.ft. to 1,500 multiplied by 4 kW/hour multiplied by the Multiplier in Equation (2). Since we do not know which residential units have air conditioning and which do not, we assigned an air conditioning load to every residential unit but reduced that load by 25%. While this will misrepresent the air conditioning-related electricity use for any one unit, it provides a reasonable estimate of air conditioning-related electricity use across the hundreds to thousands of units on each circuit. Total annual electricity usage for this end-use is shown in Figure 4-4.

Total incremental energy use for residential air conditioning is only 110,000 MWh, virtually all of which occurs during the summer months. Peak demand is 132 MW, which means the annual

average percentage to Portland and South Portland residential buildings. "Maine Single-Family Residential Baseline Study, NMR Group, Inc., submitted to Efficiency Maine Trust, September 14, 2015, at page 62.

³³ Since heat pumps are more efficient than window AC units, these 25% of households may see a reduction in total energy use. We do not factor this into the analysis as it would be very small in any case.

³⁴ See for example, <u>https://asm-air.com/airconditioning/much-cost-run-air-conditioner/</u>

load factor is 9.5%. This usage, however, is seasonally countercyclical to space heating. Even though the total usage is small and has itself a poor load factor, use of heat pumps to provide air conditioning actually improves the overall load factor of the electric grid as the grid expands to serve beneficial electrification.





4.5 Commercial and Industrial Processes

Beneficial electrification also requires the conversion of all process end-uses in the commercial and industrial sectors from distillate fuels and natural gas to electricity.³⁵ We assumed that the btus of usable heat from current boiler operations is displaced on a 1-to-0.825 basis for both commercial and industrial customers by btus of electricity to account for inefficiencies of existing heating systems. We applied these values to the hourly process requirements to obtain hour electric load equivalencies. These are shown in Figure 4-5. The total annual electricity requirement for process loads is 583 GWh. This is about 35% of current electricity usage in the region. The annual

³⁵ We assume that processes that are currently fueled by biomass remain fueled by biomass, as these already meet the zero-carbon emissions target. The amount of biomass used for this purpose in the region is very small.

peak load for this end-use is 123 MW. As a result, the annual load factor of this usage profile is 54%.



Figure 4-5 Estimated Hourly Electric Process Loads by End-Use Sector

4.6 Summary

Table 4-1 provides a summary of the amount of electricity that is required to achieve full beneficial electrification across the Portland Area. This amount of electricity provides for the continued powering of all homes and businesses at their current levels, plus (a) conversion of all space heating and domestic hot water use in all residential, commercial and industrial facilities to electricity, (b) extension air conditioning to all residential units, (c) conversion all fuels used in commercial and industrial processes to electricity and (d) electrification our transportation sector (passenger vehicles, buses and trucks).

The first row of Table 4-1 shows current electricity use. The region currently consumes an estimated 1,680 GWh of electricity across all sectors and all end-uses. Annual coincident peak demand is an estimated 271 MW. This provides a good benchmark for the generation capacity required plus the size of the transmission and distribution system necessary to serve current loads across all sectors of the economy in the region. To achieve beneficial electrification requires a grid

that is capable of transmitting and distributing a 2.5-fold increase in total electricity usage, plus, more importantly, a 4-fold increase in coincident peak load. As a result, estimated total grid utilization falls from a very high 71% today to a much lower 43% with full beneficial electrification.

Table 4-1 Summary – Electricity Use by End-Use Sector Under Beneficial Electrification

	Total	Maximum	Capacity
	Loads	Demand	Factor
Load Type	(MWh)	(MW)	⁰∕₀
Current Electricity Use	1,680,233	271	71%
Total Heating	1,140,843	738	18%
Residential AC	110,542	132	10%
Total Process	583,248	123	54%
Total EV Charging	613,343	145	48%
Total Loads	4,128,208	1,086	43%

Note: Demand levels shown are for each Load Type, respectively. Demand levels for Total Loads are the coincident demands across all load types.

While the total amount of end-use energy provided at its point of use post beneficial electrification is the same as current energy use in Maine, the conversion of heating, transportation and process to electricity reduces the primary energy required. As shown in Table 3-4, the region currently uses 34 trillion btus of energy, net of biomass and marine and jet fuels we have not included. Of this total about 5.7 trillion btus or 17% is electricity. In contrast, once full beneficial electrification is achieved, the only energy consumed will be electricity. The amount will be 4,110 GWh as shown in Table 4-1. This is about 14.1 trillion btus and represents a nearly 59% reduction in total energy used, measured in btus consumed.

Figure 4-6 presents the estimated hourly loads by end-use over the course of a year, assuming beneficial electrification as described above. This graph provides a useful illustration of just how electricity use changes as Maine moves to beneficial electrification. The first thing to note from Figure 4-6 is the impact of converting heating to electricity. This not only increases total electricity use, but more importantly it shifts peak electricity demand to the winter. The second thing is the very small impact that residential air conditioning has on the overall load shape. The

concentration of that load during the summer months means that it can be met with no incremental investments in the transmission and distribution grid, beyond those necessary to meet heating loads.

Table 4-2 looks at energy use in the region at 10-year intervals from 2020 to 2050, assuming full beneficial electrification occurs by 2050 consistent with state policy objectives. This table uses beneficial electrification conversion rates for heating, processes, air conditioning and transportation reported in a parallel modeling effort we have undertaken. As electrification occurs, the amount of each fossil fuel decreases in each end use and is replaced by electricity. The most important effect of this conversion to electricity is to reduce CO_2 emissions, as shown in the last row of Table 4-2.





Table 4-2 Energy Use by Fuel - 2020 - 2050

Energy Use Table

Portland Area

Class / End-Use						
Residential		Share	2020	2030	2040	2050
Electricity	MWh		703,152	716,591	1,057,697	1,754,085
Heating	mmbtu		10,489,261	10,373,879	7,027,805	0
Natural Gas	mmbtu	10%	2,529,060	2,501,241	1,694,470	0
Heating Oil	mmbtu	90%	7,960,201	7,872,638	5,333,334	0
Commercial						
Electricity	MWh		745,724	747,441	798,745	1,053,523
Heating	mmbtu		2,440,550	2,413,704	1,635,169	0
Natural Gas	mmbtu	20%	1,187,997	1,174,929	795,958	0
Heating Oil	mmbtu	80%	1,252,554	1,238,775	839,211	0
Process	mmbtu		677,931	677,931	671,151	0
Natural Gas	mmbtu	20%	336,140	336,140	332,779	0
Heating Oil	mmbtu	80%	341,790	341,790	338,372	0
Industrial						
Electricity	MWh		231,357	231,845	250,318	707,258
Heating	mmbtu		694,072	686,437	465,028	0
Natural Gas	mmbtu	30%	467,576	462,432	313,276	0
Heating Oil	mmbtu	70%	226,496	224,005	151,753	0
Process	mmbtu		1,927,978	1,927,978	1,908,698	0
Natural Gas	mmbtu	30%	1,298,821	1,298,821	1,285,833	0
Heating Oil	mmbtu	70%	629,157	629,157	622,865	0
Transportation						
Passenger Vehicles						
Gasoline	mmbtu		8,593,214	8,163,553	3,695,082	0
Electricity	MWh		0	24,795	282,667	495,906
Commercial Trucks						
Gasoline	mmbtu		2,583,087	2,472,014	1,239,882	0
Electricity	MWh		0	1,684	20,369	39,171
Buses						
Diesel	mmbtu		201,309	192,451	100,654	0
Electricity	MWh		0	1,055	11,984	23,968
Heavy-Duty Trucks						
Diesel	mmbtu		709,710	679,193	340,661	0
Electricity	MWh		0	2,335	28,235	54,298
Totals						
Electricity	MWh		1,680,233	1,725,746	2,450,015	4,128,208
Natural Gas	mmbtu		5,819,594	5,773,563	4,422,315	0
Heating Oil	mmbtu		10,410,198	10,306,366	7,285,535	0
Gasoline	mmbtu		11,176,300	10,635,567	4,934,964	0
Diesel	mmbtu		911,019	871,644	441,315	0
Total Energy Use	mmbtu		34,051,744	33,477,111	25,446,030	14,089,575
Total CO ₂ Emissions	tons		2,549,202	2,379,708	1,547,438	0

Chapter 5 - Distributed Solar Photovoltaic Generation

5.1 Introduction

The prior chapters have focused on the use of electricity. In this chapter, we turn our attention to the generation of electricity using renewable, zero-emission technologies, consistent with achieving deep decarbonization. There are many technologies that fit this bill, e.g., wind, solar, tidal, hydroelectric, geothermal, ocean current or wave, to name a few. For our purposes, we look only at technologies that we believe can be physically sited within the Portland Area, that can meet environmental regulations, that are politically acceptable and that are financially viable. This leaves only one technology – distributed solar PV; and given the high density of development within the two major cities in the region, we restrict this technology to rooftops only.³⁶

The model we have developed to estimate potential solar generation has four components. The first component is the solar irradiance model. This component calculates the amount of solar energy that strikes each square meter of rooftop each hour of the year across all buildings in the region. The second component is building specific. It provides a characterization of each building's rooftop surface based on the contiguous size of each rooftop plane and the slope and aspect of that plane. The last component applies certain key parameters to weed out rooftops or portions of rooftops that are not suitable for solar PV systems based on physical characteristics and economic value.³⁷ Appendix C provides a detailed discussion of each component. The application of the model results in an estimate of the total amount of distributed solar generation that can be developed in the Portland Area and the geospatial location of each such solar generator. The next chapter combines the geospatial generation profile with the geospatial distribution of electric loads from the prior chapter to calculate circuit and grid-wide balances to assess the adequacy of the

³⁶ There are likely to be locations within the region that can support canopy solar PV systems above parking lots or ground-mounted systems. We have not attempted to incorporate these in the modeling as doing so would alter the geospatial use of land in the region, something that is beyond the scope of this analysis.

³⁷ A fourth component would factor in shading; that is, whether any plane or portion of any plane on each rooftop is subject to shading by neighboring trees, buildings or other structures. The data requirements for including a shading component are very significant at this time; we did not include this component.

current electric grid to accommodate beneficial electrification and the widespread buildout of distributed solar generation.

5.2 Rooftop Solar PV – Modeling Results

The results of the solar PV modeling are shown in Table 5-1. We show results for each of the interim 10-year periods from 2020 through 2050, assuming solar PV penetration rates of 0%, 1%, 33% and 100%, in 2020, 2030, 2040 and 2050, respectively, in each of the three sectors. Table 5-1 shows results broken out by building classification – residential, commercial and industrial. We show the sum of the square footage of the building footprints of each building in each building category, the total number of solar PV panels installed, the maximum hourly generation of the installed solar panels, the percentage of total rooftop covered by these solar panels and the total annual solar PV generation, measured in MWh. The bottom rows compute the totals across the three building categories.

Focusing on 2050, maximum buildout of rooftop solar PV systems on all buildings in the Portland Area results in the installation of 2.8 million panels. Based on the representative solar PV panel used in the modeling, as discussed in Technical Appendix C, the total installed capacity is 1,011 MW. The graph in Table 5-1 shows the generation duration curve for these panels. It shows an annual capacity factor across all 2.8 million panels of 18%. In addition, while the total installed capacity is 1,011 MW, the maximum hourly generation was just less than 900 MW. This differential reflects the variability in aspect and orientation across all panels on all buildings.

The solar panels are estimated to cover about 25% of the roof surface of all residential buildings. Assuming a uniformly distributed compass orientation of residential buildings, we would expect 50% of all rooftop surfaces to be north of either due east (90°) or due west (270°) and therefore not suitable for solar panels, based on the criteria we used in the modeling, as discussed in Technical Appendix C. The 25% coverage ratio suggests that of the remaining 50% of all rooftop planes, fully half do not qualify for installation because they are too small or too steep.

The coverage ratios for commercial and industrial buildings are slightly higher at 28.6%. Most of the commercial and industrial rooftops are flat and because of this are qualified based on compass orientation for solar PV installations. However, to increase the amount of electricity generated by these panels, we have imposed a 30% inclination requirement. This inclination requires interrow-spacing to avoid shadow effects, resulting in an effective usable surface area of

roughly 33% of total rooftop surface. The remaining unusable surface area relates to non-flat roof building planes and other factors impacting rooftop suitability.

The generation duration curve at the bottom of Table 5-1 illustrates the difficulty of using solar PV to serve electric load. During the relatively few hours of very high solar generation (those hours to the left when generation is above 600 MW, for example), solar generation will exceed load, requiring the capacity to export excess generation over the grid to regions outside the Portland Area. In contrast, during the more than 50% of the hours when there is no solar generation, all load in the Portland Area must be served by imported electricity. Since this includes those hours of maximum loads on cold winter evenings, the presence of solar generation, even at maximum build-out levels, has virtually no impact on the required capacity of the transmission and distribution grid.

Table 5-1 Installed Solar PV Generation – Portland Area

		2020	2030	2040	2050
Residential					
Pct. Of Bldgs with Solar PV	%	0%	1%	33%	100%
Total Bldg. Footprint	Sq.Ft.	127,783,933	127,783,933	127,783,933	127,783,933
Number of Solar Panels	No.	0	19,415	582,463	1,765,038
Maximum Hourly Generation	MW	0.00	6.12	183.61	556.41
Pct. Of Rooftop Covered	%	0.00%	0.28%	8.47%	25.68%
Annual Solar Generation	MWh	0	10,691	320,736	971,929
Commercial					
Pct. Of Bldgs with Solar PV	%	0%	1%	33%	100%
Total Bldg. Footprint	Sq.Ft.	50,412,359	50,412,359	50,412,359	50,412,359
Number of Solar Panels	No.	0	8,547	256,403	776,978
Maximum Hourly Generation	MW	0.00	2.75	82.62	250.35
Pct. Of Rooftop Covered	%	0.00%	0.32%	9.46%	28.65%
Annual Solar Generation	MWh	0	5,027	150,812	457,005
Industrial					
Pct. Of Bldgs with Solar PV	%	0%	1%	33%	100%
Total Bldg. Footprint	Sq.Ft.	17,342,593	17,342,593	17,342,593	17,342,593
Number of Solar Panels	No.	0	2,932	87,961	266,548
Maximum Hourly Generation	MW	0.00	0.96	28.79	87.24
Pct. Of Rooftop Covered	%	0.00%	0.31%	9.43%	28.57%
Annual Solar Generation	MWh	0	1,775	53,244	161,347
TOTAL - All Buildings					
Total Bldg. Footprint	Sq.Ft.	195,538,885	195,538,885	195,538,885	195,538,885
Number of Solar Panels	No.	0	30,894	926,826	2,808,565
Maximum Hourly Generation	MW	0.00	9.83	295.02	894.00
Pct. Of Rooftop Covered	%	0.00%	0.29%	8.81%	26.70%
Annual Solar Generation	MWh	0	17,493	524,792	1,590,280



Chapter 6 - Energy Balances

6.1 Introduction

In Chapter Four, we focused on how electricity use will expand and change under beneficial electrification of the transportation, space heating and commercial and industrial processes. In Chapter Five, we turned our attention to estimating the total amount of electricity that could be generated within the region using rooftop distributed solar PV systems. In this chapter, we combine the results from these two chapters and in the process introduce a concept we refer to as an "energy balance". We show that, because total energy use (as measured by btus consumed) falls as society replaces distillate and fossil fuels used in transportation and space heating with electricity, the overall energy balance in the region improves as a result of beneficial electrification. The region still imports virtually 100% of the energy consumed – there is just less energy consumed. When we introduce the full development of distributed rooftop solar PV systems across the region, the energy balance improves further. However, even with maximum solar PV generation, this generation represents only 1,590 GWh of the 4,128 GWh (38.5%) of all the energy consumed across the region and all sectors post beneficial electrification.

While the overall regional energy balance is important, energy balances within subregions or related to specific components of the electric grid are often more important. Conditions of imbalance impose stress on the grid and can result in failures that can lead to widespread electric outages. We examine three components of the grid – individual electric circuits, electric transformers and substations. We show that beneficial electrification will impose electric loads on the grid that exceed the carrying capacities of the current system, often by significant factors. Further, the development of distributed solar generation will create situations of reverse power flows on the majority of the distribution circuits in the region. This will necessitate the redesign and reconfiguration of virtually the entire distribution grid within the region.

The redesign of the distribution grid is only one result of beneficial electrification and increased distributed solar generation. The second result is what this means for the transmission grid. While the energy balance in the region is improved through beneficial electrification, the reduction is accomplished by substituting increased electricity flows into the region for distillate and natural gas deliveries through tankers, trucks and pipelines. The increases in electricity imports are

well beyond the physical capabilities of the existing transmission and subtransmission grids in the region. We conclude this section by focusing on what the peak electricity balances in the region means for the expansion of the transmission grid.

6.2 Energy Balances

We define <u>energy balance</u> as the ratio of the total amount of all energy that is generated at a specific location to the total amount of energy that is consumed at that location, in both cases over a specific duration of time. If there is no generation at the location in question, the energy balance is zero. As energy generation at the location increases, the energy balance increases. The energy balance exceeds 1.0 when the amount of energy that is generated exceeds the amount of energy that is consumed.

The concept of an energy balance is useful, because any value that is greater than or less than 1.0 requires a means to export, import or store the energy that is not consumed on site. The first two of these actions are handled by the electric grid, which must be large enough and robust enough to accommodate the full range of energy imports into or exports out of a location at any point in time. The last of the three actions is handled by some type of energy storage technology, e.g., battery storage.

Energy balances are defined both spatially and temporally. For our purposes we focus on four spatial dimensions – each individual building, each electric distribution circuit, each transformer within each substation and the region as a whole – and on two temporal dimensions – the hour of maximum energy imports and the hour of maximum distributed solar energy generation (exports) over the course of the year. The temporal dimensions are important, because the design and sizing of the electric grid and its components are determined by peak conditions.

6.2.1 At the Building Level

Our basic unit of analysis is the building. As described in the prior three chapters, we have calculated for each building in the region current energy use, electricity usage at various stages of full beneficial electrification at ten-year intervals (2030, 2040 and 2050), and electricity generation assuming the maximum solar PV that can be generated. Currently, because there is very little distributed solar generation in the region, virtually 100% of all energy used in residential, commercial and industrial buildings is imported into the region or is generated at one of the region's existing

fossil fuel generating plants. This begins to change as rooftop solar generation is developed, and once fully deployed, we find that certain buildings are net exporters of energy on an annual basis (i.e., over the course of the year their energy balance is greater than 1.0).

Table 6-1 shows the annual energy balances for all the buildings in the Portland Region by building type. The columns are ranges of the percent of total building energy use (including transportation) post beneficial electrification that is met by on-site rooftop solar PV on an annual basis. Not surprisingly, only about 1% of industrial buildings are able to self-generate more than 40% of their energy usages. The EUIs for these buildings measured on a per square foot basis are simply much greater than the amount of solar irradiance that strikes their roofs and can be converted into electricity using rooftop solar panels.

Commercial buildings perform a little better on this metric. As a general rule, multistory commercial buildings, such many office buildings in downtown Portland are able to generate a much smaller percentage of their annual electricity requirements, since the ratio of rooftop surface to interior square footage is low. Single story office buildings, on the other hand, do better.

Energy balances for residential buildings are mixed, depending on the aspect (compass heading), slope (pitch) and number of stories. While less than 15% can meet their total annual electricity requirements with rooftop solar PV generation, more than half are able to meet 50%.

		Estimated Building Energy Balances - 2050							
Building Type	[Roof	[Rooftop Solar PV Generation as a Percent of Building Energy Use]							
	<20%	20-40%	40-60%	60-80%	80-100%	>100%			
Residential									
No. of Bldgs.	20,266	13,719	11,937	9,001	7,671	10,408			
Percent	28%	19%	16%	12%	11%	14%			
Cum. Percent	28%	47%	63%	75%	86%	100%			
Commercial									
No. of Bldgs.	1,542	1,314	2,028	957	249	77			
Percent	25%	21%	33%	16%	4%	1%			
Cum. Percent	25%	46%	79%	95%	99%	100%			
Industrial									
No. of Bldgs.	400	593	13	1	0	1			
Percent	40%	59%	1%	0%	0%	0%			
Cum. Percent	40%	99%	100%	100%	100%	100%			

	Table 6-1	Annual	Building	Energy	Balances	- 2050
--	-----------	--------	----------	--------	-----------------	--------

The annual energy balances for each of the buildings provides useful information about overall electricity flows at the building level, but they are less useful with respect to how the electric

grid must be sized to meet both loads and generation requirements. For example, post beneficial electrification peak electric loads for the region occur during evening hours on the coldest days of the winter. During these hours, there is no distributed solar generation. While there may be components of the installed distributed solar systems that can provide useful services to the grid during these hours, e.g., smart inverters may assist in providing voltage support even when there is no solar generation, the fact is that distributed solar generation systems provide very little benefits vis-a-vis the need for transmission and distribution grid capacity in northern regions, where peak loads are driven by space heating requirements.

On the other hand, maximum solar generation tends to occur mid-day in the late spring or early fall on crystal clear days. Because these hours of maximum solar generation are not on either the hottest or coldest days of the year and could occur on weekend days, electric loads on the grid are not at their peak and may only be at average or even below-average levels. This is likely to create situations where the electric loads on any given circuit are not high enough to absorb the full amount of solar generation that is interconnected to that circuit. When this happens, electricity will flow "up" the circuit back to the substation – a condition called "reverse power flow". This could create serious reliability problems for the grid, if the substations are not designed to be able to accommodate such flows.

6.2.2 At the Circuit Level

Beneficial electrification and widespread distributed solar generation create two potential problems for a distribution circuit. First, distribution circuits, like all components of the electric grid, are designed to carry no more than a certain amount of electricity based on the capacity or ratings of their component parts. When electricity flows exceed those ratings, the component parts will become stressed, causing more rapid wear or complete failure. Second, distribution level substations are not currently designed to accommodate reverse power flows. When the amount of distributed generation delivered to a distribution circuit exceeds the load on that circuit, the grid is designed to disconnect the circuit, effectively islanding all generation and loads on that circuit. This will result in a localized outage, but not before serious damage might occur to electrical equipment served by that circuit.

Table 6-1 shows the maximum and minimum hourly loads on each of the 96 circuits in the Portland Area over the course of a year. The maximum and minimum loads are shown for 2020 and

for increasing stages of beneficial electrification in 2030, 2040 and 2050. Currently, the average peak loads across these circuits is just over 3.2 MW, with a maximum circuit load of 7.15 MW. Further, consistent with the design of the distribution grid and the general lack of distributed generation systems in the region, there are no circuits that show negative load flows; that is, where the amount of generation interconnected to the circuit is greater than the total amount of load on that circuit during any hour.

The results in 2050, however, are very different. Post beneficial electrification in 2050, the average peak load across the 96 circuits increases to 11.7, with a maximum load on one of the circuits at 28.27 MW. Further, of the 96 circuits, 50% have peak loads in excess of 10 MW by 2050.

We do not have the conductor specifications for each segment of each of the 96 circuits, so we are not able to determine what percent of these circuits will have loads in excess of their carrying capacities under beneficial electrification. However, even without these ratings and even allowing for increased ratings and capabilities of the circuits during the winter season, many of these circuits will require reconductoring in order to meet the increased loadings.

Figure 6-2 presents the same information for maximum hourly loads in graphic form. It compares today's estimated non-coincident peak electric loadings on each of the 96 circuits in the Portland Area with that circuit's peak loadings under beneficial electrification and maximum distributed solar generation at ten-year intervals – 2020, 2030, 2040 and 2050.

The second reason why energy balances on each circuit are important is because electric distribution grids are designed as radial from a substation with electric flows assumed to flow from the substation to the end of the circuit. To the extent that distributed generation that is interconnected to a circuit generates more electricity than is being taken off that circuit by load, the power flow on the circuit will reverse, sending electricity upstream and eventually into the substation. Were a fault to occur, the circuit breakers would activate, essentially islanding the circuit. This would leave loads to be served by distributed generation that is not designed or capable of serving such loads.

There are three approaches to address this reverse power flow problem. The first is to require that the sum of total capacity of all distributed generation on a circuit be kept below the minimum load on that circuit. This ensures that generation will never exceed load and result in reverse power flows into the substation. The concern with this approach is that it constrains the amount of solar generation capacity that can be interconnected on each circuit.

64

Table 6-2Maximum and Minimum Hourly Loads by Distribution Circuit – 2020 - 2050

Circuit Table										
			Maximum/Minimum Loads (MW)							
Distribution Circuit	Transformer	Substation	202	0	20	30	20	40	20	50
			Max	Min	Max	Min	Max	Min	Max	Min
607 D 1	No. 1	Bishop Street	5.29	2.15	5.29	2.23	7.78	-0.57	18.64	-7.85
607D2	No. 1	Bishop Street	3.66	1.33	3.80	1.41	7.22	-0.76	15.65	-6.73
607D4	No. 1	Bishop Street	4.19	1.60	4.34	1.63	7.80	0.71	15.87	-3.87
607D5	No. 2	Bishop Street	4.51	1.84	4.44	1.91	7.21	-1.33	15.58	-9.64
611D1	No. 1	Brighton Avenue	3.36	1.29	3.31	1.31	3.62	-0.15	7.08	-4.02
611D2	No. 1	Brighton Avenue	2.64	1.03	2.60	1.05	3.45	-0.57	6.60	-4.90
611D3	No. 1	Brighton Avenue	3.70	1.48	3.64	1.62	5.38	-0.53	11.89	-5.94
613D1	No. 1	Cape Elizabeth	3.28	0.99	3.42	1.05	6.77	-2.21	14.96	-10.35
613D2	No. 1	Cape Elizabeth	4.05	1.32	4.22	1.34	8.13	-1.04	17.65	-8.21
613D3	No. 2	Cape Elizabeth	3.34	0.94	3.50	0.98	7.34	-1.96	15.77	-9.28
617D1	No. 1	Dunstan	4.49	1.38	4.69	1.45	9.46	-2.14	20.33	-11.46
617D2	No. 1	Dunstan	1.69	0.58	1.77	0.60	3.41	-0.78	7.10	-4.61
618D1	No. 1	East Deering	2.51	0.85	2.61	0.91	5.08	-1.08	11.68	-5.86
618D2	No. 2	East Deering	3.52	1.25	3.65	1.27	6.87	-1.30	14.37	-8.59
618D3	No. 2	East Deering	2.69	1.10	2.78	1.16	4.86	-0.32	10.91	-4.37
620D1	No. 2	Elm Street	6.19	1.97	6.45	2.07	12.55	-3.47	27.80	-17.69
620D2	No. 3	Elm Street	6.13	2.02	6.39	2.10	12.37	-3.78	27.01	-18.94
620D3	No. 2	Elm Street	5.99	2.14	6.22	2.20	11.68	-2.82	25.10	-16.52
620D4	No. 2	Elm Street	4.73	1.49	4.93	1.53	9.60	-3.20	21.18	-15.27
622D1	No. 1	Falmouth	2.78	1.01	2.81	1.02	3.85	-0.47	6.88	-5.06
622D2	No. 1	Falmouth	5.41	1.61	5.63	1.65	11.06	-2.81	24.72	-14.29
653D1	No. 1	Fore River	3.59	1.21	3.60	1.21	3.88	1.22	5.86	1.55
653D2	No. 2	Fore River	4.21	1.48	4.38	1.56	8.57	0.40	19.02	-3.48
653D3	No. 1	Fore River	2.66	1.04	2.72	1.05	4.78	0.68	9.62	-1.75
653D4	No. 2	Fore River	0.91	0.35	0.89	0.38	2.05	-0.14	4.28	-1.38
653D5	No. 1	Fore River	1.64	0.63	1.70	0.66	2.91	0.07	6.98	-1.52
653D6	No. 2	Fore River	1.09	0.45	1.10	0.46	1.87	0.33	4.00	-0.46
623D1	No. 1	Forest Avenue	2.27	0.83	2.26	0.83	2.82	0.41	4.94	-1.37
623D2	No. 1	Forest Avenue	4.40	1.63	4.37	1.64	4.95	0.96	8.54	-1.61
623D4	No. 1	Forest Avenue	2.90	1.09	2.90	1.11	3.95	0.37	7.33	-2.42
623D5	No. 1	Forest Avenue	0.07	0.02	0.07	0.02	0.15	0.00	0.34	-0.05
623D5A	No. 1	Forest Avenue	0.18	0.06	0.19	0.06	0.37	0.02	0.80	-0.15
225D1	No. 2	Freeport	2.20	0.76	2.21	0.77	2.51	0.23	4.03	-1.80
225D2	No. 1	Freeport	2.56	0.66	2.59	0.60	3.60	-1.51	9.40	-5.95
225D3	No. 2	Freeport	5.92	1.87	6.17	1.92	12.09	-3.03	26.30	-15.91
225D4	No. 1	Freeport	4.92	1.78	4.95	1.80	6.34	-0.35	11.31	-7.11
416D1	No. 2	Gray	4.87	1.78	5.06	1.82	9.35	-3.38	19.60	-17.24
416D2	No. 1	Gray	5.15	1.77	5.37	1.86	10.39	-3.82	21.49	-18.45
416D3	No. 1	Gray	2.62	0.88	2.74	0.93	5.49	-1.16	12.13	-6.59
690D1	No. 1	Hinckley Pond	3.06	1.15	3.06	1.18	4.41	0.07	8.04	-3.69
690D2	No. 1	Hinckley Pond	3.21	1.28	3.36	1.33	6.62	-0.21	13.03	-5.07
690D3	No. 1	Hinckley Pond	6.01	1.92	6.30	2.00	12.97	-1.56	26.31	-11.89
631D1	No. 1	Lambert Street	2.28	0.87	2.25	0.89	2.43	-0.06	5.22	-2.76
631D2	No. 1	Lambert Street	5.28	1.77	5.48	1.86	10.31	-2.09	22.35	-13.03
631D3	No. 2	Lambert Street	4.18	1.36	4.35	1.39	8.52	-2.02	18.15	-11.07

Circuit Table										
					Maximun	n/Minim	um Loads	(MW)		
Distribution Circuit	Transformer	Substation	202	0	2030		204	0	20	50
			Max	Min	Max	Min	Max	Min	Max	Min
635D1	No. 2	Moshers	4.54	1.56	4.73	1.63	9.30	-3.27	19.20	-15.81
635D2	No. 2	Moshers	3.47	1.39	3.43	1.50	5.32	-0.57	11.73	-6.29
636D1	No. 1	Mussey Road	1.02	0.35	1.03	0.35	1.15	0.18	1.73	-0.55
636D2	No. 1	Mussey Road	4.83	1.74	4.76	1.77	5.27	0.03	8.42	-4.85
644D1	No. 2	Pleasant Hill	3.34	0.36	3.36	0.31	3.97	-1.59	10.92	-5.44
644D2	No. 2	Pleasant Hill	5.52	1.54	5.80	1.67	12.49	-3.14	26.29	-14.95
644D3	No. 2	Pleasant Hill	4.86	1.80	5.05	1.85	9.48	-2.49	19.82	-14.25
644D4	No. 3	Pleasant Hill	2.67	1.07	2.65	1.09	4.26	-0.68	8.73	-5.62
647D1	No. 2	Prides Corner	3.51	1.34	3.61	1.44	6.02	-1.49	14.71	-7.87
647D2	No. 2	Prides Corner	4.87	1.65	5.11	1.75	10.72	-2.33	22.67	-12.20
647D3	No. 2	Prides Corner	2.19	0.72	2.29	0.75	4.72	-1.41	9.96	-6.74
696D1	No. 1	Red Brook	5.31	1.79	5.32	1.79	5.68	1.30	8.38	-0.94
696D2	No. 1	Red Brook	0.17	0.06	0.17	0.06	0.19	-0.06	0.27	-0.35
650D1	No. 1	Rigby	3.20	1.26	3.35	1.36	6.25	-1.02	13.48	-6.96
650D3	No. 2	Rigby	3.01	0.40	2.96	0.41	3.49	-1.46	9.22	-5.27
650D4	No. 2	Rigby	3.38	1.40	3.55	1.47	6.73	-1.34	13.22	-8.85
693D1	No. 1	Scarborough	3.08	1.14	3.20	1.17	5.92	-1.04	12.12	-7.57
693D2	No. 1	Scarborough	4.95	1.91	4.95	2.00	6.67	-1.31	16.27	-9.25
659D13	No. 2	Sewall Street	1.20	0.43	1.24	0.44	2.32	0.00	4.80	-1.69
659D4	No. 2	Sewall Street	1.40	0.51	1.39	0.51	1.69	0.19	2.94	-1.00
659D5	No. 2	Sewall Street	0.16	0.06	0.16	0.06	0.27	-0.01	0.54	-0.26
659D6	No. 2	Sewall Street	3.28	1.23	3.28	1.24	4.52	0.27	8.41	-3.28
659D8	No. 2	Sewall Street	4.29	1.27	4.49	1.31	9.16	-1.38	19.88	-8.62
659D9	No. 2	Sewall Street	3.43	1.33	3.55	1.39	6.39	0.30	13.10	-3.99
668D4	No. 4	Spring Street	3.56	1.36	3.51	1.39	3.83	0.29	7.16	-2.96
668D6	No. 4	Spring Street	1.07	0.06	1.07	0.04	1.20	-0.58	3.37	-1.80
668D1	No. 2	Spring Street	4.06	1.42	4.03	1.43	4.36	0.79	6.79	-1.64
668D2	No. 2	Spring Street	1.63	0.38	1.61	0.39	1.72	-0.47	4.49	-2.43
668D3	No. 2	Spring Street	2.50	0.61	2.46	0.62	2.72	-0.67	7.10	-3.57
668D5	No. 2	Spring Street	3.60	1.35	3.75	1.42	7.25	-1.95	15.57	-10.33
682D1	No. 1	Swett Road	4.85	1.32	5.07	1.36	10.32	-4.16	23.33	-17.11
682D2	No. 1	Swett Road	4.40	1.64	4.56	1.68	8.24	-2.85	17.19	-15.12
645D1	No. 1	Union Street	2.08	0.76	2.09	0.77	2.74	0.62	4.89	-0.26
645D2	No. 2	Union Street	0.70	0.26	0.70	0.26	0.89	0.14	1.56	-0.39
645D3	No. 1	Union Street	3.17	1.11	3.17	1.11	3.68	0.98	6.11	0.23
645D4	No. 2	Union Street	2.32	0.94	2.30	0.96	3.51	0.14	7.46	-2.42
645D7	No. 1	Union Street	1.58	0.58	1.57	0.58	1.86	0.39	3.21	-0.53
645D8	No. 2	Union Street	4.89	1.81	5.08	1.89	9.72	0.58	21.31	-3.94
645D9A	No. 1	Union Street	0.25	0.09	0.25	0.09	0.31	0.06	0.55	-0.12
645N1	No. 3	Union Street	1.52	0.52	1.52	0.52	1.67	0.33	2.59	-0.63
645N2	No. 4	Union Street	1.49	0.56	1.48	0.56	1.73	0.45	3.07	-0.06
645N3	No. 3	Union Street	2.26	0.78	2.26	0.79	2.49	0.79	4.00	0.92
645N4	No. 4	Union Street	0.84	0.29	0.84	0.29	0.91	0.10	1.38	-0.58
645N5	No. 3	Union Street	0.73	0.25	0.73	0.25	0.78	0.19	1.19	-0.08
645N6	No. 4	Union Street	0.80	0.28	0.80	0.28	0.94	0.27	1.56	0.19
674D1	No. 1	Westbrook	5.77	2.22	5.94	2.33	9.73	-1.62	23.39	-10.67
674D2	No. 1	Westbrook	2.16	0.72	2.23	0.68	3.89	-0.84	9.52	-4.12
675D1	No. 1	Western Avenue	1.41	0.48	1.41	0.48	1.50	-0.13	2.17	-1.90
675D2	No. 1	Western Avenue	1.30	0.44	1.30	0.45	1.39	-0.17	2.01	-1.89
675D3	No. 1	Western Avenue	7.15	2.37	7.10	2.45	8.74	0.22	22.06	-5.32
218D1	No. 13	Wyman	3.91	1.24	4.02	1.18	7.08	-1.28	17.88	-6.61

Table 6-3Maximum and Minimum Hourly Loads by Distribution Circuit – 2020 - 2050





The second approach is to require that all distributed generation be equipped with reverse power relays that sever the interconnection of the distributed generation resource to the distribution circuit whenever reverse power flows are detected on the circuit near the substation. This approach relieves the artificial constraint of the first approach; however, it does so by dispatching off essentially zero-cost electricity during those hours of the year when reverse power flows are detected on the circuit and when that electricity could be used to feed the entire system.

The third approach is to remodel the substation to enable it to handle reverse power flows. In this case, surplus electricity generated on one circuit is simply routed upstream through the interconnecting transformer at the substation onto the subtransmission grid, where it is then delivered to another distribution circuit. This approach permits unconstrained solar generation on a circuit but requires increased investments in the distribution grid to accommodate this result.

To test for the occurrence of potential reverse power flows, we looked at the minimum hourly energy balances on each of the 96 distribution circuits in Table 6-1. Figure 6-3 shows the minimum net energy balance over the course of the year for each of the distribution circuits by 2050. A negative number means that the amount of distributed generation output being delivered to that circuit is greater than the amount of load on the circuit. Only 4 of the 96 circuits do not suffer from reverse power flows, and even for these 4, the net energy balance during that hour of minimum net load flows is below a couple of MW.





6.2.3 At the Transformer/Substation Level

The increase in peak loads on all the distribution circuits as a result of beneficial electrification requires increased electricity flows into each distribution level substation and through transformers located at these substations to the distribution circuits. The CMP system in the Portland Area accommodates distribution circuits emanating from substations with incoming voltage at either 115 kV or 34.5 kV. We show these substations in Tables 6-2 and 6-3. Table 6-2 and Table 6-3 shows all the substations where the incoming voltage is 115 kV. Table 6-3 shows all the substations where the incoming voltage is 34.5 kV.

Table 6-2 shows the transformers within each substation that deliver electricity at distribution voltage onto distribution circuits. In some cases, the transformer serves a single distribution circuit; in other cases, there may be multiple distribution circuits fed from the same transformer. The tables also show the high-side and low-side voltage levels for each transformer and their ratings, measured in MVA. The lower level rating is without any fans providing cooling; the higher rating is with full fan cooling operating. Finally, the tables show the estimated peak loads on each transformer currently and post beneficial electrification.³⁸ These loads are expressed in MVA, assuming a 0.95 power factor.

Focusing first on Table 6-2, it is interesting to note that the total amount of transformation capacity across all transformers, even at the higher rating levels, is well below the peak electric loads that will need to be served post beneficial electrification in 2050. The total transformation capacity is 241 MVA compared to loads of just over 380 MVA. The problem is most acute at the Elm Street, Hinckley Pond Pleasant Hill and Prides Corner substations.

These capacity shortfalls are shown graphically in Figure 6-4. This figure shows the maximum loadings on each transformer as a percentage of its higher value capacity rating. While there are a few instances in which total 2050 loads are within the range of the ratings of these transformers, most cases show loads well in excess of those ratings, as noted above. Further, the loads begin to exceed ratings sometime in the 2030s.

³⁸ Where a transformer serves multiple distribution circuits, the load levels shown are the coincident peak loads across all such distribution circuits. The load levels shown as "Subtotals" and "Grand Totals" for 115/12.5 kV and 34.5/12.5 kV are the sums of the non-coincident peaks across all substations.

Table 6-4 Transformer Capacities and Loads - 115 kV Substations

Transformer Capacities and Loads - 115 kV and 34.5 kV Substations*

[* At 95% Power Factor]

[* At 95% Power Factor]				Maximum Loads				
	Transformer Voltage (kV)	Transf Capa	ormer acity	2020	2030	2040	2050	
Transformer Identifier	High/Low	MVA	MVA	MVA	MVA	MVA	MVA	
115/12.5 kV Substations								
Elm Street								
No. 2 Bank	115/12	12.00	22.00	17.81	18.52	35.61	77.99	
No. 3 Bank	34.5/12	5.00	7.00	6.46	6.72	13.02	28.43	
Fore River								
No. 1 Bank	115/12	12.00	22.40	8.13	8.14	11.52	22.05	
No. 2 Bank	115/12	12.00	22.40	6.13	6.38	11.90	26.31	
Hinckley Pond								
No. 1 Bank	115/12	10.00	14.00	12.33	12.86	25.21	49.86	
Moshers								
No. 2 Bank	115/12	10.00	14.00	7.76	8.13	15.10	32.26	
Mussey Road								
No. 1 Bank	115/34	20.00	37.00	6.16	6.09	6.76	10.63	
Pleasant Hill								
No. 2 Bank	115/12	12.00	22.40	13.05	13.61	26.51	60.03	
No. 3 Bank	34/12	5.00	7.00	2.81	2.79	4.48	9.19	
Prides Corner								
No. 2 Bank	115/12	10.00	14.00	10.83	11.32	22.58	49.83	
Sewall Street								
No. 1 Bank	115/12	12.00	22.40	0.00	0.00	0.00	0.00	
Spring Street								
No. 3 Bank	115/12	10.00	14.00	0.00	0.00	0.00	0.00	
No. 4 Bank	115/34	12.00	22.40	4.69	4.62	4.94	11.05	
Subtotal - 115/12.5 kV Substations		142.00	241.00	96.16	99.19	177.63	377.62	

Notes:

1. Sewall Street No. 1 Bank provides a secondary source of electricity supply to those circuits fed off Sewall St No. 2 Bank (34/12.5 kV Bus). All of the load on these circuits has been assigned to the No. 2 Bank transformer.

2. Spring Street No. 3 Bank provides a secondary source of electricity supply to those circuits fed off Spring St. No. 2 Bank (34/12.5 kV Bus). All of the load on these circuits has been assigned to the No. 2 Bank transformer.



The capacity shortfall is as pronounced for the 34/12.5 kV transformers in the region as shown in Table 6-4. In a number of cases, peak load levels by 2050 are more than twice the higher ratings of the transformers. A case in point is the No. 1 Bank transformer at the Bishop Street substation. This transformer has a high-level rating of 22.4 MVA; however, post beneficial electrification peak load that needs to be served through this transformer is 52.8 MVA.

Figure 6-5 presents the same information graphically. As with the 115/12.5 kV transformers noted above, peak load levels on a number of the transformers at the distribution level will exceed their high value ratings during the 2030s.
Table 6-4 Transformer Capacities and Loads – 34.5 kV Substations

Transformer Capacities and Loads - 34.5 kV Substations*

[* At 95% Power Factor]	* At 95% Power Factor] Maximum Loads						
	Transformer	Trans	former	2020	2030	2040	2050
	Voltage (kV)	Cap	acity	2020	2050	2010	2000
34.5/12.5 kV Substations	High/Low	MVA	MVA	MVA	MVA	MVA	MVA
Bishop Street							
No. 1 Bank	34/12	12.00	22.40	13.15	13.63	23.94	52.80
No. 2 Bank	34/12	5.00	7.00	4.75	4.67	7.59	16.40
Brighton Avenue							
No. 1 Bank	34/12	10.80	20.20	10.22	10.05	12.55	25.57
Cape Elizabeth							
No. 1 Bank	34/12	7.50	10.50	7.72	8.04	15.68	34.32
No. 2 Bank	34/12	5.00	7.00	3.51	3.68	7.72	16.60
Dunstan							
No. 1 Bank	34/12	7.50	10.50	6.51	6.80	13.55	28.87
East Deering							
No. 1 Bank	34/12	5.00	7.00	2.65	2.75	5.35	12.29
No. 2 Bank	34/12	7.50	10.50	6.43	6.66	12.35	26.61
Falmouth	/						
No. 1 Bank	34/12	7.50	10.50	7 92	8 22	15.20	32.58
Forest Avenue	51/12	1.00	10.00	102	0.22	10.20	52.00
No. 1 Bank	34/12	12.00	22.00	10.25	10.18	12.80	22.85
Freeport	54/12	12.00	22.00	10.25	10.10	12.00	22.05
No. 1 Bank	34/12	7.50	10.50	7 30	7 27	0.70	21.22
No. 2 Bank	34/12	10.00	14.00	7.57	8.06	14.00	21.22
No. 2 Balik	54/12	10.00	14.00	1.10	0.00	14.90	51.56
Gray	24/12	7.50	10.50	0.17	0.52	16.71	25.20
No. I Bank	34/12	7.50	10.50	8.17	8.55	10./1	35.38
No. 2 Bank	34/12	5.00	/.50	5.13	5.32	9.84	20.63
Lambert Street	24/42		40 50	==	T 05	10.07	20.02
No. 1 Bank	34/12	7.50	10.50	/.0/	/.35	13.07	28.93
No. 2 Bank	34/12	5.00	7.00	4.40	4.58	8.97	19.10
Red Brook							
No. 1 Bank	120/36	20.00	37.00	5.77	5.78	6.18	9.08
Rigby							
No. 1 Bank	34/12	5.00	7.00	3.37	3.52	6.58	14.19
No. 2 Bank	34/12	7.00	10.50	6.14	6.29	9.98	23.62
Scarborough							
No. 1 Bank	36.2	10.00	14.00	8.04	8.08	13.13	29.89
Sewall Street							
No. 2 Bank	34/12	12.00	22.40	13.40	13.87	25.25	52.13
Spring Street							
No. 2 Bank	34/12	7.50	10.50	11.25	11.09	15.36	34.58
Swett Road							
No. 1 Bank	34/12	10.00	14.00	9.75	10.14	19.54	42.65
Tank Farm							
No. 1 Bank	34/2.4	3.80	4.70				
No. 2 Bank	34/2.4	7.50	10.50				
Union Street							
No. 1 Bank	34.5/12.47	12.00	22.00	7.45	7.45	9.04	15.53
No. 2 Bank	34.5/12.47	12.00	22.00	7.83	8.15	14.76	31.86
No. 3 Bank	34.5/11.5	12.00	22.00	4.74	4.74	5.17	8.19
No. 4 Bank	34.5/11.5	12.00	22.00	3.29	3.28	3.75	6.33
Westbrook	, -						
No. 1 Bank	36.2/13.2	10.00	14.00	8.32	8.56	14.33	34.64
Western Avenue		- 0.00		0.54	0.00	1,100	5 HO F
No. 1 Bank	34/12	12.00	22.00	0.86	9.76	11 72	26.65
Wyman	57/12	12.00	<i>22.00</i>	2.00	2.70	11./2	20.05
No. 13 Baply	34/12	3.80	5 30	4 1 2	1 24	7 45	18.82
INO. 15 DAILS	JT/ 12	5.00	5.50	4.1∠	4.24	7.43	10.02
Subtotal - 34.5/12.5 kV Sub	stations	278.90	447.50	216.36	220.75	362.25	773.69
Grand Total - All Substatio	ons	420.90	688.50	312.52	319.94	539.87	1,151.31



Figure 6-4 Max. Loads by 34/12.5 kV Transformer – 2020 – 2050 as a Pct. of High Ratings

Figure 6-6 shows the hourly load levels on the Bishop Street No. 1 transformer post beneficial electrification in 2050. The load levels through this transformer are well above the ratings for most hours of the year. The top graph in Figure 6-6 shows estimated hourly loads through the No. 1 Bank transformer at Bishop Street substation post beneficial electrification, beginning

midnight January 1 and ending midnight December 31. The bottom graph shows the load duration curve for the transformer loads. Also shown on both graphs for reference are the low- and high-level capacity ratings for the transformer (12/22.4 MVA). The load duration curve shows that loadings on the transformer are in excess of the high-level rating for about a third of the hours in the year. The upper graph shows that, while hourly loadings during the winter season are almost all in excess of the high-level rating, there are many hours every month in which loads exceed the high-level rating. Importantly, these hours include summer evening hours when there is no solar generation and high ambient air temperatures place stress on transformer operations.



Load Levels v. Capacity – No. 1 Bank – Bishop Street Substation



6.2.4 At the Regional Level

We next look at the energy balance for the region. Figure 6-7 shows the net loads across the region each hour of the year. The top graph shows estimated 2020 load flows; the bottom graph shows estimated 2050 load flows, assuming beneficial electrification and full build-out of distributed solar generation. Total gross loads in 2050 are 4,128 GWh; total gross generation is 1,590 GWh. Accordingly, on balance over 2050, the region will be a net energy importer of about 2,538 MWh. However, hour-by-hour energy flows will range from a maximum import demand of just less than 1,086 MW to a maximum export of 533 MW. These two graphs describe very different electric conditions from those that exist today, and these conditions will require very different electric grids.

CMP has argued in its Needs Assessment of the Portland Region that the existing transmission grid fails to meet grid reliability requirements at current peak load levels. The portion of the grid north of Portland is weak, while the underlying 34.5 kV system in the southern portion does not have sufficient capacity to handle loads in the event of a 115 kV outage. When load levels are increased to those levels under full beneficial electrification, the existing grid fails at every level at virtually every point on it. If, as CMP has determined, the transmission grid in the region is not capable of handling a peak load of 420 MW, it will be woefully inadequate when net electricity loads across the region reaches levels in excess of 1,100 MW on cold winter evenings.

6.3 Storage

None of the modeling underlying our estimates of energy balances at any level of the electric grid includes any consideration of energy storage technologies. Intuitively, we would expect storage to be capable of addressing some of the energy balance mismatches by absorbing excess energy generated by the distributed solar PV rooftop systems (essentially functioning as load during the charging cycle) and returning it to the grid during evening and nighttime hours when loads exceed solar generation. To the extent that storage is able to play this role, it may be possible to reduce the required capacity of the grid and/or reduce investments in the distribution grid necessary to avoid the islanding scenarios that can arise when there are reverse power flows on distribution circuits. Upon closer examination, however, storage may provide less value as a means of addressing energy balance situations.



First, consider the regional energy balance. Figure 6-6 shows that the transmission grid in the Portland Region must be able to support electricity import flows of more than 1,000 MW during peak winter hours. A portion of these power inflows can be offset by storage facilities located within the region. These facilities can be of any form, including batteries, electric thermal storage, flywheels, but in order to offset electricity imports, they must be physically interconnected to the grid in the region or deliver electricity use offsets to buildings located in the region. This location requirement could present a hurdle to grid-scale storage solutions that require large footprints such as battery storage systems.

An alternative are smaller distributed storage options such as home battery back-up devices and passenger vehicle batteries. Assuming a centralized control system can be developed to provide management and operational control of thousands of such distributed storage facilities, it will still be necessary to obtain the consent of the owners of these systems to use them for this purpose. This may not be easy. The problem is that peak loads are likely to occur during a prolonged cold wave – at precisely the time residents and businesses will be most reliant on electric service for building heat. Whether many will allow the grid to drawn down their small distributed battery storage capacities during the coldest evenings in the winter, thereby leaving them fully exposed to power outages, is an open question.³⁹

A related issue will most certainly affect peoples' willingness to allow a central grid operator to drawn down the electric energy stored in vehicle batteries. Because these draw-downs are likely to occur during periods of very cold weather, the electricity stored in vehicle battery systems at those times is significantly derated in terms of the useful miles it can provide its owner. This limits the range the owner could subsequently travel in the event of an emergency. Further, to the extent any power outage is widespread across the region, the owner will have difficulty recharging his or her vehicle, because no charging station will be able to afford to install battery storage on the scale necessary to provide charging capacities in the event of a grid outage.⁴⁰

³⁹ It is important to note that in a zero-carbon economy, residents and businesses will not have backup propane or diesel generators to provide electric service during grid outages. While there may be no laws prohibiting such systems, the upstream infrastructure and delivery requirements to drill for, refine, store and deliver the fuels would be uneconomical.

⁴⁰ Consider a typical gas station with two underground 20,000 gallon storage tanks that are half full. Assuming an average of 20 mpg across the vehicles using this station, the stored gasoline can provide 400,000 miles of travel, which it can do with a backup generator in the event of a power outage. To provide the same travel miles during a cold winter period when the average EV is achieving 2 miles/kWh, the station would have to have a 200 MWh battery storage system. To put this in perspective, the battery system Tesla installed in Australia a few years ago has the ability to store 129 MWh of electricity and covers an area bigger than a full city block.

Ultimately, whether people allow a central grid operator access to its stored electricity in any form will depend on the price offered. The prior discussion suggests that the price will need to be quite high for the grid operator is to acquire access to much of the available storage capacity. The key question will be whether the price is less than the costs of the incremental grid capacity avoided.

Next, consider conditions of reverse power flows on any individual circuit. As we discuss further in the next chapter, reverse power flows in and of themselves do not create problems on the grid. What reverse power flows indicate, however, does. To see this, consider first the case where reverse power flows on a circuit do not exist. The absence of reverse power flow conditions on a circuit means that the amount of distributed solar PV generation interconnected to the circuit is always less than the amount of load served by the circuit. In this situation, any fault that results in an isolation of the circuit from the grid will collapse the circuit. The solar generators will not be able to sustain the load, voltage levels will fall, and each solar system will cease generating electricity, thus protecting any electrical equipment powered by the circuit.

On the other hand, when a reverse power flow occurs on a circuit, it means that the amount of distributed solar PV generation interconnect to the circuit exceeds loads served by the circuit. In this situation, if there is a fault at the substation that isolates the circuit from the grid, the circuit may not go down but instead may be supported and carried by the solar PV generation – the circuit may function as an electrical island in an unmanaged fashion. This can create serious problems. Because of the intermittency of the solar generation from multiple systems interconnected to the grid each operating on its own, the collective capability of those systems to follow load in a stable and reliable manner is highly uncertain. Absent some form of centralized control on the circuit, that mimics the function of an ISO or other grid manager, voltage fluctuations and instability are likely and can cause damage to electrical equipment connected to the circuit. Storage systems interconnected to the same circuit can provide some stabilizing effect on the islanded circuit, just as they do on the grid as a whole, but to do so requires some form of passive power management that involves communication and control feedback loops for the distributed solar PV and storage systems. These may cost more than alternatives that simply prevent islanding of any circuit by dispatching off all generation immediately upon isolation of the circuit from the grid.

We are certain there is a critical role for storage to play in reallocating energy across different time periods to meet electric loads. We are less certain that storage will play a major role as a transmission and distribution system capacity alternative. We note that this is an area that warrants significant research, modeling and analyses.

Chapter 7 - Electric Grid Design

7.1 Introduction

The purpose of the electric grid is to interconnect electric generators with electric consumers. The design and structure of the grid is constantly changing in response to changing generation technologies and the location of generating plants, on the one hand, and the location of electric consumers and how those consumers use electricity, on the other. It is also impacted by performance standards with respect to reliability and stability, each of which has become stricter over time, as electricity has become an essential utility in today's world. However, all the changes that have impacted the electric grid over the past century pale in comparison to those that must occur if we are to achieve a zero-carbon economy through beneficial electrification and deep decarbonization of electricity generation.

The previous chapter illustrates the inadequacies of the current electric grid in three critical respects. First, the distribution grid has far too little capacity to handle the amount of electricity that will flow to residential, commercial and industrial consumers as they convert their transportation vehicles, space heating and process requirements from distillate fuels and natural gas to electricity. Second, the existing grid will be unable to serve distributed rooftop solar generation as it is developed across all buildings. The distribution grid is not designed to accommodate multi-directional power flows and not equipped with the intelligence and capabilities to manage tens of thousands of small-scale electric generation plants and orders of magnitude more load centers and battery storage devices. Finally, the very low energy balance ratios that will exist even with full build-out of distributed rooftop solar systems will require substantially more energy imports into urban centers that, in turn, will require major increases in transmission capacities.

We look at each of these three grid deficiencies in this chapter; but first we focus on load forecasting and how load forecasting methodologies must adapt to incorporate changes in how we will use electricity in the future and advances in how such electricity use is measured.

7.2 Electricity Load Forecasting

The planning, design and buildout of any electric grid begins with a forecast of electricity loads. Since many components of electric grids are capital intensive and have fixed capacities, efficient and cost-effective planning of electric grids requires forward looking load forecasts of a minimum of ten (10) years, and for some components, even longer. It is simply not cost-effective to meet current load with a specific transformer or circuit conductor if future demands on the equipment are likely to exceed capacity ratings in the near future. In that case, it may be preferable to install equipment with higher capacity ratings to accommodate future load growth, even though some of this capacity may be excess capacity and not used today.

Techniques and methodologies for forecasting electric load have changed significantly over the past 100 years as the underlying factors impacting electricity use in the country have changed. During the initial build-out of localized transmission and distribution grids in the early 1900s, load was driven largely by electric lighting, and specifically how many existing homes, businesses and public facilities could be interconnected to the grid. Forecasting demand for electricity was less important than extending the distribution grid to increasing numbers of end-users. During this initial period of electrification, the overriding objective was to interconnect buildings of all types to bring electric service to as many businesses and people as economically feasible. The use of the grid by those end-users was of secondary concern, except for certain high-intensity end-users.

This all changed following the end of World War II. In the immediate post war years, electricity demand was driven by three factors – (a) the suburbanization of housing and related commercial establishments, (b) the electrification of residential appliances (e.g., clothes washers and dryers, stoves, air conditioning, space heating and hot water systems) and commercial HVAC systems and the diffusion of those appliances and systems across the existing and new housing and building stocks, and (c) the electrification of production processes. Unlike the first wave of electrification that drove the development and dissemination of the electric grid, this second wave of electrification resulted in an expansion of electricity demand at virtually each location on the grid. Electricity demand became less a function of the number of buildings interconnected to the grid than to the end-uses of electricity at each point of interconnection.

This meant that the relative importance of macroeconomic variables in driving electric loads gave ground to variables measuring the market penetration of end-use technologies and equipment powered by electricity. As a result, utilities undertook spatial and temporal studies of how various

end-use equipment consumed electricity and then how these types of equipment would be adopted by customers across the grid. The new electricity forecasting models reflected underlying trend lines related to overall economic growth within a utility service territory. These trend lines, however, were modified by forecasted penetration of key end-uses such as commercial HVAC systems, residential air conditioning, and washers and dryers and the results of studies showing how these end-uses consumed electricity. Perhaps not surprisingly, given that the relative price of electricity fell during this period, these forecasting models generally did not include any price terms. The concept that demand for electricity was responsive to the price of electricity was generally not a factor in estimating future electricity demands.

The consequence of the failure to consider the price of electricity in forecasts of electricity loads became apparent in the aftermath of the oil embargoes of the 1970s and major cost overruns in nuclear plant construction during the 1980s. The forecasts of electricity demand that were used in part to support the buildout of new generation plants were proven wrong. As electricity prices rose, demand for electricity slowed. Initially, this slowdown was driven largely by price effects – what economists refer to as the price elasticity of demand. People responded to higher prices by using less electricity. Over time, of course, the market (with help and encouragement from government regulations and financial incentives) responded with new technologies and equipment that was more energy efficient, so much so that for many utility service territories, the increase in efficiency and conservation has offset the underlying macroeconomic driven trend lines. Load forecasting models have adapted to this situation by incorporating economic growth/income variables, price variables and the impacts of energy efficiency and conservation, although many such models have tended to underestimate the load suppression effects of this last factor.

The present danger with current load forecasting models is that they will repeat the errors of the past by not adapting to changed market conditions and specifically to the next wave of electrification – beneficial electrification of transportation, space heating and industrial and commercial processes. As we have shown in the Portland Area and across the State of Maine, electricity use will increase three- to four-fold as we convert these three sectors to electricity. The speed at which this occurs will be the primary factor that determines electricity load growth over the next thirty years. Further, the geospatial locations of the people and businesses that are leaders in this conversion will determine where new transmission and distribution plants will be required, which, in turn, will define the physical layout and requirements of tomorrow's electricity grid. These

factors must become the building blocks for electricity load forecasting models, as we return to models designed to build from the bottom-up rather than from the top-down.

Fortunately, the design and development of the next generation of electricity load forecasting models can be built on a data and information system infrastructure that is made possible by advanced metering technologies, so-called "big-data" systems, advances in artificial intelligence and networked information systems. We don't have to sample 2,000 Maine households to measure hourly consumption of electricity that can then be applied statistically to all 700,000 plus households in Maine. CMP's and Emera Maine's smart meters already measure, capture and store this data for virtually all 700,000 households. We don't have to guess the levels of peak power flows on distribution circuits, through transformers and at substations. Advanced metering and communications systems embedded in the grid are available to provide this information. We don't have to build electricity forecasting models based on aggregate measures of growth, electricity price projections and technology penetration. We can build electricity use models from the fundamental building block of the customer meters that can then be used to estimate hourly (or even finer time intervals) power flows across circuits, through transformers, into and out of substations and ultimately up to large high-voltage power flows on major transmission lines. Once these electricity use models are built, forecasting models can apply estimates of temporal and spatial expansions of beneficial electrification of the various sectors of the economy to predict electricity loads, not just for the aggregate utility service territory, but for subregions of the utility's service territory down to individual neighborhoods. This is the "stuff" upon which the design and development of the next generation of the electric grid must be based.

Based on our work in the Portland Area and a similar type of analysis for the State of Maine, we believe that the process of forecasting electric loads used by CMP and Emera Maine and by others involved in the planning and design of Maine's electric grids needs to be completely overhauled and rebuilt from the bottom-up, as described above. We are beginning to see some recognition of the mismatch between the results of current forecast models and the policy goals and laws and regulations of the New England states creep into load forecasts being done by ISO-NE. These efforts, however, are at best in the earliest of stages and reflect ad hoc or piecemeal add-ons to the forecasts produced using the traditional models at ISO-NE. We strongly recommend that the Maine Public Utilities Commission initiate an open, non-adjudicatory proceeding for the purposes of developing new electricity load forecasting methodologies. We do not believe that this initiative should act to suspend transmission and distribution projects that are currently under consideration

or in the immediate pipeline. Instead, as an interim step, we recommend that these projects be assessed in terms of the likelihood of being components of a major expansion of the grid in the electric region in which they are located at some point over the next 20 years. If it is reasonable to conclude that a specific project is not – that it will be inadequate to meet loads under beneficial electrification, then the project should be suspended and reconsidered. We illustrate how this process could be applied in the Portland Area in the next chapter.

7.3 Expanding the Distribution Grid

Figure 6-2 shows that most existing distribution circuits in the Portland Area have excess capacity, and assuming conductor ratings in the 7-10 MVA range, can meet increased electricity flows as a result of beneficial electrification into the mid-2030s. Beyond this time period, however, the existing circuit configuration is simply inadequate to meet anticipated electricity loads. If the distribution conductor sizes and their ratings remain in the 7-10 MVA range, we would need to roughly double the number of distribution circuits to meet loads and retain some excess capacity to accommodate load growth or customer relocations. However, the fact that increased heating loads are the primary factor driving the need for additional distribution circuit capacity and that these loads occur in the winter and not just on any winter day, but on the coldest winter day means that conductor ratings for each given conductor size are likely higher.

Figure 4-6 offers some insight into the factors that will drive the number and sizing of distribution circuits post beneficial electrification. Relative to current peak loads of 271 MW that occur during the summer, winter peak loads by 2050 will be 1,100 MW, while summer peak loads will be around 600 MW. Depending on the winter and summer ratings for conductors at ambient air temperatures of around -10°F and 95°F, respectively, individual circuits in the region may be winter or summer peaking. In either case, the relationship between winter loadings, ambient air temperatures and grid component ratings is an important factor and needs to be carefully considered as heating becomes electrified.

A doubling of the number of distribution circuits over the next 30 years will require significant capital investments. Further, as shown in Table 4-1, the annual capacity factor of Maine's electric grid will fall from around 71% in 2020 to 43% in 2050, largely as a result of the increase in heating loads during the winter season. Together, these factors will lead to rate increases and more money being spent by Maine families and businesses on electricity. However, these rate increases

and higher spending will be offset – perhaps entirely if we are careful in how we organize and manage this transition to electrification – by reductions in spending on fossil fuels.⁴¹

Increases in the carrying capacities of the distribution grid will require more miles of distribution circuits and more and/or larger sized distribution substations. We would not expect to see more than one distribution circuit in front of each home or business, so in this sense, the basic building block of the distribution grid will not look much different tomorrow than it does today to the typical Mainer. What will change is that the circuits will need to be reconductored to support higher peak loads; there will need to be more circuits with longer runs back to the existing substation locations; the number (not just the capacities) of substations will need to increase; or most likely, a combination of all three. Assuming we don't move to more undergrounding of distribution lines, we are likely to see taller telephone poles to provide improved reliability and increased space reserved on these poles to carry more than one distribution circuit.

The land-use impacts of an expanded distribution grid are most likely to occur as a result of expansions of existing distribution substations and/or the construction of new substations. This could present a challenge to utility planners, given the lack of available space in urban centers and the general opposition to new electrical substations in residential neighborhoods. In either case, we believe it is prudent for utilities to consider acquiring for future use a number of parcels of land across their service territories to site new electrical distribution substations and to work with towns to ensure that their land-use plans, zoning and building codes accommodate the types of electrical grid upgrades and expansions that will be necessary to support beneficial electrification and increased distributed generation.

One consideration that could further increase the required size of the distribution grid is a redesign of that grid from a radial system to a networked system. It is useful to characterize the current distribution grid as a radial grid in which each load is served through only one physical delivery path. This is the situation for the majority of CMP's service territory, although we understand that CMP does have some limited networked distribution circuits located in downtown Portland.

⁴¹ While this may be accomplished in the aggregate, there will be many individual residents and businesses whose energy use is electricity intensive. They are likely to see an increase in their overall energy costs even if overall spending on energy remains flat in real terms.

Network designs provide improved reliability to distribution grids by enabling loads to be served through a second path and perhaps multiple paths. This increased reliability, however, comes at a cost. Each segment of each path of delivery must be able to support all possible flow configurations within the network. Unlike in radial designs where the ends of radial circuits support smaller loads and therefore can be built for lower electricity flows, a networked system must be able to support the maximum flow on all its components. In practice, this requires larger capacity conductors, more reclosers and generally shorter circuit run lengths, especially under beneficial electrification, where overall flows are much higher than they are today.

7.4 Accommodating Multi-Directional Power Flows

Beneficial electrification drives the need to expand the grid to deliver more electricity to all end-users. Deep decarbonization, through the development of renewable generation and in particular distributed generation, creates a different set of problems for distribution grids. Figure 6-3 shows that virtually all the distribution circuits in the Portland Area will experience reverse power flows by 2050 as distributed roof-top solar systems are built out across the region, thus triggering islanding concerns across the entire distribution grid. This is true even though in total this solar generation will meet less than 40% of the region's electricity requirements in 2050.

This, of course, only deals with one form of distributed generation. As a result of a legislatively mandated expansion of net metering opportunities and utility purchases of distributed generation output, we are currently seeing an explosion of proposed distributed ground-mounted solar projects, all less than 5 MW in total capacity. When many project developers seek to interconnect relatively small-scale (less than 5 MW of capacity) solar PV systems to distribution circuits, issues related to conductor, transformer and substation capacities as well as system reliability due to pervasive reverse power flows and potential islanding concerns are impacting the electric grid now, not 20 years from now.

At the heart of the matter is the question of who pays for upgrades to utility transmission and distribution systems that will be necessary for the state to achieve its overall emission target reductions over the next thirty years. The rules and regulations currently in place for allocating cost obligations across all users of the grid (both the existing grid and expansions of this grid) are different for CMP than for Emera Maine, different for new load than for new generation and different for some new generation than for other new generation, even though the two generation

projects might be essentially identical in all material respects. These rules and regulations were put in place in an era before distributed generation, when generators were large-scale facilities interconnected to the transmission components of the grid. In addition, they reflect compromises that may have been important decades ago but are simply no longer relevant today. Most important, they convey preferential access rights to use transmission and distribution grid capacities paid for by load to certain generators and not others through interconnection processes. The effect is to slowdown and even stall completely the development of new distributed generation at certain points on the grid.

There may be grid designs in the future that can enable Maine to meet its emission reduction objectives that do not require the ability to accommodate reverse power flows at the distribution level. What is clear, however, is that such a grid will be incapable of supporting an even modest buildout of distributed generation. Further, it will not support a network design structure in which point sources of load, distributed generation systems and battery storage are used in an optimal manner to meet grid requirements for the delivery of electricity, reliability and stability.

This last point is important. Introducing network-like designs into a broader geographic range of the distribution system not only enables multi-direction power flows, it permits loads to be served through multiple delivery paths, thus increasing reliability. Since the vast majority of power outages occur on specific distribution circuits, having a second or even third path for power to flow to loads can have a very significant impact on grid reliability.

Two factors impact the ability to design networked distribution systems capable of supporting multi-directional power flows. The first is the requirement that distributed generation can never be operated to serve load when such generation and load are "islanded" (that is, disconnected from the main transmission and distribution grid) unintentionally. Anti-islanding requirements are necessary to prevent distributed generation that is not intended or capable of serving load without the support of the electric grid from ever doing so, thereby leading to unsafe conditions that could cause major equipment damage and threaten health and safety. At issue is the achievement of a balancing of sometimes competing factors. On the one hand, anti-islanding requires all distributed generation sources (including the smallest rooftop facilities) to dispatch off at the exact instant the interconnection to the grid is lost. On the other hand, distributed generation can provide reliability and stability services to the broader grid if a problem is imminent, but only if these resources remain interconnected to the grid. In either case, however, there needs to be communication capabilities between the grid and each distributed generation resource that controls

the on/off status of that resource. This can be expensive for small-scale distributed generation. It has not been a problem to date – and likely won't be an issue for a number of years, at least until power flows on distribution circuits reach negative levels at the substation due to the development of such distributed generation resources. Perhaps by then, widespread development of 5G wireless communication networks or other forms of communications may reduce communications costs and expand capabilities.

Assuming the technical issues related to anti-islanding can be addressed, the first area that requires policy attention relates to the interconnection of renewable generation projects to the electric grid. While some progress has been made in streamlining interconnection studies and standards, especially for smaller-scale projects, the interconnection process continues to present problems for project developers, especially in those instances in which the utility identifies necessary upstream grid improvements. Under current rules, any available capacity on the grid to support generator interconnection (capacity that has been paid for by ratepayers) is allocated at no charge to interconnecting generators on a first-come, first-served basis until such capacity is exhausted. At this point, the next generator in the interconnection queue must pay the full cost of all upstream improvements and upgrades to the grid that are required to interconnect its project. For small projects, the costs of this upgrade can amount to multiple times the cost of the project itself. Adding insult to injury, the next and succeeding generators in the queue able to utilize any spare capacity created as a result of the upgrades paid for by the previous generator in the queue. Not surprisingly, this policy acts as a serious drag on the development of renewable generation projects, and in some states such as Hawaii and California that are further ahead than Maine, has resulted in generation interconnection moratoria.

This current structure is intended to ensure that large-scale generators bear the interconnection costs for their location decisions to discourage uneconomic location decisions, the cost of which would otherwise be borne by ratepayers. This policy had merit for large-scale generation projects, such as nuclear plants and combined-cycle natural gas plants. However, today, the vast majority of interconnection requests are not from large nuclear, gas or coal plants, or even wind farms, but rather are from small-scale distributed generation resources, many of which are interconnected behind the customer's meter. The current interconnection process is simply not useful for these types of generation projects. The interconnection queue and the allocation of interconnection costs need fundamental change.

One proposal for addressing this issue is the so-called "clustering approach". This approach allows multiple generators to pool together to pay for grid related upgrades necessary for their interconnections. While there may be some cases involving a small number of very large-scale projects located in the same region of the electric grid where clustering could work, we are skeptical that this type of clustering will be effective in the majority of cases, especially those involving thousands of distributed solar PV installations and battery storage generation resources.

An alternative form of clustering is where the utility, acting on its own initiate, aggregates a number of small-scale distributed generation projects in its interconnection queue for simultaneous study. This new approach is being used across the New England Control Area. We are not sure of how this approach will work in those cases where the study indicates upgrade requirements are necessary for the transmission system. Open questions remain as to how the costs of such upgrades as well as the incremental interconnection capacity they create will be assigned in the first instance, and then reassigned when one or more of the distributed generation projects do not move forward to be built.

We believe that a better approach is one that facilitates the interconnection of small-scale projects, while preserving the price signaling feature of the current process for large utility-scale developments. This can be accomplished by allocating to electric loads in Maine the first \$3 million of any upstream grid costs required to interconnect a generator. This compromise relieves distributed generation resources of the need to upgrade the immediately upstream substation as well as any feeders, reclosers, switches or other equipment located on the circuit serving the interconnecting generator, because these costs are almost always less than \$3 million. Further, these are components of the distribution grid that will need to be upgraded to accommodate beneficial electrification – upgrades that would otherwise be paid for by load. In comparison, those large-scale generators such as utility-scale solar and off-shore wind, whose interconnection may impose significantly more costs on the utility in the form of new substation construction, new transformation capacity transmission line upgrades and other electronic equipment, will bear all costs in excess of the \$3 million.

7.5 Addressing Regional Energy Balances

Figure 6-7 illustrates the fundamental mismatch between the growth in electricity use and the build-out of zero-emission, renewable generation to enable Maine to achieve a zero-carbon economy

by 2050. Urban centers such as the Portland Region are not likely to be able to site generation within the region in enough quantity or of the appropriate type to offset peak load demands that will occur during the evening hours on the coldest days of the year. This means that most if not all this demand must be met through importing power from outside the region through new transmission lines.

Meeting this energy requirement will require major new 345 kV and 115 kV transmission lines as well as associated substations to meet N-1-1 conditions. The siting of these lines and substations will present serious challenges to the utility and to local governments. As anyone driving around the new Ravens Farm substation in Yarmouth will attest, high voltage substations are quite large and have much more of an industrial quality to them than most of the electric equipment found in towns in the region. In addition, the extensive new 115 kV loops in each of the southern and northern sections of the region to step-down power flows on these new 345 kV transmission lines for delivery downstream on the grid will present their own unique siting challenges. Further, once these lines are built, the entire system will become part of the bulk power system under which reliability standards will require meeting N-1-1 conditions.

Less obvious will be the fact that the higher load levels at various substations will likely require additional distribution feeders and, under a 25 MW maximum consequential loss of load requirement, may require redundancy of many components of the distribution system in the region, because each of these components will represent single points of failure that will expose loads in excess of 25 MW to consequential loss.

In the next chapter, we look at these new grid requirements and lay out one possible option for what the grid will need to look like to meet the increased peak load demands that come from beneficial electrification.

Chapter 8 - Portland Area

In this chapter, we consider the design of a transmission and subtransmission grid in the Portland Region that is capable of meeting reliably electricity demands post beneficial electrification. Our effort is necessarily limited. First, we are focusing on an electric region that is defined today in the context of the overall electric grid in Maine and current electricity usage levels. As electricity usage increases due to beneficial electrification, we may find that the existing electric regions are not optimal and need to be adjusted.

Second, we have not defined the source of generation except to allow for 1,000 MW of offshore wind landed at Wyman Station in Yarmouth and at the Tank Farm in South Portland. Since post 2050, the Wyman units in Yarmouth, the Calpine Westbrook gas plant and the Cape diesel units will all be shut down to meet the State's zero carbon requirements, we have assumed that some portion of the 5+ GW of offshore wind capacity in the Gulf of Maine will be interconnected to the New England electric grid in the region, as noted. We have further assumed that additional onshore wind and solar PV (in conjunction with battery storage) will be interconnected to the backbone system and, based on our proposed design of the grid in this region, capable of delivery into the region.

Third, GridSolar does not have the technical capabilities nor the electric system models to develop and test existing or potential electric grids. This is particularly important with respect to parallel electricity flows, voltage conditions and stability. It is also important in specifying grid components with ratings consistent with grid conditions during peak usage and peak power flows.

Our design looks only at system demands during periods of peak loads. We have designed the grid to ensure it can meet expected peak loads post beneficial electrification based on typical capacity ratings for key system components. Our effort here is a very high level exercise; further testing and refinement is necessary by those with the technical capacities to conduct this research and analysis. Nevertheless, we believe that our approach is highly instructive of the design features the grid must possess to meet future electricity demands and the costs of these features.

Further, and of direct relevance to the Portland Region, we believe that our modeling provides an important context for consideration of the reliability upgrades CMP has identified as required to meet reliability standards. These upgrades are based on current load levels. Therefore, they provide a very limited picture of what is required over the next 30 years if Maine is to meet its climate commitments.

We have divided this chapter into subsections that address each voltage level of the grid – 345 kV, 115 kV and 34.5 kV. At each level, we identify a grid design that has the capacity to meet peak loads post 2050. We use standard industry data and CMP cost estimates for other projects to estimate the cost of the incremental grid components that need to be developed. We estimate these costs to be roughly \$2.5 billion in today's dollars. Of perhaps equal importance, we estimate that these components will require a land area that is roughly four-times the amount of land used by the 40 linear miles of I-295 and I-95 from the Freeport-Brunswick border to the Scarborough-Saco border.

8.1 The 345 kV Transmission Grid

8.1.1 The 345 kV Transmission Grid - 2020

The existing (post-MPRP) 345 kV grid in Southern Maine is represented in Figure 8-1. All transmission segments are 345 kV. The current grid provides 3 separate 345 kV transmission paths for electricity to flow into/out of the Portland Region from New Hampshire (Deerfield, Scobie and Three Rivers) in the south to Maine Yankee/Larrabbe Road in the north. These transmission lines can deliver enough electricity to the Portland Region to meet current peak loads of 400 MW (give-or-take) under N-1-1 conditions (and assuming both Wyman 4 and Calpine-Westbrook are out of service). Electricity delivered to the Portland Region is stepped down to 115 kV at Surowiec (one 345/115 kV auto transformer) and South Gorham (two 345/115 kV autotransformers – the second one was added as part of the MPRP). The Raven Farm and Buxton substations do not currently offer step-down service. The Raven Farm substation was specifically built to handle an additional 345/115 kV autotransformer and a 115 kV feed to Cape Elizabeth. This part of the substation has not been built, pending the results of the Portland Area efforts. We expect the Buxton substation was built to enable a 345 kV line to extend to the South Gorham substation, thereby allowing service to that substation from the main north-south backbone as well as from Wyman 4 in Yarmouth.

We believe that the Portland Region's 345 kV grid meets all reliability standards at current load levels. It is the underlying 115 kV and 34.5 kV systems that CMP has identified as weak and where the issues lie and to which CMP has proposed its regional solution to address. The major components of this solution include:

1. A new 345/115 kV autotransformer at Raven Farm and a new 115 kV substation

- 2. A new 115 kV line from Raven Farm to Cape Elizabeth
- 3 new 115/34.5 kV substations North Yarmouth (off Surowiec) and East Deering and Anderson Rd (off the new line from Raven Farm to South Portland
- Upgrades to the Pleasant Hill Rd. substation to accommodate a new 115 kV line from South Gorham



Figure 8-1 Electrical Representation of the 345 kV System - 2020

8.1.2 The 345 kV Transmission Grid – Post 2050

For purposes of simplifying and to define the requirements of the 345 kV grid in 2050, we assume that peak load in the Portland Region is around 1,000 MW in 2050. We further assume that two, 1,000 MW (+/-) Offshore Wind Farms (OWFs) interconnect in the Portland Region; that 1,000 MW of utility-scale solar PV facilities (greater than 100 MW) are developed in or adjacent to the Portland Region; and that the large-scale battery storage systems to meet seasonal cycling requirements are located outside the region where there is more space.

These assumptions create the following conditions – as shown in Figure 8-2:

New Generation:

- Two Offshore Wind Farms (OWF) have landing points for either AC or DC interties with Offshore Wind Farms – OWF A and OWF B – located in the Gulf of Maine. (We might anticipate as many as three more landing points in Maine – Maine Yankee, Bucksport and Rockland – for a total of 5 GW of OWF capacity.)
- An Aggregation and Delivery point for 1,000 MW of solar PV located in Cumberland and York Counties. While these large-scale solar PV systems (each in 100 MW or greater) may deliver power to the underlying 115 kV grid, they will need a separate path to the 345 kV grid, or they will overwhelm the conductor capacities of the 115 kV grid under maximum generation scenarios. Alternatively, the 1,000 MW of solar could come from far outside the region where land is more readily available. In this case, the existing grid might be adequate for importing the electricity assuming there are no demands on the existing grid to move this electricity south through the region which, given the sharp increases in electric loads by 2050, seems highly unlikely.

New 345 kV substations:

- OWF A assumed to land at Wyman and displace a retired or infrequently run Wyman 4.
 No new substation is required for this landing point. (However, if the OWF is delivered to the mainland as dc power, a converter station will need to be located here.)
- OWF B assumed to land at a new substation located at the tank farms in South Portland. (This could also include a dc converter station.)

• Solar PV – assumed to require a new substation located near or adjacent to South Gorham substation.

The 345 kV grid in the Portland Region must serve two functions. First, it must allow for the interconnection of the new large generation sources to the main 345 kV grid in the State. This is accomplished through generator leads – much the same way Wyman 4 has been and still is interconnected to South Gorham (via Raven Farm). The existing line 3039 from Wyman to Raven Farm serves this purpose for OWF A. New 345 kV lines – 3042 and 3050 serve this purpose for the solar PV and OWF B, respectively.

The second function is the ability to deliver electricity into the Portland Region under peak load (and minimum generation) conditions – a net of 1,000 MW under our assumptions above – while meeting N-1-1 conditions. This requires the development of a pair of 345 kV loops within the Portland Region to enable the grid to deliver 1,000 MW of electricity under N-1-1 conditions – where any 2 segments are off-line simultaneously.

New 345 kV lines:

One design for the loops is illustrated in the Figure 8-2. This design requires the following new 345 kV line segments, in addition to the "generator leads" noted above.

- 3038 Wyman Station to Raven Farm a parallel path to the existing line 3039.
- 3041 and 3042 Raven Farm to Solar PV to South Gorham a parallel path to line 3040 from Raven Farm to South Gorham.
- 3050 Generator lead from South Portland to South Gorham
- 3052 and 3042 South Portland to Solar PV to South Gorham a parallel path to line 3050
- 3060 and 3061 Two parallel paths completing the loop from South Portland to Wyman, both of which are likely to be undersea cables, given land constraints.
- 3043 Surowiec to Solar PV to provide a fourth 345 kV entry point to deliver electricity into the Portland Region from the main 345 kV grid. (This could also come over from the Buxton 345 substation.)

This configuration would require new 345/115 kV autotransformers at Raven Farms, South Portland and Solar PV, based on our suggested design of the 115 kV grid discussed in the Section 8.2 below.

This new 345 kV loop accomplishes the following objectives:

- It enables generation to flow from the two OWFs and from the solar PV (through Solar PV 345 substation) under all N-1-1 conditions.
- It enables 1,000 MW of electricity to flow uninterrupted around the loop under all N-1-1 conditions.
- 3. It enables 1,000 MW of electricity to flow from the main 345 kV grid (assuming there is zero wind and solar generation) under all N-1-1 conditions. There are 4 paths to the 345 kV Portland Loop three existing ones lines 3020, 3010 and 3021, plus a new one 3043.





8.1.3 Estimated Costs of the 345 kV Grid Additions

The estimated costs of the additions and modifications to the 345 kV grid to meet peak load conditions in the Portland Region at N-1-1 reliability levels are just under \$1 billion (in 2020 dollars) as shown in Table 8-1. We have developed these cost estimates from those prepared by CMP to support the development of the Maine Power Reliability Program (MPRP). The MPRP costs used were from the latest of such filings made in August 2009. Table 1 identifies each of the MPRP substations we used as a model for each of the new substations and the estimated costs for these in 2009 – e.g., we used the new Coopers Mills substation as the reference model for the proposed new South Portland substation. The 2009 cost estimates were inflated by cost inflation to 2020 using an average annual inflation rate of 3%. We made no adjustments to reflect potential land acquisition and construction cost differentials in the greater Portland area compared to the model areas.

The lower portion of Table 8-1 identifies various 345 kV line segments that were proposed for construction under the MPRP. Each segment shows its length and estimated costs. We used these to calculate an average cost per mile. The average cost per mile across these 7 segments and 182 miles was just under \$2.5 million. We increased this to \$4.652 million per mile to adjust for what we would expect to be higher construction costs within the Portland Region. We compared the costs of 115 kV line segments to be constructed north of Lewiston to those to be constructed in the Portland Region. When the averages of these two sets is compared in 2020 dollars using a 3% average inflation factor, the Portland Region costs are almost double those in the rural area north of Lewiston. This adjustment is shown in Table 2.

Finally, since the MPRP did not contain any undersea cable components, we made the assumption that the 2009 cost of constructing 345 kV line segments undersea would have been twotimes the cost per mile of average land-based systems. This comes to a little over \$9 million a mile, which is in the range of HVDC undersea cable systems. (We note also that a relatively short 1.2 mile underground segment of 115 kV cable in downtown Lewiston was estimated by CMP to cost about \$7 million in 2009.)

Table 8-1 Estimated Costs (2020\$) of 345 kV Grid Additions

	Costs -	2008	Costs - 2020	
345 kV Substations	(millio	on\$)	(million\$)	
Wyman OWF				
Model - Suroweic MPRP		\$32.156	\$44.51	
Substation Upgrade	\$30.144			
Line Terminations	\$1.006			
South Portland OWF				
Model - Coopers Mills MPRP		\$124.252	\$171.99	
Substation	\$119.856			
Line Terminations	\$4.396			
Solar PV				
Model - Larrabbe Road MPRP				
Substation	\$71.357	\$73.406	\$101.61	
Line Terminations	\$2.049			
345 kV Segments - Land-Based	Miles			
3050 - S. Portland to S. Gorham	10.0	\$46.516	\$64.39	
3051 - S. Portland to Solar PV	10.0	\$46.516	\$64.39	
3042 - S. Gorham to Solar PV	1.0	\$4.652	\$6.44	
3043 - Suroweic to Solar PV	23.0	\$106.986	\$148.09	
3041 - Raven Farms to Solar PV	16.0	\$74.425	\$103.02	
3038 - Wyman to Raven Farm	6.0	\$27.909	\$38.63	
345 kV Segments - Undersea				
3060 - Wyman to S. Portland	9.0	\$83.728	\$115.90	
3061 - Wyman to S. Portland	9.0	\$83.728	\$115.90	
Total Capital Investment - 2020\$	84.0		\$974.88	

		Cost	Cost/Mile
MDRD	Miles	(million\$)	(million\$)
	Willes	(111110113)	(111110113)
3020 - Raven Farm to Suroweic	10.0	\$29.400	\$2.940
3021 - S. Gorham to Maguire	21.0	\$50.200	\$2.390
3022 - Maguire to Three Rivers	19.2	\$46.800	\$2.438
3023 - Orrington to Albion	59.0	\$112.485	\$1.907
3024 - Albion to Coopers Mills	21.0	\$54.026	\$2.573
3025 - Larrabbe to Coopers Mills	17.0	\$32.935	\$1.937
3026 - Larrabbe top Suroweic	34.4	\$121.350	\$3.528
	181.6	\$447.196	\$2.463
Adjust Portland Area Costs			\$4.652
Undersea 345 kV Costs Per Mile			\$9.303
Factor Increase 2			
Cost Adjustment Factor to 2020			138.4%
Est. Avg. Annual Inflation 2009 - 2020 %	3.0%		

Source: MPRP Cost Estimate of PPA by Component and Region CMP Filing in Docket No. 2008-00255 - Attachment 3 8-Aug-09

Table 8-2Estimate of Portland Region Cost Differential

2009 to 2018 Inflation Factor at 3%	130.5%			
2018 to 2020 Inflation Factor at 3%	106.1%			
	Miles	Cost	Cost/Mile	2020\$
MPRP - 2009				
251 - Larrabbe to Livermore Falls	24.1	\$33.625	\$1.395	\$1.820
255 - Larrabbe to Middle St (Lewiston)	4.2	\$6.048	\$1.440	\$1.879
Average				\$1.850
Portland Region - 2018				
So. Gorham to Pleasant Hill	9	\$25.800	\$2.867	\$3.041
Raven Farm to East Deering	10	\$37.200	\$3.720	\$3.947
Average				\$3.494
Portland Region Cost Adjustment Factor				189%

8.2 The 115 kV Transmission Grid

8.2.1 The 115 kV Grid – Post 2050

The existing 115 kV grid in the Portland Region consists of 12 substations fed from the 345 kV system at Surowiec and South Gorham. According to CMP's 2018 Needs Assessment, this grid is inadequate to meet current 90/10 peak load levels of 400 MW under N-1-1 conditions. It is woefully inadequate at the much higher 1,100-plus MW peak load levels by 2050.

The 115 kV grid for the Portland Region by 2050 will be part of the Bulk Power System. Accordingly, it must meet the following conditions:

- 1. It must satisfy N-1-1 conditions.
- 2. It must be capable of delivering electricity to all sub-regions at the load requirements for these regions in 2050.
- 3. It cannot be designed to place loads on the conductors that exceed ratings which we have assumed to be 200 MW, based on winter ratings, since this peak occurs during the winter. One design that we believe meets these standards is represented in Figure 8-3. This design is

based on the delineation of electric sub-regions, each one served by a major 115 kV substation. Since peak loads are 1,100 MW, the seven sub-regions can be defined in which each sub-region has a peak load of less than 200 MW.⁴² The seven sub-regions are – Raven Farm, Surowiec, Central, S.

⁴² We have allowed the South Portland substation to exceed this load level by a small amount.

Portland, S. Gorham, Solar and Spring St. Estimated 2050 peak loads (measured at the current substations – see Chapter 6) are shown in Table 8-3 – along with their allocations to one of the seven sub-regions.

Table 8-3Load Assigned to Sub-Regions

Existing Substations	Assigned Sub-Region	Peak Load (MW)
Cape Elizabeth	S. Portland	50.92
Rigby	S. Portland	37.81
Pleasant Hill	S. Portland	69.22
Hinckley Pond	S. Portland	49.86
Subtotal - S. Portland		207.81
Red Brook	S. Gorham	9.08
Scarborough	S. Gorham	29.89
Dunston	S. Gorham	28.87
Western Avenue	S. Gorham	26.65
Mussey	S. Gorham	10.63
Westbrook	S. Gorham	34.64
Subtotal - S. Gorham		139.76
Falmouth	Spring St.	32.58
Spring St. 115 kV	Spring St.	11.05
Spring St. 34.5 kV	Spring St.	34.58
Bishop	Spring St.	69.20
Lambert	Spring St.	48.03
Subtotal - Spring St.		195.44
Swett	Solar	42.65
Prides Corner	Solar	49.83
Brighton	Solar	25.57
Mosher	Solar	32.26
Subtotal - Solar		150.31
Forest Avenue	Central	22.85
Union	Central	61.91
Sewall	Central	52.13
Fore River	Central	48.36
Subtotal - Central		185.25
Gray	Suroweic	56.01
Freeport	Suroweic	52.60
Subtotal - Suroweic		108.61
East Deering	Raven	38.90
Elm St 115 kV	Raven	106.42
Wyman	Raven	18.82
Subtotal - Raven Farm		164.14
TOTAL - PORTLAND REGION		1151.32

Figure 8-3 shows each of the seven 115 kV substations that serve each of the sub-regions. This configuration incorporates the existing substations at Surowiec, S. Gorham and Spring St. and adds four new substations – Raven Farm, Solar, Central and S. Portland.⁴³ Three of these are located adjacent to 345 kV substations. The exception is Central. This substation is located in Portland center to serve loads in the central parts of Portland.



Figure 8-3 Electrical Representation of the 115 kV Grid – Post 2050

By design, each of the substations is served by a minimum of three 115 kV lines that extend back to 345 kV substations. This allows for each sub-region's peak loads to be served under N-1-1

⁴³ The E. Deering substation is shown as a new 115 kV substation; however, its design and scope of services provided is more akin to the other substations shown in green than to these 115 kV substations.

conditions. In addition, each of the other 115 kV stations (shown in green) are capable of being served by two different upstream substations without exceeding the 200 MW threshold. The exception is E. Deering. If service is lost from Raven Farm and E. Deering is forced to be served from Central, the total loads at Central would exceed 200 MW. This has been addressed by adding a second feed from Raven Farm to Central. While this feed has to go only as far as the E. Deering substation to meet this requirement, we have extended it all the way to Central to provide additional redundancy into downtown Portland.

As with the 345 kV system, we have estimated the costs for the new substation facilities using model substation costs from the MPRP, inflated to 2020. The results are shown in Table 4. Costs for the 115 kV lines are estimated using costs per mile values from the 2018 Portland Area Study that have been similarly inflated to 2020. In addition, we added 1 mile of undersea cabling to connect the Central and S. Portland substations. The total estimated cost of the new facilities is \$520 million.

	Costs - 2	2009	Costs - 2020
115 kV Substations	(millio	n\$)	(million\$)
Raven Farms			
Model - Raven Farms MPRP		\$44.700	\$61.88
Substation Upgrade	\$38.470		
Line Terminations	\$3.115		
South Portland			
Model - Raven Farm MPRP		\$41.585	\$57.56
Substation	\$38.470		
Line Terminations	\$3.115		
Solar PV			
Model - S. Gorham MPRP			
Substation	\$28.872	\$29.851	\$41.32
Line Terminations	\$0.979		
Central			
Model - Raven Farm MPRP			
Substation	\$38.470	\$41.585	\$57.56
Line Terminations	\$3.115		
115 kV Segments - Land-Based	Miles		
4064-A - Raven Farms to Central	12.0		\$41.93
4064-B - Raven Farms to Central	12.0		\$41.93
4066 - S. Portland to Spring St.	10.0		\$34.94
4067 - Solar to Spring St.	3.0		\$10.48
4068 - Solar to S. Gorham	3.0		\$10.48
4069 - Solar to Suroweic	23.0		\$80.36
4070 - S. Gorham to S. Portland	10.0		\$34.94
4071 - S. Gorham to Central	11.0		\$38.43
115 kV Segments - Undersea			
4065 - Central to S. Portland	1.0		\$8.42
Total Capital Investment - 2020\$	85.0		\$520.23

Table 8-4Estimated Costs (2020%) for 115 kV Grid Additions

8.3 The 34.5 kV Subtransmission System

The primary impact beneficial electrification has on the 115 kV and 345 kV transmission grids is to increase the number of substations and lines within the Portland Region. Because the larger transmission grid must satisfy N-1-1 reliability conditions, that grid remains loop fed and allows bidirectional electricity flows. The overall design and general structure of the grid itself is largely unchanged. This is not the case with the underlying 34.5 kV grid.

There are two factors that have a direct impact on the design of the 34.5 kV system post beneficial electrification. The first factor is the 25 MW consequential loss of load limitation embedded in Maine transmission and distribution planning guidelines. The second factor is the significant increase in electricity use post beneficial electrification, what we will refer to as "electricity use density". Taken together, these two factors require a redesign on the 34.5 kV system.

Consider the second factor. Currently, a typical Maine residential housing unit uses roughly 5,000 kWh per year, drives approximately 15,000 miles a year and uses the thermal equivalent of 750 gallons of heating oil for space heating. Post beneficial electrification, assuming that housing unit converts to EVs and air-source heat pumps, its electricity use will increase by approximately 4,000 kWh to power its EVs (assuming most of its charging of the EVs is done at the housing unit) plus about 10,000 kWh to replace its fossil fuel burner system. Total electricity use at the housing unit will increase from 5,000 kWh to roughly 20,000 kWh – a four-fold increase. The electricity use density at that housing unit's geospatial location has quadrupled.

This increase in electricity use density is evident across all 34.5 kV substations in the region as shown in Table 6-4. Consider the case of Freeport. In 2020, peak loads through the two transformer banks at the substation were just over 15 MVA. By 2050, they are estimated to be more than 50 MVA. This means that the current situation, where the Freeport substation is served radially out of Elm Street (See Figure 2-3), is not acceptable. By 2050, the loss of Section 104 would result in a consequent loss of load well in excess of 25 MW, not only during the peak hour, but during most hours of the year.⁴⁴

A different but equally concerning situation arises with respect to 34.5 kV substations that are fed bidirectionally in series from two upstream 115 kV substations. Today, this design provides improved reliability, since it enables all substations along this path to survive the failure of a section

⁴⁴ The same conditions apply to the Gray, Care Elizabeth, E. Deering, Rigby and Swett Road substations, as well as Hinckley Pond at the 115/12.5 kV substation.

of 34.5 kV line or an upstream transformer at one of the 115/34.5 kV substations.⁴⁵ A case in point is line 180 and its offshoot to E. Deering, line 180A. This line allows the Falmouth, E. Deering and Lambert Street substations to be fed from either Prides Corner or Elm Street. Peak loads on this line are roughly 9 MW, 10 MW and 12 MW, respectively, at 90/10 load levels, for a total of 31 MW. Assuming the transformers at each end of line 180 have enough capacity and the 34.5 kV conductors are appropriately sized along the entire route of 180, this design satisfies the 25 MW loss of load criteria. However, at estimated 2050 peak load levels of 32 MW, 38 MW and 47 MW, the current design cannot carry the loads. The total load of almost 120 MW far exceeds the capacity of any 34.5 kV conductors. The problem is that increased electricity use density makes it much more challenging to design a 34.5 kV that allows for service from different upstream 115 kV substations. Table 6-4 shows that, by 2050, no two 34.5 kV substations can be served simultaneously from two different upstream 115 kV substations along a single 34.5 kV path.

The increased electricity use density that results from beneficial electrification means that the two forms of service currently embedded in CMP's existing 34.5 kV grid in the Portland Region – radial and single-path bidirectional service – will not meet requirements. Instead, a variant of either of the two options shown in Figure 8-4 must be used.

Figure 8-4 presents two options – a Parallel Path option and a Loop Feed option – for loads in Gray and Freeport that have been assigned to take service from the Surowiec 115 kV substation. By 2050, peak loads at Gray and Freeport are estimated to be each a bit over 50 MW. We made the assumption that serving these loads in each geographic subregion will be best accomplished through two 34.5 kV substations of between 25 and 30 MW each.

The Parallel Path option, shown in the upper chart in Figure 8-4, enables each of the four 34.5 kV substations to be served from either the Surowiec or Raven Farm 115 kV substations. However, given the load requirements at each substation, this can only be accomplished by developing four parallel 34.5 kV paths – one for each substation. The second option, noted as the Loop Feed option in Figure 8-4, provides two 34.5 kV points of interconnection to a single 115 kV substation using two 34.5 kV lines. The number of interconnections within the 115 kV and 34.5 kV substations are the same for each option. The difference lies in the 34.5 kV line segments connecting each 34.5 kV substation to either one or two 115 kV substation. The preferred option

⁴⁵ The design can also provide a parallel path enabling electricity to flow to serve load in the event of an outage of an element of the 115 kV system, assuming grid component ratings are not exceeded.

from a cost perspective, therefore, depends on the relative distances between 115 substations compared to the relative distances of the substations from the single 115 kV substation.



Figure 8-4 Two Options for 34.5 kV System Design Post 2050

Table 8-5 provides an estimate of the costs (in 2020\$) required to develop the 34.5 kV subtransmission system to meet the load requirements of full beneficial electrification in the Portland Region. The top part of the table shows the calculation for the 25 new 115kV/34.5 kV substations that will need to be built, assuming each substation serves no more than about 25 MW of peak load. To estimate the costs, we have used an average of the three new 115 kV/34.5 kV substations identified in CMP's 2018 Portland Region study, escalated to 2020 dollars. The total cost for these substations is approximately \$557 million.

The bottom part of the table shows the derivation of the costs for the additional 34.5 kV lines, assuming that the average distance between each substation and its assigned 115 kV substation is 3 miles and further assuming that each of the 25 existing 115/34.5 kV substations requires only 1 new line while each new 115 kV/34.5 kV substation requires 2 new lines. Using the two examples

from the 2018 CMP Study shown in the table and escalating their costs to 2020, we calculate that total costs of new 34.5 kV lines to be \$492 million. The total costs of the 34.5 kV system are a little over \$1 billion.

		Assignment	of 34.5 kV		
		Substa			
115 kV Substations		2020	2050		
S. Portland		4	10		
S. Gorham		5	8		
Spring Street		5	10		
Solar		4	7		
Contral		4	8		
Elm Street		3	7		
Total		25	50		
New 115 kV/34.5 kV Substations			25		
Costs - New 34.5 kV Substations					
CMP 2018 Report		2018	2020		
E. Deering	million\$	\$20.00	\$21.22		
Anderson St.	million\$	\$18.00	\$19.10		
N. Yarmouth	million\$	\$25.00	\$26.52		
Average	million\$		\$22.28		
Cost of New 115 kV/34.5 kV Substations	million\$		\$556.97		
34.5 kV Lines					
Average Distance of 34.5 kV Substation	miles		3		
Fricting 24 E W/ Substations			25		
EXISTING 34.5 KV Substations	No.		25		
New 34.5 KV Substations	No.	-	<u> </u>		
TOLAI	miles		225	Cost /A	1:10
Costs - New 34.5 kV Lines				(millio	on\$)
CMP 2018 Report		Miles	Cost	2018	2020
N. Yarmouth - Freeport		11	\$22.80	\$2.07	\$2.20
N. Yarmouth - Gray		4	\$8.20	\$2.05	\$2.17
Average					\$2.19
Cost of New 34.5 kV Lines	million\$		\$492.05		
Cost of 34.5 kV System	million\$	-	\$1,049.03		

Table 8-5Estimated Costs – 34.5 kV System Post 2050

8.4 Summary

The costs of the transmission and subtransmission upgrades are summarized in Table 8-6. We estimate the total system costs for the Portland Region to be about \$2.5 billion in today's dollars.

This amount does <u>not</u> include costs related to the expansion of the distribution grid and, where feasible, the conversion of that grid from a primarily radial design to a network design capable of enabling two-way flows of electricity and providing increased reliability.

Estimated Transmission/Subtransmissio		Cost	
345 kV System	No.	Miles	(millions\$)
New 345 kV Substations	3		\$318.12
345 kV Line - Overhead		66	\$424.96
345 kV line - Undersea		18	\$231.80
Subtotal			\$974.88
115 kV System			
New 115 kV Substations	4		\$218.32
345 kV Line - Overhead		84	\$293.49
345 kV line - Undersea		1	\$8.42
Subtotal			\$520.23
34.5 kV System			
New 115 kV/34.5 kV Substations	25		\$556.97
34.5 kV Line - Overhead		225	\$492.05
34.5 kV line - Undersea		0	\$0.00
Subtotal		_	\$1,049.03
Total Transmission/Subtransmission			\$2,544.13

 Table 8-6
 Summary – Estimated Cost of Transmission/Subtransmission Upgrades - 2050

We have looked at what the land requirements for the required transmission and subtransmission system components might be based on the footprints of the various components. The results are shown in Table 8-7. We have included only the transmission line and substation components of the grid; as with the cost calculations, we have not included distribution circuits. For transmission lines, we have used representative right-of-way corridor widths and estimated segment lengths based on the new proposed design of the grid post 2050. Using these parameters, we calculated the footprint (in acres) of each line segment for each voltage.

We have done the same calculation for substations. Here, we have used the Surowiec Substation as a model for the 345 kV category, the Spring Street Substation as a model for the 115 kV category and an approximation of the size of 115 kV/34.5 kV substations. In addition, we have added set-backs or buffers for each class of substation as shown in the table.

Based on these parameters, we calculate the amount of acreage required to be 3,764 acres. To put this in perspective, we have compared this to the acreage used by the Interstates 295/95

from Freeport to the Saco border, a distance of roughly 40 miles. The footprint of this linear ribbon running the length of the Portland Region is approximately 970 acres. The land requirements for the grid build-out are almost four times those of the Interstate corridor – that is, building out the grid will require the equivalent of four new Interstate 295/95 corridors running from Freeport to the Saco border. This is the land-use equivalent of Figure 6-6, which shows graphically just how different the flows on the electric grid will be in a zero-carbon economy in 2050.

		Width	Length	Area
Transmission Lines		(ft.)	(miles)	(acres)
345 kV Lines		150	66	1,200
115 kV Lines		100	84	1,018
34.5 kV Lines		50	225	1,364
Subtotal				3,582
		Width	Length	Area
	No.	(ft.)	(ft.)	(acres)
Substations				
345 kV Lines	3	1,200	1,700	140
115 kV Lines	4	450	450	19
115 kV/34.5 kV	25	200	200	23
Subtotal				182
Total Land Area				3,764
				↑
Notes:				
Buffer Factors - Set Bac	ks for Subst	ations:		
345 kV	Feet	200		
115 kV	Feet	150		
34.5 kV	Feet	100		
Interstate 295/95	(ft.)	(miles)	(acres)	
Freeport to Scarborough	200	40	970	

Table 8-7 Land-Use Consequences of Electric Grid Build-Out

These land-use requirements can be mitigated to a degree by undergrounding transmission lines. However, this comes at a significant expense, as much as a doubling of the respective per mile costs. Alternatively, the corridors could be narrowed considerably and located above or alongside other rights-of-way such as highways, railroad lines, and streets as is done in other cities across the country, where, presumably, visual impacts and risks to health and safety are evaluated differently.
REDACTED – Public Version

In any case, the impacts on land-use in the Portland Region that will result from the buildout of the transmission and distribution grid necessary to achieve a zero-carbon economy by 2050 will be substantial – possibly on a par with those related to the building of new roads to accommodate the explosion of cars and trucks over the latter half of the 20th century. It is not too early to begin to plan for grid needs over the 30-year planning horizon between now and 2050. One very important aspect of this effort should be the setting aside by municipal governments in the region of land corridors to accommodate future transmission lines and the establishment of zoning ordinances to permit their development. In addition, we believe it is prudent for utilities to look acquire rights, title or interest in land in the region that can be put to use over the next thirty years in support of transmission grid expansions.

8.5 Concluding Thoughts

By any measure, the region's electric grid will need to become significantly larger and will require significant investments over the next 30 years. The grid design we lay out in this chapter represents one of countless designs that can meet 2050 electric loads and accommodate decarbonization of the grid. The actual design is of far less importance today than is the recognition that the region's electric grid in 2050 will look very different – of this we can be certain. And yet, decisions will have to be made about how to incrementally expand the grid, how to replace and renew grid components, how to accommodate large numbers of distributed generation systems and how to meet increasingly stringent standards for reliability and resiliency. Should these decisions be made based on current grid conditions or should they be made so as to be consistent with and support longer-term policy objectives, and if the latter, what is the appropriate planning horizon?

Addressing this question is made more difficult because of the geospatial rigidity of transmission and distribution plant – once in place, it is not easily moved, and because of its "lumpiness" – it is built out in relatively large increments rather than small units. These characteristics make such investments susceptible to being rendered uneconomic as a result of unpredicted futures. As with all capital intensive, fixed location infrastructure, building out the electric grid must be done in a balanced way with one-eye firmly focused on the longer-term requirements of electrification as a means of decarbonizing the economy and the other on the near-term requirements of reliability and resiliency.

REDACTED – Public Version

In the prior chapter, we discussed some of the guiding principles that we believe should guide electric grid planning. We turn now to illustrating how we believe these principles may be put to work in the context of CMP's proposed transmission investments in the Portland Region. Below, we consider the major components of CMP's proposed Transmission Solution 1 in its Portland Area Study to determine whether and how they may fit in to the longer-term needs of the region and the designs set forth above.

- Raven Farm 345 kV/115 kV Substation This is a key component in the 2050 design. The longer-term design includes one additional 115 kV feed. As CMP designs this new substation, we recommend that its design allow for this additional feed to be constructed at a later date.
- 2. North Yarmouth Substation This substation is not included in the 2050 design. CMP is proposing to loop feed Gray, Freeport and North Yarmouth out of both Raven Farm and Surowiec. While this configuration works at current load levels and provides improved reliability in this sub-region, we do not believe it will work as conversions to electrification occur. Instead, our 2050 design opts to loop-feed a total of four 34.5 kV substations in Gray and Freeport out of the Surowiec 115 kV substation. If CMP believes the North Yarmouth Substation to be a component of the longer-term grid design for the region, CMP should be required to make this demonstration to support its position.
- E. Deering 115 kV/34.5 kV Substation This is included in the 2050 design. The longer-term design we have laid out includes a parallel, second 115 kV feeder from Raven Farm to Central. We recommend that the design of this new substation includes allowance for this additional feeder.
- 4. Sections 262, 263N and 263S This 115 kV line connecting Raven Farm to Cape, through new E. Deering and Anderson St. substations is included in our proposed 2050 design. A second parallel 115 kV line is also included in the 2050 design, as noted in item 3. Securing a right-of-way for CMP's proposed new overhead 115 kV line will be difficult in this part of the region. Securing a second right-of-way in 20 years will be even more difficult. We recommend that any new right-of-way that is acquired be capable of supporting two parallel 115 kV lines on separate towers or a minimum allow for the undergrounding of a second line in the future.
- 5. Anderson Street Substation While this substation is not included in our 2050 design, a more robust and larger 115 kV substation "Central" is included in that design. We are skeptical that the Anderson Street location is adequate to meet the longer-term needs of the region, and if

REDACTED – Public Version

constructed, could obsolete well before the end of its useful life. Further, we are concerned that our proposed Central Substation could be a difficult substation to physically locate in Portland on the path of the parallel 115 kV feeds between Raven Farm and the new 115 kV substation at S. Portland at the Tank Farm. Given the building density in this region and the lack of openspace, CMP should look to acquire lands today that will allow it to build a major new 115 kV substation to meet future electricity requirements. This may require a new design for substations – one that is more suitable for high density urban areas, which, in turn, may require modifications to Portland's zoning ordinances and building codes.

- 6. Pleasant Hill Substation upgrade This is included in our 2050 design to accommodate parallel 115 kV feeds between the S. Gorham and S. Portland 115 kV substations. We expect this expanded substation to be a major component of the 2050 grid and recommend that CMP designs its upgrade to be able to accommodate additional 34.5 kV transformers and feeders.
- New 115 kV line from S. Gorham to Pleasant Hill This is included in our 2050 design. Our design extends this line (4070 in Figure 8-3) beyond Pleasant Hill to S. Portland.

In addition to the above items, we recommend that CMP begins the process of acquiring land for future 34.5 kV substations in the region, consistent with our discussion about loop feeding these from larger 115/34.5 kV substations. The amount of land necessary is not large and, since this land can be sold if not used for this purpose at a later date, the investment is not at risk of being stranded. The recent experiences of Emera Maine in Bar Harbor may be telling in regard to how difficult it will be to locate distributed substations in the future. Having these locations established well in advance and reflected on town planning maps could make it less difficult to secure permits for their development in the future.

Technical Appendix A Validating the Current Electricity Use Model

The model used to estimate current electricity use by building in the Portland Area relies upon three key parameters – the Energy Use Intensity or EUI for residential, commercial, and industrial square footage. As described in the body of the Report, the EUI measures were based on statewide data and national databases developed and provided by the U.S. Department of Energy for New England and/or the Northeast. By applying these EUI parameters to estimates of the square footage of each building (classified as residential, commercial or industrial), we are able to compute estimated annual electricity usage for each building in the region. We, then, apportioned this annual usage to each hour of the year using proforma Central Maine Power (CMP) load shapes for residential and commercial customers within the CMP service territory, and actual hourly use for the CMP industrial class of customers. This latter value was obtained by subtracting the residential and commercial class hourly loads from the CMP hourly RNS loads for calendar year 2017.

The next step in the model was to assign each building in the Portland Area to an existing CMP electric distribution circuit. CMP provided us with the GIS coordinates for each of its distribution circuits. We used a simple shortest distance as-the-crow-flies algorithm to assign each building to the nearest circuit. This algorithm provided an accurate assignment of most of the buildings. The exceptions were (a) where multiple circuits emerged from the same substation and tracked along the same right-of-way until they diverged and (b) in high dense areas where a building was essentially equidistant from two different circuits. In these cases, we made some manual modifications to address larger buildings but otherwise relied on the algorithm.

1

To test the accuracy of the model, we compared the model results with actual circuit load readings provided by CMP for selected circuits in the region. We chose ten circuits (three of which we aggregated into a single test case) where the CMP data was generally complete (few missing data points) and where the geographic area served by each circuit was relatively self-contained and therefore less likely to be subject to potential assignment errors. The results of our testing are shown in Figures A-1 through A-9 below. We have also provided maps of three of these circuits at the end of this Appendix to provide a visual indication of how distribution circuits are located and the nature of buildings they serve.

Figure A-1 provides the aggregate results across all eight circuit cases. Where multiple circuits originate from the same substation, we show the results for each circuit and for those circuits combined. In addition, we combined three circuits in South Portland where the close proximity of portions of these circuits to each other could create assignment problems. The table shows the number of each type of building served by the circuit and the annual electricity loads as measured by CMP and as estimated by GridSolar. These circuits represent about 20% of all residential, 14% of commercial and 17% of industrial buildings in the region and about 14% of total loads. On balance, across all of the circuits, our total estimated load is very close to the CMP measured load.¹

The largest differences between CMP measured loads and our estimated loads occur on circuits with more industrial buildings. This reflects the wide variability in electricity use per square foot in industrial structures, depending on what is being produced in those buildings. Using a single

¹ A small difference between the CMP measured loads and our estimated loads is the point of measurement. We understand that CMP records circuit load flows at the low-side of the substation transformer. Our estimate is based on EUIs that are reflective of loads at the building meter, which includes a small loss factor through the primary/secondary transformer that serves the customer.

EUI for this class of buildings misses this variability. On the other hand, as noted in the body of the Report, the variability is tied to current building use, which may not be the best indicator of building use over the next 30 years.

		I	Buildings		Ele	ectricity Load	s
Substation	Circuit	Resid. (No.)	Comm. (No.)	Ind. (No.)	CMP (MWh)	GridSolar (MWh)	Pct. Diff. (Pct.)
Swett Road	682D2	1,474	185	0	24,629	25,715	4.41%
Swett Road	682D1	2,486	7	0	19,351	22,226	14.86%
Subtotal		3,960	192	0	43,980	47,941	9.01%
Westbrook	674D1	1,322	145	30	28,206	35,012	24.13%
Westbrook	674D2	839	27	18	22,209	12,000	-45.97%
Subtotal	_	2,161	172	48	50,415	47,012	-6.75%
Freeport	255D3	2,489	100	6	31,719	30,260	-4.60%
Lambert Street	631D2	1,608	84	0	27,273	28,377	4.05%
Lambert Street	631D3	1,684	73	1	21,992	21,848	-0.65%
Subtotal	*	3,292	157	1	49,265	50,225	1.95%
So. Portland	650D1,D3,D4	3,025	219	119	65,168	55,408	-14.98%
Totals		14,927	840	174	240,547	230,846	-4.03%

Figure A - 1	Comparison	of Model to	CMP Loads -	- All Selected	Circuits
--------------	------------	-------------	-------------	----------------	----------

A second source of error relates to the assignment of buildings to circuits. This is a bigger problem in some instances than in others. For example, the differences between CMP measured loads and our estimates of loads for the two circuits emanating from the Lambert Street substation are very small, indicating minimal assignment error. In contrast, the errors are much larger for the Westbrook substation circuits and in opposite directions reflecting an assignment problem. Specifically, the circuit 674D1 is estimated by GridSolar (GS) on the high-end (GS = 35,012 MWh and CMP = 28,206 MWh), while circuit 674D2 is estimated on the low-end (GS = 12,200 MWh and CMP = 22,209 MWh). These two circuits physically overlap one another in the spatial data provided by CMP, making the assignment of buildings to one circuit versus the other difficult using shortest distance type algorithms. Accordingly, it is likely that some buildings have been assigned incorrectly. Combing the two circuits confirms this, as the GS combined load = 47,211 MWh and CMP = 50,415 MWh (difference of 3,204 or 6.36%).

Figures A-2 through A-9 provide further details with respect to each of the circuits and a more detailed comparison between the CMP measured loads and our estimated loads. In addition to the number of buildings by class on each circuit, we provide the total square footage for those buildings, the EUI by building class (3.35 kWh/year/sq.ft. for residential buildings and 11.00 and 12.00 kWh/year/sq.ft. for commercial and industrial buildings, respectively), and total electricity use by building class. In addition, we show estimated heating and process energy requirements for the different buildings by class on the circuit. This information is not used in the model validation, as it represents the use of other fuels in these buildings. We use this information in other components of our analysis where, through beneficial electrification, this fuel use is discontinued and replaced by the use of electricity.

We also show a correction factor for current energy use based on modifications to the total square footage of residential, commercial, and industrial buildings of 95%, 87%, and 99%, respectively. As discussed in the body of the Report, these correction factors are based on a comparison between the modeled square footage and the actual square footage from visual examinations of a sample of buildings of each type. We manually created real-world measurements and story counts from Google Street view and aerial imagery of a sample of 25 randomly selected structures for each building type.

The two graphs in each of the figures for each of the distribution circuits compare the CMP measured loads with our estimated loads by calendar month and by hour of the day over the course of the year. As would be expected, the differences between CMP measured loads and our model loads increase as the unit of observation becomes smaller. There is much higher variability at the

building level, less variability at the circuit level, even less variability at the substation level, and only very small differences at the level of aggregation of these eight circuit cases. As shown in Figure A-1, the overall accuracy of the modeling in aggregate across all circuits and all hours is 96%.

Figure A - 2 Comparison of Model to CMP Loads – Circuits 650D1, 650D3 and 650D4

Case Study Area

Circuit(s) 650D1, 650D3, and 650D4 Filename and Version Number: Circuit_650D1_650D3_and_650D4_Case_Study_V7_20200106

	Residential Buildings	Commercial Buildings	Industrial Buildings	Total
Number of Buildings	3,025	219	119	3,363
Total Square Footage	5,368,693	1,943,785	1,659,187	8,971,664
Average Square Footage per Building	1,775	8,876	13,943	24,593
Percentage of Square Footage	59.84%	21.67%	18.49%	100%
Electricity (kWh) per sqft Annually	3.35	11.00	12.00	
Electricity (MWh) Consumption	17,995	21,382	19,910	59,286
Percentage of Consumption	30.35%	36.06%	33.58%	100%
Heat (BTU) per sqft Annually	36,000	36,000	36,000	
Heat (Million BTU) Consumption	193,273	69,976	59,731	322,980
Percentage of Consumption	59.84%	21.67%	18.49%	100%
Process (BTU) per sqft Annually	N/A	10,000	10,000	
Process (Million BTU) Consumption	N/A	19,438	16,592	36,030
Percentage of Consumption	N/A	53.95%	46.05%	100%
Factoring sqft Accuracy (percentage)	95	87	99	
Estimated Annual MWh Consumption	17,095	18,602	19,711	55,408
Difference	-900	-2,780	-199	3,878
Electricity (MWh) Annually	CMP (Real-World)	GridSolar (Initial Prediction)	GridSolar (Factoring sqft Error)	
Electricity (MWh) Consumption	65,168	59,286	55,408	

N/A

N/A

5,881

90.97%

9,760

85.02%

Accuracy

Difference



Figure A - 3 Comparison of Model to CMP Loads – Circuit 225D3

Case Study Area Circuit(s) 225D3

Filename and Version Number: Circuit_225D3_Case_Study_V2_20200106

Substation: FREEPORT

	Residential Buildings	Commercial Buildings	Industrial Buildings	Total
Number of Buildings	2,489	100	6	2,595
Total Square Footage	7,176,028	751,444	18,429	7,945,902
Average Square Footage per Building	2,883	7,514	3,072	13,469
Percentage of Square Footage	90.31%	9.46%	0.23%	100%
Electricity (kWh) per sqft Annually	3.35	11.00	12.00	
Electricity (MWh) Consumption	24,052	8,266	221	32,539
Percentage of Consumption	73.92%	25.40%	0.68%	100%
Heat (BTU) per sqft Annually	36,000	36,000	36,000	
Heat (Million BTU) Consumption	258,337	27,052	663	286,052
Percentage of Consumption	90.31%	9.46%	0.23%	100%
Process (BTU) per sqft Annually	N/A	10,000	10,000	
Process (Million BTU) Consumption	N/A	7,514	184	7,699
Percentage of Consumption	N/A	97.61%	2.39%	100%
Factoring sqft Accuracy (percentage)	95	87	99	
Estimated Annual MWh Consumption	22,850	7,191	219	30,260
Difference	-1,203	-1,075	-2	2,279
Electricity (MWh) Annually	CMP (Real-World)	GridSolar (Initial Prediction)	GridSolar (Factoring sqft Error)	

Electricity (MWh) Consumption	31,719	32,539	30,260
Difference	N/A	-820	1,459
Accuracy	N/A	97.48%	95.40%





Figure A - 4 Comparison of Model to CMP Loads – Circuit 631D2

Case Study Area Circuit(s) 631D2

Filename and Version Number: Circuit_631D2_Case_Study_V2_20200106

Substation: LAMBERT STREET

	Residential Buildings	Commercial Buildings	Industrial Buildings	Total
Number of Buildings	1,608	84	0	1,692
Total Square Footage	5,865,517	1,013,625	0	6,879,142
Average Square Footage per Building	3,648	12,067	#DIV/0!	#DIV/0!
Percentage of Square Footage	85.27%	14.73%	0.00%	100%
Electricity (kWh) per sqft Annually	3.35	11.00	12.00	
Electricity (MWh) Consumption	19,660	11,150	0	30,810
Percentage of Consumption	63.81%	36.19%	0.00%	100%
Heat (BTU) per sqft Annually	36,000	36,000	36,000	
Heat (Million BTU) Consumption	211,159	36,490	0	247,649
Percentage of Consumption	85.27%	14.73%	0.00%	100%
Process (BTU) per sqft Annually	N/A	10,000	10,000	
Process (Million BTU) Consumption	N/A	10,136	0	10,136
Percentage of Consumption	N/A	100.00%	0.00%	100%
Factoring sqft Accuracy (percentage)	95	87	99	
Estimated Annual MWh Consumption	18,677	9,700	0	28,377
Difference	-983	-1,449	0	2,432
Electricity (MWh) Annually	CMP (Real-World)	GridSolar (Initial Prediction)	GridSolar (Factoring sqft Error)	

Electricity (MWh) Consumption	27,273	30,810	28,377
Difference	N/A	-3,537	-1,105
Accuracy	N/A	88.52%	96.11%





Figure A - 5 Comparison of Model to CMP Loads – Circuit 631D3

Case Study Area Circuit(s) 631D3

Filename and Version Number: Circuit_631D3_Case_Study_V7_20200106

	Residential Buildings	Commercial Buildings	Industrial Buildings	Total
Number of Buildings	1,684	73	1	1,758
Total Square Footage	4,871,330	649,185	10,409	5,530,924
Average Square Footage per Building	2,893	8,893	10,409	22,194
Percentage of Square Footage	88.07%	11.74%	0.19%	100%
Electricity (kWh) per sqft Annually	3.35	11.00	12.00	
Electricity (MWh) Consumption	16,328	7,141	125	23,594
Percentage of Consumption	69.20%	30.27%	0.53%	100%
Heat (BTU) per sqft Annually	36,000	36,000	36,000	
Heat (Million BTU) Consumption	175,368	23,371	375	199,113
Percentage of Consumption	88.07%	11.74%	0.19%	100%
Process (BTU) per sqft Annually	N/A	10,000	10,000	
Process (Million BTU) Consumption	N/A	6,492	104	6,596
Percentage of Consumption	N/A	98.42%	1.58%	100%
Factoring sqft Accuracy (percentage)	95	87	99	
Estimated Annual MWh Consumption	15,511	6,213	124	21,848
Difference	-816	-928	-1	1,746
Electricity (MWh) Annually	CMP (Real-World)	GridSolar (Initial Prediction)	GridSolar (Factoring sqft Error)	

Electricity (MWh) Consumption	21,992	23,594	21,848
Difference	N/A	-1,602	144
Accuracy	N/A	93.21%	99.34%





Figure A - 6 Comparison of Model to CMP Loads – Circuit 674D1

Case Study Area Circuit(s) 674D1

Filename and Version Number: Circuit_674D1_Case_Study_V2_20200106

Substation: WESTBROOK

	Residential Buildings	Commercial Buildings	Industrial Buildings	Total
Number of Buildings	1,322	145	30	1,497
Total Square Footage	3,252,018	1,029,206	1,246,381	5,527,605
Average Square Footage per Building	2,460	7,098	41,546	51,104
Percentage of Square Footage	58.83%	18.62%	22.55%	100%
Electricity (kWh) per sqft Annually	3.35	11.00	12.00	
Electricity (MWh) Consumption	10,900	11,321	14,957	37,178
Percentage of Consumption	29.32%	30.45%	40.23%	100%
Heat (BTU) per sqft Annually	36,000	36,000	36,000	
Heat (Million BTU) Consumption	117,073	37,051	44,870	198,994
Percentage of Consumption	58.83%	18.62%	22.55%	100%
Process (BTU) per sqft Annually	N/A	10,000	10,000	
Process (Million BTU) Consumption	N/A	10,292	12,464	22,756
Percentage of Consumption	N/A	45.23%	54.77%	100%
Factoring sqft Accuracy (percentage)	95	87	99	
Estimated Annual MWh Consumption	10,355	9,850	14,807	35,012
Difference	-545	-1,472	-150	2,166
Electricity (MWh) Annually	CMP (Real-World)	GridSolar (Initial Prediction)	GridSolar (Factoring sqft Error)	

Electricity (MWh) Consumption	28,206	37,178	35,012
Difference	N/A	-8,972	-6,806
Accuracy	N/A	75.87%	80.56%





Figure A - 7 Comparison of Model to CMP Loads – Circuit 674D2

Case Study Area Circuit(s) 674D2

Filename and Version Number: Circuit_674D2_Case_Study_V2_20200106

Substation: WESTBROOK

	Residential Buildings	Commercial Buildings	Industrial Buildings	Total
Number of Buildings	839	27	18	884
Total Square Footage	1,538,507	147,076	496,081	2,181,664
Average Square Footage per Building	1,834	5,447	27,560	34,841
Percentage of Square Footage	70.52%	6.74%	22.74%	100%
Electricity (kWh) per sqft Annually	3.35	11.00	12.00	
Electricity (MWh) Consumption	5,157	1,618	5,953	12,728
Percentage of Consumption	40.52%	12.71%	46.77%	100%
Heat (BTU) per sqft Annually	36,000	36,000	36,000	
Heat (Million BTU) Consumption	55,386	5,295	17,859	78,540
Percentage of Consumption	70.52%	6.74%	22.74%	100%
Process (BTU) per sqft Annually	N/A	10,000	10,000	
Process (Million BTU) Consumption	N/A	1,471	4,961	6,432
Percentage of Consumption	N/A	22.87%	77.13%	100%
Factoring sqft Accuracy (percentage)	95	87	99	
Estimated Annual MWh Consumption	4,899	1,408	5,893	12,200
Difference	-258	-210	-60	528
Electricity (MWh) Annually	CMP (Real-World)	GridSolar (Initial Prediction)	GridSolar (Factoring sqft Error)	

Electricity (MWh) Consumption	22,209	12,728	12,200
Difference	N/A	9,482	10,010
Accuracy	N/A	57.31%	54.93%





Figure A - 8 Comparison of Model to CMP Loads – Circuit 682D1

Case Study Area Circuit(s) 682D1

Filename and Version Number: Circuit_682D1_Case_Study_V2_20200106

Substation: SWETT ROAD

	Residential Buildings	Commercial Buildings	Industrial Buildings	Total	
Number of Buildings	2,486	7	0	2,493	
Total Square Footage	6,816,608	54,398	0	6,871,006	
Average Square Footage per Building	2,742	7,771	#DIV/0!	#DIV/0!	
Percentage of Square Footage	99.21%	0.79%	0.00%	100%	
Electricity (kWh) per sqft Annually	3.35	11.00	12.00		
Electricity (MWh) Consumption	22,848	598	0	23,446	
Percentage of Consumption	97.45%	2.55%	0.00%	100%	
Heat (BTU) per sqft Annually	36,000	36,000	36,000		
Heat (Million BTU) Consumption	245,398	1,958	0	247,356	
Percentage of Consumption	99.21%	0.79%	0.00%	100%	
Process (BTU) per sqft Annually	N/A	10,000	10,000		
Process (Million BTU) Consumption	N/A	544	0	544	
Percentage of Consumption	N/A	100.00%	0.00%	100%	
Factoring sqft Accuracy (percentage)	95	87	99		
Estimated Annual MWh Consumption	21,705	521	0	22,226	
Difference	-1,142	-78	0	1,220	
Electricity (MWh) Annually	CMP (Real-World)	GridSolar (Initial Prediction)	GridSolar (Factoring soft Error)		

Electricity (MWh) Consumption	19,351	23,446	22,226
Difference	N/A	-4,095	-2,875
Accuracy	N/A	82.53%	87.06%





Figure A - 9 Comparison of Model to CMP Loads – Circuit 682D2

Case Study Area

Circuit(s) 682D2

Filename and Version Number: Circuit_682D2_Case_Study_V2_20200106

Substation: SWETT ROAD

	Residential Buildings	Commercial Buildings	Industrial Buildings	Total
Number of Buildings	1,474	185	0	1,659
Total Square Footage	4,137,562	1,310,395	0	5,447,957
Average Square Footage per Building	2,807	7,083	#DIV/0!	#DIV/0!
Percentage of Square Footage	75.95%	24.05%	0.00%	100%
Electricity (kWh) per sqft Annually	3.35	11.00	12.00	
Electricity (MWh) Consumption	13,868	14,414	0	28,282
Percentage of Consumption	49.03%	50.97%	0.00%	100%
Heat (BTU) per sqft Annually	36,000	36,000	36,000	
Heat (Million BTU) Consumption	148,952	47,174	0	196,126
Percentage of Consumption	75.95%	24.05%	0.00%	100%
Process (BTU) per sqft Annually	N/A	10,000	10,000	
Process (Million BTU) Consumption	N/A	13,104	0	13,104
Percentage of Consumption	N/A	100.00%	0.00%	100%
Factoring sqft Accuracy (percentage)	95	87	99	
Estimated Annual MWh Consumption	13,175	12,540	0	25,715
Difference	-693	-1,874	0	2,567

			GridSolar (Factoring sqft	
Electricity (MWh) Annually	CMP (Measured)	GridSolar (Initial Prediction)	Error)	
Electricity (MWh) Consumption	24,629	28,282	25,715	
Difference	N/A	-3,653	-1,086	
Accuracy	N/A	87.08%	95.78%	





Figure A - 10 Location of Portland Circuit 631D3



Figure A - 11 Portland Circuit- 618D3



Figure A - 12 South Portland Circuits – 650D1, 650D3 and 650D4

Technical Appendix B

Energy Use by Municipality

Technical Appendix B presents energy use by type of fuel for 2020, 2030, 2040 and 2050 for each of the twenty-three municipalities that lie wholly or partially in the Portland Region in the same format as Table 4-2 in the main body of the Report.¹ In addition, we provide a summary table for total energy use across all municipalities. We are providing this information, because we think it may be of interest to the municipalities in the region as a guide for their efforts to reduce carbon emissions.

We note that the totals in this table are different from those in Table 4-2. The reason for this is that Table 4-2 includes only those buildings in each municipality that are within the Portland Area electrical region.² Because buildings not included in the Portland Area electrical region were omitted from energy totals in Table 4-2, the current electricity usage as well as energy used for transportation and heating that is associated with these buildings is not included in the Table 4-2 totals. For many of the municipalities, there are no or very few omitted buildings. For others on the edge of the electrical region, such as Brunswick, Buxton, Saco, Durham and Raymond, much or most of the buildings in the municipality are omitted. Therefore, the totals shown in the table in this Appendix B represent energy use and emissions from such use for all of the twenty-three municipalities.

¹ The models used to estimate energy use for residential and commercial buildings do not differentiate between those buildings used year-round and those only used seasonally. As a result, the energy estimates for the island communities of Long Island and Chebeague Island are likely overstated. There are so few such buildings, however, that this has essentially no impact on total energy use in the region.

² By comparison, the total number of residential, commercial and industrial buildings across all 23 municipalities is 107,464, 8,123 and 1,176, respectively, compared to 73,000, 6,167 and 1,008 in the Portland Area electric region.

Energy Use Table			Portland Area				
				All Munici	palities		
Class / End-Use							
Residential		Share	2020	2030	2040	2050	
Electricity	MWh		1,004,471	1,023,670	1,510,949	2,505,757	
Heating	mmbtu		14,984,190	14,809,100	9,920,974		
Natural Gas	mmbtu	10%	2,998,508	2,962,155	1,969,487		
Heating Oil	mmbtu	90%	11,985,682	11,812,021	7,549,885		
Commercial							
Electricity	MWh		949,332	961,781	1,135,261	1,557,120	
Heating	mmbtu		3,106,903	3,072,727	2,081,625		
Natural Gas	mmbtu	20%	1,308,934	1,294,536	876,986		
Heating Oil	mmbtu	80%	1,797,969	1,778,191	1,204,639		
Process	mmbtu		863,029	863,029	854,398		
Natural Gas	mmbtu	20%	373,064	373,064	369,334		
Heating Oil	mmbtu	80%	489,964	489,964	485,065		
Industrial							
Electricity	MWh		263,542	267,467	324,654	878,235	
Heating	mmbtu		790,626	781,929	529,719		
Natural Gas	mmbtu	30%	501,230	495,717	335,824		
Heating Oil	mmbtu	70%	289,395	286,212	193,895		
Process	mmbtu		2,196,182	2,196,182	2,174,221		
Natural Gas	mmbtu	30%	1,392,306	1,392,306	1,378,383		
Heating Oil	mmbtu	70%	803,876	803,876	795,838		
Transportation							
Passenger Vehicles							
Gasoline	mmbtu		12,096,844	11,492,002	5,201,643	0	
Electricity	MWh		0	34,905	397,916	698,098	
Commercial Trucks							
Gasoline	mmbtu		3,670,361	3,512,535	1,761,773	0	
Electricity	MWh		0	2,393	28,942	55,659	
Dunga							
Discol	1.		260.022	240 451	120 466	0	
Electricity	mmbtu		200,932	1 267	150,400	21.066	
Electricity	MWh		0	1,307	15,555	31,000	
Heavy-Duty Trucks							
Diesel	mmbtu		958,461	917,248	460,061	0	
Electricity	MWh		0	3,153	38,131	73,329	
Totals							
Electricity	MWh		2,217,344	2,322,921	3,773,964	6,368,878	
Natural Gas	mmbtu		6,574,043	6,521,147	4,969,527	0	
Heating Oil	mmbtu		15,366,888	15,212,084	10,709,844	0	
Gasoline	mmbtu		15,767,205	15,004,537	6,963,416	0	
Diesel	mmbtu		1,219,394	1,166,699	590,528	0	
Total Energy Use	mmbtu	-	46,495,325	45,832,597	36,113,852	21,736,979	
Total CO2 Emissions	tons		3,511,839	3,284,347	2,124,422	0	

Table B - 1 Total Energy Use and Emissions – All Municipalities

Table B - 2	Total Energy	Use and	Emissions -	Brunswick
-------------	--------------	---------	-------------	-----------

Energy Use Table		City of				
				Brunswi	ick	
Class / End-Use						
Residential		Share	2020	2030	2040	2050
Electricity	MWh		62,663	65,619	114,354	191,728
Heating	mmbtu		934,775	924,492	626,299	0
Natural Gas	mmbtu	10%	93,477	92,449	62,630	0
Heating Oil	mmbtu	90%	841,297	832,043	563,669	0
Commercial						
Electricity	MWh		87,177	88,027	100,858	136,799
Heating	mmbtu		285,307	282,168	191,156	0
Natural Gas	mmbtu	20%	57,061	56,434	38,231	0
Heating Oil	mmbtu	80%	228,245	225,735	152,924	0
Process	mmbtu		79,252	79,252	78,459	0
Natural Gas	mmbtu	20%	15,850	15,850	15,692	0
Heating Oil	mmbtu	80%	63,402	63,402	62,768	0
Industrial						
Electricity	MWh		15,513	15,741	19.061	51.562
Heating	mmbtu		46.538	46.026	31.180	0
Natural Gas	mmbtu	30%	13,961	13 808	9 354	0
Heating Oil	mmbtu	70%	32,576	32,218	21.826	0
Process	mmbtu	1070	129.271	129.271	127.978	0
Natural Gas	mmbtu	30%	38,781	38 781	38 394	0
Heating Oil	mmbtu	70%	90,490	90,490	89,585	0
Transportation						
Passenger Vehicles						
Gasoline	mmbtu		775.690	736,906	333,547	0
Electricity	MWh		0	2,238	25,516	44,764
Commercial Trucks						
Gasoline	mmbtu		154.342	147,705	74.084	0
Electricity	MWh		0	101	1,217	2,340
Buses						
Diesel	mmbtu		17,310	16,548	8,655	0
Electricity	MWh		0	91	1,030	2,061
Heavy-Duty Trucks						
Diesel	mmbtu		52,571	50,311	25,234	0
Electricity	MWh		0	173	2,091	4,022
Totals						
Electricity	MWh		165,353	171,989	264,128	433,276
Natural Gas	mmbtu		219,132	217,322	164,300	0
Heating Oil	mmbtu		1,256,010	1,243,887	890,772	0
Gasoline	mmbtu		930,032	884,611	407,631	0
Diesel	mmbtu		69,881	66,859	33,889	0
Total Energy Use	mmbtu		3,039,404	2,999,677	2,398,061	1,478,773
Total CO2 Emissions	tons	-	233,899	217.768	142.459	0

Energy Use Table				City of	•	
				Buxtor	L	
Class / End-Use						
Residential		Share	2020	2030	2040	2050
Electricity	MWh		28,683	29,817	49,859	83,410
Heating	mmbtu		427,872	423,165	286,674	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	427,872	423,165	286,674	0
Commercial						
Electricity	MWh		9,929	10,132	12,712	17,752
Heating	mmbtu		32,494	32,137	21,771	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	32,494	32,137	21,771	0
Process	mmbtu		9,026	9,026	8,936	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	9,026	9,026	8,936	0
Industrial						
Electricity	MWh		1,041	1,109	1,903	4,597
Heating	mmbtu		3,122	3,087	2,091	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	3,122	3,087	2,091	0
Process	mmbtu		8,671	8,671	8,584	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	8,671	8,671	8,584	0
Transportation						
Passenger Vehicles						
Gasoline	mmbtu		252,752	240,114	108,683	0
Electricity	MWh		0	729	8,314	14,586
Commercial Trucks						
Gasoline	mmbtu		78,270	74,904	37,570	0
Electricity	MWh		0	51	617	1,187
Buses						
Diesel	mmbtu		0	0	0	0
Electricity	MWh		0	0	0	0
Heavy-Duty Trucks						
Diesel	mmbtu		16,028	15,339	7,693	0
Electricity	MWh		0	53	638	1,226
Totals						
Electricity	MWh		39,652	41,891	74,043	122,758
Natural Gas	mmbtu		. 0	. 0	0	. 0
Heating Oil	mmbtu		481,185	476,087	328,057	0
Gasoline	mmbtu		331,022	315,019	146,253	0
Diesel	mmbtu		16,028	15,339	7,693	0
Total Energy Use	mmbtu		963,567	949,420	734,714	418,973
Total CO2 Emissions	tons	—	75,924	71,620	45,913	0

Table B - 3Total Energy Use and Emissions – Buxton

Energy Use Table			City of Cape Elizabeth			
Class / End-Use						
Residential		Share	2020	2030	2040	2050
Electricity	MWh		38,236	39,851	67,619	113,175
Heating	mmbtu		570,392	564,118	382,163	0
Natural Gas	mmbtu	10%	57,039	56,412	38,216	0
Heating Oil	mmbtu	90%	513,353	507,706	343,946	0
Commercial						
Electricity	MWh		9,813	10,125	13,827	19,860
Heating	mmbtu		32,117	31,763	21,518	0
Natural Gas	mmbtu	20%	6,423	6,353	4,304	0
Heating Oil	mmbtu	80%	25,693	25,411	17,215	0
Process	mmbtu		8,921	8,921	8,832	0
Natural Gas	mmbtu	20%	1,784	1,784	1,766	0
Heating Oil	mmbtu	80%	7,137	7,137	7,066	0
Industrial						
Electricity	MWh		0	0	0	0
Heating	mmbtu		0	0	0	0
Natural Gas	mmbtu	30%	0	0	0	0
Heating Oil	mmbtu	70%	0	0	0	0
Process	mmbtu		0	0	0	0
Natural Gas	mmbtu	30%	0	0	0	0
Heating Oil	mmbtu	70%	0	0	0	0
Transportation						
Passenger Vehicles						
Gasoline	mmbtu		370,792	352,253	159,441	0
Electricity	MWh		0	1,070	12,197	21,398
Commercial Trucks						
Gasoline	mmbtu		62,962	60,255	30,222	0
Electricity	MWh		0	41	496	955
Buses						
Diesel	mmbtu		8,334	7,968	4,167	0
Electricity	MWh		0	44	496	992
Heavy-Duty Trucks						
Diesel	mmbtu		5,770	5,522	2,770	0
Electricity	MWh		0	19	230	441
Totals						
Electricity	MWh		48,050	51,150	94,866	156,822
Natural Gas	mmbtu		65.247	64.549	44.286	0
Heating Oil	mmbtu		546,183	540,254	368.227	0
Gasoline	mmbtu		433,755	412,508	189,663	0
Diesel	mmbtu		14,104	13,490	6,937	0
Total Energy Use	mmbtu		1,223,283	1,205,376	932,888	535,233
Total CO2 Emissions	tons	_	94,982	89,686	57,166	0

Table B - 4 Total Energy Use and Emissions – Cape Elizabeth

Energy Use Table				City of		
0,				Chebeague I	sland	
Class / End-Use				0		
Residential		Share	2020	2030	2040	2050
Electricity	MWh		3,693	3,804	6,021	10,032
Heating	mmbtu		55,083	54,477	36,906	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	55,083	54,477	36,906	0
Commercial						
Electricity	MWh		524	538	708	1,004
Heating	mmbtu		1,713	1,695	1,148	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	1,713	1,695	1,148	0
Process	mmbtu		476	476	471	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	476	476	471	0
Industrial						
Electricity	MWh		0	0	0	0
Heating	mmbtu		0	0	0	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	0	0	0	0
Process	mmbtu		0	0	0	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	0	0	0	0
Transportation						
Passenger Vehicles						
Gasoline	mmbtu		17,391	16,522	7,478	0
Electricity	MWh		0	50	572	1,004
Commercial Trucks						
Gasoline	mmbtu		2,082	1,992	999	0
Electricity	MWh		0	1	16	32
Buses						
Diesel	mmbtu		0	0	0	0
Electricity	MWh		0	0	0	0
Heavy-Duty Trucks						
Diesel	mmbtu		641	614	308	0
Electricity	MWh		0	2	26	49
Totals						
Electricity	MWh		4,216	4,395	7,343	12,120
Natural Gas	mmbtu		0	0	0	0
Heating Oil	mmbtu		57,273	56,648	38,525	0
Gasoline	mmbtu		19,473	18,514	8,478	0
Diesel	mmbtu		641	614	308	0
Total Energy Use	mmbtu		91,777	90,776	72,373	41,364
Total CO2 Emissions	tons	_	7,245	6,832	4,526	0

Table B - 5Total Energy Use and Emissions – Chebeague Island

Table B - 6Total Energy Use and Emissions – Cumberland

Energy Use Table				City of		
				Cumberla	ind	
Class / End-Use						
Residential		Share	2020	2030	2040	2050
Electricity	MWh		35,246	36,725	62,228	104,155
Heating	mmbtu		525,776	519,992	352,270	0
Natural Gas	mmbtu	10%	52,578	51,999	35,227	0
Heating Oil	mmbtu	90%	473,198	467,993	317,043	0
Commercial						
Electricity	MWh		10,948	11,269	15,106	21,657
Heating	mmbtu		35,831	35,437	24,007	0
Natural Gas	mmbtu	20%	7,166	7,087	4,801	0
Heating Oil	mmbtu	80%	28,665	28,350	19,206	0
Process	mmbtu		9,953	9,953	9,854	0
Natural Gas	mmbtu	20%	1,991	1,991	1,971	0
Heating Oil	mmbtu	80%	7,963	7,963	7,883	0
Industrial						
Electricity	MWh		1,493	1,579	2,577	6,304
Heating	mmbtu		4,478	4,429	3,000	0
Natural Gas	mmbtu	30%	1,343	1,329	900	0
Heating Oil	mmbtu	70%	3,135	3,100	2,100	0
Process	mmbtu		12,439	12,439	12,314	0
Natural Gas	mmbtu	30%	3,732	3,732	3,694	0
Heating Oil	mmbtu	70%	8,707	8,707	8,620	0
Transportation						
Passenger Vehicles						
Gasoline	mmbtu		355,100	337,345	152,693	0
Electricity	MWh		0	1,025	11,681	20,492
Commercial Trucks						
Gasoline	mmbtu		72,682	69,557	34,887	0
Electricity	MWh		0	47	573	1,102
Buses						
Diesel	mmbtu		15.387	14.710	7.693	0
Electricity	MWh		0	81	916	1,832
Heavy-Duty Trucks						
Diesel	mmbtu		9,617	9,203	4,616	0
Electricity	MWh		0	32	383	736
Totals						
Electricity	MWh		47.687	50.757	93.464	156.279
Natural Gas	mmbtu		66.809	66.138	46.593	0
Heating Oil	mmhtu		521.667	516.112	354.851	0
Gasoline	mmbtu		427.782	406.902	187.580	0
Diesel	mmbtu		25,003	23,913	12,309	0
Total Energy Use	mmbtu		1,204,017	1,186,298	920,327	533,380
Total CO2 Emissions	tons		93,418	88,165	56,354	0

Energy Use Table			City of Durham				
Class / End-Use							
Residential		Share	2020	2030	2040	2050	
Electricity	MWh		15,664	16,394	28,491	47,777	
Heating	mmbtu		233,670	231,099	156,559	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	233,670	231,099	156,559	0	
Commercial							
Electricity	MWh		5,606	5,781	7,880	11,339	
Heating	mmbtu		18,347	18,146	12,293	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	18,347	18,146	12,293	0	
Process	mmbtu		5,097	5,097	5,046	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	5,097	5,097	5,046	0	
Industrial							
Electricity	MWh		338	381	858	1,922	
Heating	mmbtu		1,014	1,003	679	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	1,014	1,003	679	0	
Process	mmbtu		2,816	2,816	2,788	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	2,816	2,816	2,788	0	
Transportation							
Passenger Vehicles							
Gasoline	mmbtu		186,437	177,116	80,168	0	
Electricity	MWh		0	538	6,133	10,759	
Commercial Trucks							
Gasoline	mmbtu		53,905	51,587	25,874	0	
Electricity	MWh		0	35	425	817	
Buses							
Diesel	mmbtu		2,564	2,452	1,282	0	
Electricity	MWh		0	13	153	305	
Heavy-Duty Trucks							
Diesel	mmbtu		14,746	14,112	7,078	0	
Electricity	MWh		0	49	587	1,128	
Totals							
Electricity	MWh		21,608	23,191	44,527	74,049	
Natural Gas	mmbtu		0	0	0	0	
Heating Oil	mmbtu		260,943	258,160	177,364	0	
Gasoline	mmbtu		240,343	228,703	106,043	0	
Diesel	mmbtu		17,310	16,563	8,360	0	
Total Energy Use	mmbtu		592,344	582,578	443,737	252,729	
Total CO2 Emissions	tons		46,668	44,127	27,728	0	

Table B - 7Total Energy Use and Emissions – Durham

Energy Use Table	City of					
			Falmou	Falmouth		
Class / End-Use						
Residential		Share	2020	2030	2040	2050
Electricity	MWh		54,732	57,019	96,524	161,605
Heating	mmbtu		816,471	807,489	547,035	0
Natural Gas	mmbtu	10%	81,647	80,749	54,704	0
Heating Oil	mmbtu	90%	734,823	726,740	492,332	0
Commercial						
Electricity	MWh		27,824	28,299	34,511	47,857
Heating	mmbtu		91,060	90,058	61,010	0
Natural Gas	mmbtu	20%	18,212	18,012	12,202	0
Heating Oil	mmbtu	80%	72,848	72,046	48,808	0
Process	mmbtu		25,294	25,294	25,041	0
Natural Gas	mmbtu	20%	5,059	5,059	5,008	0
Heating Oil	mmbtu	80%	20,235	20,235	20,033	0
Industrial						
Electricity	MWh		0	0	0	0
Heating	mmbtu		0	0	0	0
Natural Gas	mmbtu	30%	0	0	0	0
Heating Oil	mmbtu	70%	0	0	0	0
Process	mmbtu		0	0	0	0
Natural Gas	mmbtu	30%	0	0	0	0
Heating Oil	mmbtu	70%	0	0	0	0
Transportation						
Passenger Vehicles						
Gasoline	mmbtu		504,266	479,053	216,835	0
Electricity	MWh		0	1,455	16,587	29,101
Commercial Trucks						
Gasoline	mmbtu		158,079	151,282	75,878	0
Electricity	MWh		0	103	1,247	2,397
Buses						
Diesel	mmbtu		14,104	13,484	7,052	0
Electricity	MWh		0	74	840	1,679
Heavy-Duty Trucks						
Diesel	mmbtu		5,770	5,522	2,770	0
Electricity	MWh		0	19	230	441
Totals						
Electricity	MWh		82,556	86,968	149,938	243,081
Natural Gas	mmbtu		104,918	103,819	71,914	0
Heating Oil	mmbtu		827,907	819,022	561,173	0
Gasoline	mmbtu		662,346	630,335	292,713	0
Diesel	mmbtu		19,874	19,006	9,822	0
Total Energy Use	mmbtu		1,896,809	1,869,006	1,447,360	829,636
Total CO2 Emissions	tons		147,017	138,235	88,144	0

Table B - 8 Total Energy Use and Emissions – Falmouth

Energy Use Table			City of Freeport				
Class / End Use				ricepo			
Class / Ellu-Use		Sharo	2020	2020	2040	2050	
Flootrigity	N (NV/1-	Silate	2020	2030	2 040 50,712	100.069	
Heating	Mwn		405 125	190,690	221 740	100,000	
Network Cas	mmbtu	100/	495,155	409,009	22 174	0	
Natural Gas	mmbtu	1070	49,515	40,909	35,174	0	
Heating Oil	mmbtu	90%	445,621	440,720	298,300	0	
Commercial							
Electricity	MWh		41,129	41,499	47,209	63,810	
Heating	mmbtu		134,604	133,123	90,184	0	
Natural Gas	mmbtu	20%	26,921	26,625	18,037	0	
Heating Oil	mmbtu	80%	107,683	106,498	72,148	0	
Process	mmbtu		37,390	37,390	37,016	0	
Natural Gas	mmbtu	20%	7,478	7,478	7,403	0	
Heating Oil	mmbtu	80%	29,912	29,912	29,613	0	
Industrial							
Electricity	MWh		9,720	9,825	11,496	31,483	
Heating	mmbtu		29,161	28,840	19,538	0	
Natural Gas	mmbtu	30%	8,748	8.652	5.861	0	
Heating Oil	mmbtu	70%	20.413	20,188	13.677	0	
Process	mmbtu		81.003	81.003	80,193	0	
Natural Gas	mmbtu	30%	24 301	24 301	24.058	0	
Heating Oil	mmbtu	70%	56,702	56,702	56,135	0	
Transportation							
Passenger Vehicles							
Gasoline	mmhtu		371 265	352 702	159 644	0	
Electricity	MW/b		0	1 071	12 212	21 425	
Encetterty	1 11 W 11		0	1,071	12,212	21,125	
Commercial Trucks							
Gasoline	mmbtu		101,857	97,477	48,891	0	
Electricity	MWh		0	66	803	1,545	
Buses							
Diesel	mmbtu		7,052	6,742	3,526	0	
Electricity	MWh		0	37	420	840	
Heavy-Duty Trucks							
Diesel	mmhtu		12 181	11 657	5 847	0	
Electricity	MW/b		12,101	40	485	932	
Liteticity	W W II		0	-10	100	752	
Totals							
Electricity	MWh		84,041	87,220	132,338	220,103	
Natural Gas	mmbtu		116,961	116,024	88,533	0	
Heating Oil	mmbtu		660,331	654,020	470,138	0	
Gasoline	mmbtu		473,122	450,179	208,535	0	
Diesel	mmbtu		19,233	18,399	9,373	0	
Total Energy Use	mmbtu	_	1,556,480	1,536,304	1,228,249	751,211	
Total CO2 Emissions	tons		119,697	111,520	73,384	0	

Table B - 9 Total Energy Use and Emissions – Freeport

Energy Use Table	City of						
				Gorhai	Gorham		
Class / End-Use							
Residential		Share	2020	2030	2040	2050	
Electricity	MWh		52,989	55,661	98,714	165,807	
Heating	mmbtu		790,462	781,767	529,610	0	
Natural Gas	mmbtu	10%	79,046	78,177	52,961	0	
Heating Oil	mmbtu	90%	711,416	703,590	476,649	0	
Commercial							
Electricity	MWh		38,308	39,036	48,425	67,669	
Heating	mmbtu		125,372	123,993	83,999	0	
Natural Gas	mmbtu	20%	25,074	24,799	16,800	0	
Heating Oil	mmbtu	80%	100,297	99,194	67,199	0	
Process	mmbtu		34,825	34,825	34,477	0	
Natural Gas	mmbtu	20%	6,965	6,965	6,895	0	
Heating Oil	mmbtu	80%	27,860	27,860	27,582	0	
Industrial							
Electricity	MWh		8,800	9,097	12,814	33,017	
Heating	mmbtu		26,399	26,108	17,687	0	
Natural Gas	mmbtu	30%	7,920	7,832	5,306	0	
Heating Oil	mmbtu	70%	18,479	18,276	12,381	0	
Process	mmbtu		73,330	73,330	72,596	0	
Natural Gas	mmbtu	30%	21,999	21,999	21,779	0	
Heating Oil	mmbtu	70%	51,331	51,331	50,818	0	
Transportation							
Passenger Vehicles							
Gasoline	mmbtu		702,671	667,538	302,149	0	
Electricity	MWh		0	2,028	23,114	40,551	
Commercial Trucks							
Gasoline	mmbtu		275,183	263,351	132,088	0	
Electricity	MWh		0	179	2,170	4,173	
Buses							
Diesel	mmbtu		17,951	17,161	8,976	0	
Electricity	MWh		0	94	1,069	2,137	
Heavy-Duty Trucks							
Diesel	mmbtu		83,986	80,374	40,313	0	
Electricity	MWh		0	276	3,341	6,426	
Totals							
Electricity	MWh		100,096	106,371	189,647	319,779	
Natural Gas	mmbtu		141,004	139,772	103,741	0	
Heating Oil	mmbtu		909,383	900,251	634,628	0	
Gasoline	mmbtu		977,855	930,888	434,237	0	
Diesel	mmbtu		101,937	97,535	49,289	0	
Total Energy Use	mmbtu		2,471,808	2,431,490	1,869,159	1,091,405	
Total CO2 Emissions	tons	_	191,446	180,188	114,176	0	

Table B - 10Total Energy Use and Emissions – Gorham

Energy Use Table			City of				
Class / End-Use				Gray			
Residential		Share	2020	2030	2040	2050	
Flectricity	MWb	onare	28.013	2030	51 843	87.022	
Heating	mmbtu		417 885	413 289	279.983	07,022	
Natural Gas	mmbtu	0%	-17,005	-115,209	275,505	0	
Heating Oil	mmbtu	100%	417 885	413 289	279 983	0	
Treating On	mmotu	10070	417,005	413,207	219,905	0	
Commercial							
Electricity	MWh		16,010	16,365	20,818	29,328	
Heating	mmbtu		52,398	51,821	35,106	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	52,398	51,821	35,106	0	
Process	mmbtu		14,555	14,555	14,409	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	14,555	14,555	14,409	0	
Industrial							
Flectricity	маль		<i>/</i> 10	197	1 160	2 544	
Lection	Mwn		410	462	1,109	2,344	
Natural Cas	mmbtu	097	1,234	1,240	040	0	
Natural Gas	mmbtu	100%	1 254	1 240	840	0	
Heating Oil	mmbtu	100%	1,254	1,240	840 2 440	0	
Process	mmbtu	00/	3,464	3,484	5,449	0	
Natural Gas	mmbtu	0%	2 494	2 494	2 4 4 0	0	
Heating Oil	mmbtu	100%	5,484	3,484	5,449	0_	
Transportation							
Passenger Vehicles							
Gasoline	mmbtu		365,323	347,057	157,089	0	
Electricity	MWh		0	1,054	12,017	21,082	
Commercial Trucks							
Gasoline	mmbtu		112,840	107 988	54 163	0	
Electricity	MWb		0	74	890	1 711	
Incetterty	101 0011		0	71	070	1,711	
Buses							
Diesel	mmbtu		9,617	9,194	4,808	0	
Electricity	MWh		0	50	572	1,145	
Heavy-Duty Trucks							
Diesel	mmbtu		15.387	14.725	7.386	0	
Electricity	MWh		0	51	612	1,177	
Totals							
Electricity	MWh		44,442	47,472	87,922	144,010	
Natural Gas	mmbtu		0	0	0	0	
Heating Oil	mmbtu		489,576	484,389	333,788	0	
Gasoline	mmbtu		478,164	455,045	211,252	0	
Diesel	mmbtu		25,003	23,919	12,194	0	
Total Energy Use	mmbtu	_	1,144,422	1,125,376	857,312	491,506	
Total CO2 Emissions	tons		90,070	84,947	53,227	0	

Table B - 11 Total Energy Use and Emissions – Gray

Energy Use Table			City of Long Island				
Class / End-Use							
Residential		Share	2020	2030	2040	2050	
Electricity	MWh		2,262	2,312	3,481	5,780	
Heating	mmbtu		33,744	33,373	22,609	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	33,744	33,373	22,609	0	
Commercial							
Electricity	MWh		701	705	772	1,027	
Heating	mmbtu		2,295	2,269	1,537	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	2,295	2,269	1,537	0	
Process	mmbtu		637	637	631	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	637	637	631	0	
Industrial							
Electricity	MWh		0	0	0	0	
Heating	mmbtu		0	0	0	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	0	0	0	0	
Process	mmbtu		0	0	Ő	0	
Natural Gas	mmbtu	0%	0	0	Ő	0	
Heating Oil	mmbtu	100%	0	0	0	0	
Transportation							
Passenger Vehicles							
Gasoline	mmbtu		2.979	2.830	1.281	0	
Electricity	MWh		0	9	98	172	
Commercial Trucks							
Gasoline	mmbtu		106	101	51	0	
Electricity	MWh		0	0	1	2	
Buses							
Diesel	mmbtu		0	0	0	0	
Electricity	MWh		0	0	0	0	
Heavy-Duty Trucks							
Diesel	mmbtu		0	0	0	0	
Electricity	MWh		0	0	0	0	
Totals							
Electricity	MWh		2.963	3.025	4,351	6.980	
Natural Gas	mmbtu		0	0	0	0,1.50	
Heating Oil	mmbtu		36 676	36.280	24.777	0	
Gasoline	mmbtu		3.085	2.931	1.332	0	
Diesel	mmhtu		0	_,1	0	0	
Total Energy Use	mmbtu		49.874	49.536	40,959	23.824	
Total CO2 Emissions	tons	_	3 935	3 680	2.534	0	
	10110		-,	-,000	_,001	0	

Table B - 12 Total Energy Use and Emissions – Long Island

Energy Use Table	0.			City o	f		
		New Glouc			cester		
Class / End-Use							
Residential		Share	2020	2030	2040	2050	
Electricity	MWh		20,956	21,765	36,198	60,534	
Heating	mmbtu		312,604	309,166	209,445	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	312,604	309,166	209,445	0	
Commercial							
Electricity	MWh		12,417	12,577	14,829	20,295	
Heating	mmbtu		40,637	40,190	27,227	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	40,637	40,190	27,227	0	
Process	mmbtu		11,288	11,288	11,175	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	11,288	11,288	11,175	0	
Industrial							
Electricity	MWh		93	132	549	1,093	
Heating	mmbtu		280	277	188	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	280	277	188	0	
Process	mmbtu		779	779	771	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	779	779	771	0	
Transportation							
Passenger Vehicles							
Gasoline	mmbtu		176,085	167,281	75,717	0	
Electricity	MWh		0	508	5,792	10,162	
Commercial Trucks							
Gasoline	mmbtu		54,246	51,914	26,038	0	
Electricity	MWh		0	35	428	823	
Buses							
Diesel	mmbtu		0	0	0	0	
Electricity	MWh		0	0	0	0	
Heavy-Duty Trucks							
Diesel	mmbtu		10,899	10,430	5,231	0	
Electricity	MWh		0	36	434	834	
Totals							
Electricity	MWh		33,466	35,054	58,230	93,740	
Natural Gas	mmbtu		0	0	0	0	
Heating Oil	mmbtu		365,589	361,700	248,806	0	
Gasoline	mmbtu		230,332	219,195	101,755	0	
Diesel	mmbtu		10,899	10,430	5,231	0	
Total Energy Use	mmbtu		721,038	710,964	554,530	319,934	
Total CO2 Emissions	tons		56,755	53,298	34,261	0	

Total Energy Use and Emissions – New Gloucester Table B - 13

Energy Use Table	City of						
		nouth					
Class / End-Use							
Residential		Share	2020	2030	2040	2050	
Electricity	MWh		17,531	18,261	30,896	51,729	
Heating	mmbtu		261,514	258,638	175,215	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	261,514	258,638	175,215	0	
Commercial							
Electricity	MWh		3,697	3,823	5,323	7,663	
Heating	mmbtu		12,098	11,965	8,106	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	12,098	11,965	8,106	0	
Process	mmbtu		3,361	3,361	3,327	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	3,361	3,361	3,327	0	
Industrial							
Electricity	MWh		826	887	1,586	3,804	
Heating	mmbtu		2,479	2,452	1,661	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	2,479	2,452	1,661	0	
Process	mmbtu		6,887	6,887	6,818	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	6,887	6,887	6,818	0	
Transportation							
Passenger Vehicles							
Gasoline	mmbtu		169,274	160,810	72,788	0	
Electricity	MWh		0	488	5,568	9,769	
Commercial Trucks							
Gasoline	mmbtu		57,163	54,705	27,438	0	
Electricity	MWh		0	37	451	867	
Buses							
Diesel	mmbtu		0	0	0	0	
Electricity	MWh		0	0	0	0	
Heavy-Duty Trucks							
Diesel	mmbtu		14,104	13,498	6,770	0	
Electricity	MWh		0	46	561	1,079	
Totals							
Electricity	MWh		22,054	23,543	44,384	74,910	
Natural Gas	mmbtu		0	0	0	0	
Heating Oil	mmbtu		286,340	283,303	195,127	0	
Gasoline	mmbtu		226,437	215,515	100,226	0	
Diesel	mmbtu		14,104	13,498	6,770	0	
Total Energy Use	mmbtu		602,151	592,670	453,605	255,669	
Total CO2 Emissions	tons		47,475	44,931	28,559	0	

Table B - 14 Total Energy Use and Emissions – North Yarmouth

Energy Use Table				City of			
			Old Orchard Beach				
Class / End-Use							
Residential		Share	2020	2030	2040	2050	
Electricity	MWh		35,680	37,199	63,237	105,847	
Heating	mmbtu		532,252	526,397	356,609	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	532,252	526,397	356,609	0	
Commercial							
Electricity	MWh		8,761	9,046	12,420	17,844	
Heating	mmbtu		28,671	28,356	19,210	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	28,671	28,356	19,210	0	
Process	mmbtu		7,964	7,964	7,885	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	7,964	7,964	7,885	0	
Industrial							
Electricity	MWh		920	984	1,706	4,064	
Heating	mmbtu		2,759	2,729	1,849	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	2,759	2,729	1,849	0	
Process	mmbtu		7,665	7,665	7,588	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	7,665	7,665	7,588	0	
Transportation							
Passenger Vehicles							
Gasoline	mmbtu		373,220	354,559	160,485	0	
Electricity	MWh		0	1,077	12,277	21,538	
Commercial Trucks							
Gasoline	mmbtu		58,910	56,377	28,277	0	
Electricity	MWh		0	38	465	893	
Buses							
Diesel	mmbtu		5,770	5,516	2,885	0	
Electricity	MWh		0	30	343	687	
Heavy-Duty Trucks							
Diesel	mmbtu		5,770	5,522	2,770	0	
Electricity	MWh		0	19	230	441	
Totals							
Electricity	MWh		45,360	48,393	90,678	151,315	
Natural Gas	mmbtu		0	0	0	0	
Heating Oil	mmbtu		579,312	573,112	393,140	0	
Gasoline	mmbtu		432,130	410,936	188,762	0	
Diesel	mmbtu		11,540	11,038	5,655	0	
Total Energy Use	mmbtu		1,177,797	1,160,252	897,040	516,439	
Total CO2 Emissions	tons		92,826	87,751	55,989	0	

Table B - 15 Total Energy Use and Emissions – Old Orchard Beach

Energy Use Table			City of Bostland				
Class / End-Use		Fortial	i ortianu				
Besidential		Share	2020	2030	2040	2050	
Flectricity	MWb	Share	191 801	200 883	350.487	587 869	
Heating	mwh		2 861 184	200,885	1 916 993		
Natural Gas	mmbtu	50%	1 430 592	1 /1/ 856	958 497	0	
Heating Oil	mmbtu	50%	1,430,592	1 414 856	958 497	0	
Treating On	mmbtu	5070	1,+50,572	1,414,050	JJ0, T J7	0	
Commercial							
Electricity	MWh		333,019	335,977	381,921	516,928	
Heating	mmbtu		1,089,879	1,077,890	730,219	0	
Natural Gas	mmbtu	65%	708,421	700,629	474,642	0	
Heating Oil	mmbtu	35%	381,458	377,262	255,577	0	
Process	mmbtu		302,744	302,744	299,717	0	
Natural Gas	mmbtu	65%	196,784	196,784	194,816	0	
Heating Oil	mmbtu	35%	105,960	105,960	104,901	0	
Industrial							
Electricity	MWb		70 170	71 115	85 299	231 818	
Heating	mmhtu		210 509	208 193	141 041	251,010	
Natural Gas	mmbtu	80%	168 407	166 554	112,833	Ő	
Heating Oil	mmbtu	20%	42 102	41 639	28 208	0	
Process	mmbtu	2070	584 746	584 746	578 898	0	
Natural Gas	mmbtu	80%	467 797	467 797	463 119	0	
Heating Oil	mmbtu	20%	116,949	116,949	115,780	0	
Transportation							
Passenger Vehicles							
Gasoline	mmhtu		2 345 106	2 227 851	1 008 396	0	
Electricity	MWh		2,345,100	6 767	77 140	135 334	
Electricity	M W II		0	0,707	11,140	155,554	
Commercial Trucks							
Gasoline	mmbtu		671,802	642,915	322,465	0	
Electricity	MWh		0	438	5,297	10,187	
Buses							
Diesel	mmbtu		98,731	94,387	49,366	0	
Electricity	MWh		0	517	5,877	11,755	
Heavy-Duty Trucks							
Diesel	mmbtu		207,720	198,788	99,706	0	
Electricity	MWh		0	683	8,264	15,892	
Totals							
Electricity	MWh		594,989	616,380	914,286	1,509,784	
Natural Gas	mmbtu		2,972,001	2,946,619	2,203,906	0	
Heating Oil	mmbtu		2,077,061	2,056,666	1,462,962	0	
Gasoline	mmbtu		3,016,908	2,870,766	1,330,861	0	
Diesel	mmbtu		306,451	293,175	149,071	0	
Total Energy Use	mmbtu	_	10,403,118	10,270,930	8,267,257	5,152,892	
Total CO2 Emissions	tons		751,309	694,761	454,598	0	

Table B - 16 Total Energy Use and Emissions – Portland
Energy Use Table				City of Pownal		
Class / End-Use						
Residential		Share	2020	2030	2040	2050
Electricity	MWh		7,423	7,737	13,133	21,992
Heating	mmbtu		110,734	109,516	74,192	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	110,734	109,516	74,192	0
Commercial						
Electricity	MWh		1,660	1,733	2,575	3,807
Heating	mmbtu		5,433	5,373	3,640	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	5,433	5,373	3,640	0
Process	mmbtu		1,509	1,509	1,494	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	1,509	1,509	1,494	0
Industrial						
Electricity	MWh		68	81	219	464
Heating	mmbtu		204	202	137	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	204	202	137	0
Process	mmbtu		566	566	560	0
Natural Gas	mmbtu	0%	0	0	0	0
Heating Oil	mmbtu	100%	566	566	560	0
Transportation						
Passenger Vehicles						
Gasoline	mmbtu		73,927	70,231	31,789	0
Electricity	MWh		0	213	2,432	4,266
Commercial Trucks						
Gasoline	mmbtu		23,331	22,328	11,199	0
Electricity	MWh		0	15	184	354
Buses						
Diesel	mmbtu		1,923	1,839	962	0
Electricity	MWh		0	10	114	229
Heavy-Duty Trucks						
Diesel	mmbtu		4,488	4,295	2,154	0
Electricity	MWh		0	15	179	343
Totals						
Electricity	MWh		9,151	9,804	18,835	31,455
Natural Gas	mmbtu		0	0	0	0
Heating Oil	mmbtu		118,446	117,166	80,023	0
Gasoline	mmbtu		97,258	92,558	42,987	0
Diesel	mmbtu		6,411	6,134	3,116	0
Total Energy Use	mmbtu		253,348	249,318	190,411	107,358
Total CO2 Emissions	tons		19,974	18,907	11,951	0

Table B - 17 Total Energy Use and Emissions – Pownal

Energy Use Table		City of Raymond					
Class / End-Use							
Residential		Share	2020	2030	2040	2050	
Electricity	MWh		20,007	20,880	35,712	59,832	
Heating	mmbtu		298,459	295,176	199,967	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	298,459	295,176	199,967	0	
Commercial							
Electricity	MWh		9,423	9,583	11,684	16,147	
Heating	mmbtu		30,840	30,501	20,663	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	30,840	30,501	20,663	0	
Process	mmbtu		8,567	8,567	8,481	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	8,567	8,567	8,481	0	
Industrial							
Electricity	MWh		0	0	0	0	
Heating	mmbtu		0	0	0	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	0	0	0	0	
Process	mmbtu		0	0	0	0	
Natural Gas	mmbtu	0%	0	0	0	0	
Heating Oil	mmbtu	100%	0	0	0	0	
Transportation							
Passenger Vehicles							
Gasoline	mmbtu		199,282	189,318	85,691	0	
Electricity	MWh		0	575	6,555	11,500	
Commercial Trucks							
Gasoline	mmbtu		63,375	60,650	30,420	0	
Electricity	MWh		0	41	500	961	
Buses							
Diesel	mmbtu		0	0	0	0	
Electricity	MWh		0	0	0	0	
Heavy-Duty Trucks							
Diesel	mmbtu		3,847	3,681	1,846	0	
Electricity	MWh		0	13	153	294	
Totals							
Electricity	MWh		29,431	31,093	54,605	88,735	
Natural Gas	mmbtu		0	0	0	0	
Heating Oil	mmbtu		337,865	334,243	229,111	0	
Gasoline	mmbtu		262,657	249,968	116,111	0	
Diesel	mmbtu		3,847	3,681	1,846	0	
Total Energy Use	mmbtu		704,816	694,011	533,435	302,851	
Total CO2 Emissions	tons	_	55,484	52,267	33,167	0	

Table B - 18 Total Energy Use and Emissions – Raymond

Saco Residential Share 2020 2030 2040 2050 Electricity MWh 64,514 67,876 121,446 204,128 Heating mmbu 902,380 925,774 644,475 0 Natural Gas mmbu 30% 288,714 285,538 193,458 0 Heating Oil mmbu 70% 673,666 666,256 451,356 0 Commercial Electricity MWh 39,148 40,016 50,926 71,720 Heating Oil mmbu 30% 38,456 38,014 25,752 0 Industrial mmbu 70% 89,486 86,096 60,089 0 Process mmbu 30% 35,589 35,233 0 Natural Gas mmbu 30,62 33,588 22,754 0 Ideatring mmbu 33,302 33,588 22,754 0 0 Natural Gas mmbu 50% 16,981	Energy Use Table			City of						
Class / End-Use Share 2020 2030 2040 2080 Electricity MWh 64,514 $67,876$ 121,446 204,128 Heating mmhtu $902,380$ $951,794$ $644,795$ 0 Natural Gas mmhtu 30% $288,714$ $285,538$ 193,438 0 Commercial Electricity MWh $30,148$ $40,016$ $50,926$ $71,720$ Heating mmhtu 30% $38,436$ $38,014$ $25,752$ 0 Heating OD mmhtu 70% $89,688$ $88,098$ $60,089$ 0 Process mmhtu 70% $89,685$ $35,589$ $35,233$ 0 Natural Gas mmhtu 30% $21,354$ 21,140 0 Industrial Electricity MWh $11,521$ $11,709$ $16,553$ $42,669$ Heating OD mmhtu 50% $16,981$ $16,794$ $11,577$ 0 Natural Gas<				Saco						
Residential Share 202 203 2040 2050 Electricity MWh 64,514 67,876 121,446 204,128 Heating mubu 30% 288,714 285,538 193,438 0 Commercial Electricity MWh 30,148 40,016 50,926 71,720 Heating mmbu 128,121 126,712 85,841 0 Natural Gas mmbu 30% 38,435 38,014 25,752 0 Heating Oil mmbu 35,859 35,589 35,233 0 Natural Gas 0 Natural Gas mmbu 35,859 35,589 35,233 0 0 Heating Oil mubu 35,959 35,589 35,233 0 0 Natural Gas mubu 33,062 33,588 22,754 0 Natural Gas mubu 50% 16,081 16,794 11,377 0 Natural Gas mubu 50%	Class / End-Use									
Electricity MWh $64,514$ $67,876$ $121,446$ $204,128$ Heating mmbra $902,230$ $951,774$ $644,795$ 0 Natural Gas mmbra 70% $673,666$ $666,256$ $451,356$ 0 Commercial Electricity MWh $39,148$ $40,016$ $50,926$ $71,720$ Heating mmbra 30% $38,436$ $38,014$ $25,752$ 0 Natural Gas mmbra 70% $89,685$ $88,608$ 60.69 0 Proces mmbra 30% $38,436$ $30,014$ $25,752$ 0 Natural Gas mmbra 70% $89,685$ $88,608$ 60.69 0 Proces mmbra 00% $21,354$ $21,354$ $21,343$ $11,400$ Industrial Gas mmbra 50% $16,081$ $16,794$ $11,377$ 0 Natural Gas mmbra 50% $16,081$ $16,794$	Residential		Share	2020	2030	2040	2050			
Heating mmbu 962,380 951,794 644,795 0 Natural Gas mmbu 70% 238,714 285,538 193,438 0 Itating OI mmbu 70% 673,666 666,256 451,356 0 Commercial Electricity MWh 39,148 40,016 50,926 71,720 Heating OI mmbu 70% 89,685 88,698 60,089 0 Natural Gas mmbu 70% 89,685 88,698 60,089 0 Process mmbu 40% 21,354 21,354 21,140 0 Industrial Electricity MWh 11,321 11,709 16,553 42,609 Heating mmbu 50% 16,981 16,794 11,377 0 Heating OI mmbu 50% 47,169 47,169 46,697 0 Natural Gas mmbu 50% 47,169 47,169 46,697 0 Passenger Vehicles	Electricity	MWh		64,514	67,876	121,446	204,128			
Natural Gas mmbu 30% 288,714 285,538 193,438 0 Heating Oil mmbu 70% 673,666 666,256 451,356 0 Commercial Electricity MWh 39,148 40,016 50,926 71,720 Heating mmbu 30% 38,436 38,014 25,752 0 Natural Gas mmbu 30% 38,436 38,014 25,752 0 Process mmbu 30% 35,589 35,589 30,089 0 Process mmbu 40% 14,236 14,236 14,003 0 Heating mmbu 60% 21,354 21,140 0 Industrial Electricity MWh 11,321 11,709 16,553 42,609 Heating Oil mmbu 50% 16,081 16,794 11,377 0 Heating Oil mmbu 50% 47,169 47,169 46,607 0 Transportation m	Heating	mmbtu		962,380	951,794	644,795	0			
Heating Oil mmbu 70% 673,666 666,256 451,356 0 Commercial Heating mmbu 39,148 40,016 50,926 71,720 Heating mmbu 30% 38,436 38,014 25,752 0 Heating mmbu 30% 38,436 38,014 25,752 0 Process mmbu 70% 89,685 88,698 60,089 0 Process mmbu 70% 89,685 86,098 05,233 0 Natural Gas mmbu 40% 14,236 14,236 14,093 0 Industrial Electricity MWh 11,321 11,709 16,553 42,609 Heating Oil mmbu 50% 16,981 16,794 11,377 0 Heating Oil mmbu 50% 47,169 47,169 46,607 0 Transportation Passenger Vehicles Gasoline mmbu 579,596 363,274 182,206 0 <t< td=""><td>Natural Gas</td><td>mmbtu</td><td>30%</td><td>288,714</td><td>285,538</td><td>193,438</td><td>0</td></t<>	Natural Gas	mmbtu	30%	288,714	285,538	193,438	0			
Commercial Electricity MWh $39,148$ $40,016$ $50,926$ $71,720$ Heating mmbu $128,121$ $126,712$ $85,841$ 0 Natural Gas mmbu 30% $38,436$ $38,001$ $25,752$ 0 Heating Oil mmbu $35,589$ $35,589$ $35,233$ 0 Natural Gas mmbu 40% $14,236$ $14,023$ 14,033 0 Heating Oil mmbu 60% $21,354$ $21,354$ $21,140$ 0 Industrial Electricity MWh $11,521$ $11,709$ $16,553$ $42,609$ Heating Oil mmbu 50% $16,981$ $16,794$ $11,377$ 0 Natural Gas mmbu 50% $16,981$ $16,794$ $11,377$ 0 Process mmbu 50% $47,169$ $47,169$ $46,697$ 0 Transportation Process gasoline mmbu 50% $47,169$	Heating Oil	mmbtu	70%	673,666	666,256	451,356	0			
Electricity MWh 39,148 40,016 50,226 71,720 Heating mmbu 128,121 126,712 85,841 0 Natural Gas mmbu 30% 38,436 38,014 25,752 0 Heating Oil mmbu 70% 89,685 88,698 60,089 0 Natural Gas mmbu 35,589 35,583 35,233 0 Natural Gas mmbu 60% 21,354 21,354 21,140 0 Industrial Electricity MWh 11,321 11,709 16,553 42,609 Heating Oil mmbu 50% 16,981 16,794 11,377 0 Process mmbu 50% 47,169 47,169 46,697 0 Natural Gas mmbu 50% 47,169 46,697 0 Process mmbu 50% 47,169 46,697 0 Passenger Vehicles Gasoline mmbu 50% 47,169 <	Commercial									
Heating mmbu 128,121 126,712 85,841 0 Natural Gas mmbu 30% 38,014 22,572 0 Heating Oil mmbu 70% 89,685 88,098 60,089 0 Process mmbu 35,589 35,233 0 0 Matural Gas mmbu 60% 21,354 21,354 21,40 0 Industrial Electricity MVh 11,321 11,709 16,553 42,609 Heating Oil mmbu 33,962 33,588 22,754 0 Natural Gas mmbu 50% 16,981 16,794 11,377 0 Heating Oil mmbu 50% 47,169 47,169 46,607 0 Process mmbu 50% 47,169 47,169 46,607 0 Heating Oil mmbu 50% 47,169 47,169 46,607 0 Consenceial Trucks Gasoline mmbu 50% 47,169<	Electricity	MWh		39,148	40,016	50,926	71,720			
Natural Gas mmbu 30% 38,436 38,014 25,752 0 Heating Oil mmbu 70% 89,685 86,698 60,089 0 Process mmbu 35,589 35,233 0 0 Natural Gas mmbu 60% 21,354 21,354 21,140 0 Industrial Electricity MWh 11,321 11,709 16,553 42,609 Heating mmbu 50% 16,981 16,794 11,377 0 Natural Gas mmbu 50% 16,981 16,794 11,377 0 Process mmbu 94,338 94,338 93,394 0 Natural Gas mmbu 94,338 94,338 93,394 0 Natural Gas mmbu 50% 47,169 47,169 46,697 0 Rassenger Vehicles Gasoline mmbu 50% 23,528 29,471 51,703 Commercial Trucks Gasoline mmbu	Heating	mmbtu		128,121	126,712	85,841	0			
Heating Oil mmbu 70% 89,685 88,698 60,089 0 Process mmbu 35,589 35,589 35,233 0 Natural Gas mmbu 40% 14,236 14,236 14,003 0 Heating Oil mmbu 60% 21,354 21,134 0 0 Industrial Electricity MWh 11,321 11,709 16,553 42,609 Heating mmbu 50% 16,081 16,794 11,377 0 Heating Oil mmbu 50% 16,081 16,794 11,377 0 Process mmbu 94,338 94,338 93,394 0 0 Natural Gas mmbu 50% 47,169 47,169 46,607 0 Heating Oil mmbu 50% 47,169 46,607 0 0 Electricity MWh 0 2,585 29,471 51,705 Gasoline mmbu 379,596 363,	Natural Gas	mmbtu	30%	38,436	38,014	25,752	0			
Process mmbu $35,589$ $35,289$ $35,233$ 0 Natural Gas mmbu 40% $14,236$ $14,236$ $14,003$ 0 Industrial Electricity MWh $11,321$ $11,709$ $16,553$ $42,609$ Heating mmbu $33,962$ $33,588$ $22,754$ 0 Natural Gas mmbu 50% $16,981$ $16,794$ $11,377$ 0 Heating Oil mmbu 50% $16,981$ $16,794$ $11,377$ 0 Process mmbu 90% $47,169$ $47,169$ $46,697$ 0 Natural Gas mmbu 50% $47,169$ $47,169$ $46,697$ 0 Transportation Passenger Vehicles Gasoline mmbu $379,596$ $363,274$ $182,206$ 0 Electricity MWh 0 248 2993 $5,756$ Buses mmbu $16,028$ $15,323$ $8,014$ 0	Heating Oil	mmbtu	70%	89,685	88,698	60,089	0			
Natural Gas mmbu 40% 14,236 14,236 14,093 0 Heating Oil mmbu 60% 21,354 21,354 21,140 0 Industrial Electricity MWh 11,321 11,709 16,553 42,609 Heating mmbu 33,962 33,588 22,754 0 Natural Gas mmbu 50% 16,981 16,794 11,377 0 Heating Oil mmbu 50% 16,981 16,794 11,377 0 Process mmbu 50% 47,169 47,169 46,697 0 Heating Oil mmbu 50% 47,169 47,169 46,697 0 Transportation Passenger Vehicles Gasoline mmbu 895,928 851,132 385,249 0 Electricity MWh 0 2,485 2,9471 51,703 Commercial Trucks Gasoline mmbu 379,596 363,274 182,206 0 E	Process	mmbtu		35,589	35,589	35,233	0			
Heating Oil mmbtu 60% 21,354 21,354 21,140 0 Industrial Electricity MWh 11,321 11,709 16,553 42,609 Heating mmbtu 33,962 33,588 22,754 0 Natural Gas mmbtu 50% 16,981 16,794 11,377 0 Process mmbtu 50% 47,169 47,169 46,697 0 Natural Gas mmbtu 50% 47,169 47,169 46,697 0 Heating Oil mmbtu 50% 47,169 47,169 46,697 0 Tansportation Passenger Vehicles Gasoline mmbtu 895,928 851,132 385,249 0 Electricity MWh 0 2,585 29,471 51,703 Commercial Trucks Gasoline mmbtu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses <t< td=""><td>Natural Gas</td><td>mmbtu</td><td>40%</td><td>14,236</td><td>14,236</td><td>14,093</td><td>0</td></t<>	Natural Gas	mmbtu	40%	14,236	14,236	14,093	0			
Industrial Electricity MWh 11,321 11,709 16,553 42,609 Heating mmbu 50% 16,981 16,794 11,377 0 Heating Oil mmbu 50% 16,981 16,794 11,377 0 Process mmbu 94,338 94,338 93,934 0 Natural Gas mmbu 94,338 94,338 93,944 0 Process mmbu 94,358 94,338 93,944 0 Heating Oil mmbu 50% 47,169 47,169 46,697 0 Transportation Passenger Vehicles Gasoline mmbu 895,928 851,132 385,249 0 Electricity MWh 0 2,585 29,471 51,703 Commercial Trucks Gasoline mmbu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses Dissel mmbu 16,0	Heating Oil	mmbtu	60%	21,354	21,354	21,140	0			
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	Industrial									
Heating mmbu 33,962 33,588 22,754 0 Natural Gas mmbu 50% 16,981 16,794 11,377 0 Heating Oil mmbu 50% 16,981 16,794 11,377 0 Process mmbu 50% 47,169 47,169 46,697 0 Matural Gas mmbu 50% 47,169 47,169 46,697 0 Transportation mmbu 50% 47,169 47,169 46,697 0 Electricity MWh 0 2,585 29,471 51,703 Commercial Trucks Gasoline mmbu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses Diesel mmbu 16,028 15,323 8,014 0 Electricity MWh 0 354 4,285 8,240 Totals Itertricity MWh 114,982 122,871	Electricity	MWh		11,321	11,709	16,553	42,609			
Natural Gas mmbu 50% $16,981$ $16,794$ $11,377$ 0 Heating Oil mmbu 50% $16,981$ $16,794$ $11,377$ 0 Process mmbu $94,338$ $94,338$ $93,394$ 0 Natural Gas mmbu 50% $47,169$ $47,169$ $46,697$ 0 Transportation Passenger Vehicles Gasoline mmbu $895,928$ $851,132$ $385,249$ 0 Electricity MWh 0 $2,585$ $29,471$ $51,703$ Commercial Trucks Gasoline mmbu $379,596$ $363,274$ $182,206$ 0 Electricity MWh 0 248 $2,993$ $5,756$ Buses Diesel mmbu $16,028$ $15,323$ $8,014$ 0 Electricity MWh 0 354 $4,285$ $8,240$ Totals Electricity MWh 0 354 $4,285$ $8,0605$	Heating	mmbtu		33,962	33,588	22,754	0			
Heating Oil mmbu 50% 16,981 16,794 11,377 0 Process mmbu 94,338 94,338 93,394 0 Natural Gas mmbu 50% 47,169 47,169 46,697 0 Heating Oil mmbu 50% 47,169 47,169 46,697 0 Transportation Passenger Vehicles Gasoline mmbu 895,928 851,132 385,249 0 Electricity MWh 0 2,585 29,471 51,703 Commercial Trucks Gasoline mmbtu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses Diesel mmbtu 16,028 15,323 8,014 0 Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 114,9	Natural Gas	mmbtu	50%	16,981	16,794	11,377	0			
Process nmbu 94,338 94,338 93,394 0 Natural Gas mmbu 50% 47,169 47,169 46,697 0 Heating Oil mmbu 50% 47,169 47,169 46,697 0 Transportation Passenger Vehicles Gasoline mmbu 895,928 851,132 385,249 0 Electricity MWh 0 2,585 29,471 51,703 Commercial Trucks Gasoline mmbtu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses Diesel mmbtu 16,028 15,323 8,014 0 Heavy-Duty Trucks Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 427	Heating Oil	mmbtu	50%	16,981	16,794	11,377	0			
Natural Gas mmbu 50% 47,169 47,169 47,169 46,697 0 Heating Oil mmbu 50% 47,169 47,169 46,697 0 Transportation Passenger Vehicles Gasoline mmbu 895,928 851,132 385,249 0 Electricity MWh 0 2,585 29,471 51,703 Commercial Trucks Gasoline mmbtu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses Diesel mmbtu 16,028 15,323 8,014 0 Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu </td <td>Process</td> <td>mmbtu</td> <td></td> <td>94.338</td> <td>94.338</td> <td>93,394</td> <td>0</td>	Process	mmbtu		94.338	94.338	93,394	0			
Heating Oil mmbu 50% 47,169 47,169 46,697 0 Transportation Passenger Vehicles Gasoline mmbu 895,928 851,132 385,249 0 Electricity MWh 0 2,585 29,471 51,703 Commercial Trucks Gasoline mmbu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses Diesel mmbu 16,028 15,323 8,014 0 Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbu 405,536 401,751 291,359 0 Heating Oil mmbu 1,275,524	Natural Gas	mmbtu	50%	47.169	47.169	46.697	Õ			
Transportation Passenger Vehicles Gasoline mmbru 895,928 $851,132$ $385,249$ 0 Electricity MWh 0 $2,585$ $29,471$ $51,703$ Commercial Trucks Gasoline mmbru $379,596$ $363,274$ $182,206$ 0 Electricity MWh 0 248 $2,993$ $5,756$ Buses Diesel mmbru $16,028$ $15,323$ $8,014$ 0 Electricity MWh 0 84 954 $1,908$ Heavy-Duty Trucks Diesel mmbru $107,707$ $103,075$ $51,699$ 0 Electricity MWh 0 354 $4,285$ $8,240$ Totals Electricity MWh $114,982$ $122,871$ $226,629$ $386,065$ Natural Gas mmbru $405,536$ $401,751$ $291,359$ 0 Heating Oil mmbru $122,7524$ $1,214,405$ $567,455$ <td>Heating Oil</td> <td>mmbtu</td> <td>50%</td> <td>47,169</td> <td>47,169</td> <td>46,697</td> <td>0</td>	Heating Oil	mmbtu	50%	47,169	47,169	46,697	0			
Pasenger Vehicles mmbtu 895,928 851,132 385,249 0 Electricity MWh 0 2,585 29,471 51,703 Commercial Trucks Gasoline mmbtu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses Diesel mmbtu 16,028 15,323 8,014 0 Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 0 354 4,285 8,240 Totals Ilectricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 1,275,524 1,214,405 567,455	Transportation									
Gasoline mmbu 895,928 851,132 385,249 0 Electricity MWh 0 2,585 29,471 51,703 Commercial Trucks Gasoline mmbtu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses Diesel mmbtu 16,028 15,323 8,014 0 Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 848,855 840,271 590,660 0 Gasoline mmbtu 1,275,524 1,214,405 567,455 0 Diesel mmbtu 123,734 118,398 59,713 0 <td>Passenger Vehicles</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>	Passenger Vehicles									
Electricity MWh 0 2,585 29,471 51,703 Commercial Trucks Gasoline mmbuu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses Diesel mmbuu 16,028 15,323 8,014 0 Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbuu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbuu 405,536 401,751 291,359 0 Heating Oil mmbuu 848,855 840,271 590,660 0 Gasoline mmbuu 1,275,524 1,214,405 567,455 0 Diesel mmbuu 123,734 118,398 59,713 0 Total Energy Use mmbuu 3,046,084 2,994,184 2,282,672 <th1< td=""><td>Gasoline</td><td>mmbtu</td><td></td><td>895,928</td><td>851.132</td><td>385.249</td><td>0</td></th1<>	Gasoline	mmbtu		895,928	851.132	385.249	0			
Commercial Trucks Gasoline mmbtu $379,596$ $363,274$ $182,206$ 0 Electricity MWh 0 248 $2,993$ $5,756$ Buses Diesel mmbtu $16,028$ $15,323$ $8,014$ 0 Electricity MWh 0 84 954 $1,908$ Heavy-Duty Trucks Diesel mmbtu $107,707$ $103,075$ $51,699$ 0 Electricity MWh 0 354 $4,285$ $8,240$ Totals Electricity MWh $114,982$ $122,871$ $226,629$ $386,065$ Natural Gas mmbtu $405,536$ $401,751$ $291,359$ 0 Heating Oil mmbtu $4495,536$ $401,751$ $291,359$ 0 Gasoline mmbtu $1,275,524$ $1,214,405$ $567,455$ 0 Diesel mmbtu $123,734$ $118,398$ $59,713$ 0 Total Energy Use mmbtu $3,046,084$ $2,994,184$ $2,282,672$	Electricity	MWh		0	2,585	29,471	51,703			
Gasoline mmbtu 379,596 363,274 182,206 0 Electricity MWh 0 248 2,993 5,756 Buses Diesel mmbtu 16,028 15,323 8,014 0 Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 405,536 401,751 291,359 0 Gasoline mmbtu 1,275,524 1,214,405 567,455 0 Diesel mmbtu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642	Commercial Trucks									
Electricity MWh 0 248 2,993 5,756 Buses Diesel mmbtu 16,028 15,323 8,014 0 Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 848,855 840,271 590,660 0 Gasoline mmbtu 1,275,524 1,214,405 567,455 0 Diesel mmbtu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0 <td>Gasoline</td> <td>mmbtu</td> <td></td> <td>379,596</td> <td>363,274</td> <td>182,206</td> <td>0</td>	Gasoline	mmbtu		379,596	363,274	182,206	0			
Buses Diesel mmbtu 16,028 15,323 8,014 0 Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 848,855 840,271 590,660 0 Gasoline mmbtu 1,275,524 1,214,405 567,455 0 Diesel mmbtu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Electricity	MWh		0	248	2,993	5,756			
Diesel mmbtu 16,028 15,323 8,014 0 Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 848,855 840,271 590,660 0 Gasoline mmbtu 1,275,524 1,214,405 567,455 0 Diesel mmbtu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Buses									
Electricity MWh 0 84 954 1,908 Heavy-Duty Trucks Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 848,855 840,271 590,660 0 Gasoline mmbtu 1,275,524 1,214,405 567,455 0 Diesel mmbtu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Diesel	mmbtu		16,028	15,323	8,014	0			
Heavy-Duty Trucks Diesel mmbu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbu 405,536 401,751 291,359 0 Heating Oil mmbu 848,855 840,271 590,660 0 Gasoline mmbu 1,275,524 1,214,405 567,455 0 Diesel mmbu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Electricity	MWh		0	84	954	1,908			
Diesel mmbtu 107,707 103,075 51,699 0 Electricity MWh 0 354 4,285 8,240 Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 848,855 840,271 590,660 0 Gasoline mmbtu 1,275,524 1,214,405 567,455 0 Diesel mmbtu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Heavy-Duty Trucks									
ElectricityMWh03544,2858,240TotalsElectricityMWh114,982122,871226,629386,065Natural Gasmmbtu405,536401,751291,3590Heating Oilmmbtu848,855840,271590,6600Gasolinemmbtu1,275,5241,214,405567,4550Dieselmmbtu123,734118,39859,7130Total Energy Usemmbtu3,046,0842,994,1842,282,6721,317,642Total CO2 Emissionstons230,892217,509136,6080	Diesel	mmbtu		107,707	103,075	51,699	0			
Totals Electricity MWh 114,982 122,871 226,629 386,065 Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 848,855 840,271 590,660 0 Gasoline mmbtu 1,275,524 1,214,405 567,455 0 Diesel mmbtu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Electricity	MWh		0	354	4,285	8,240			
ElectricityMWh114,982122,871226,629386,065Natural Gasmmbtu405,536401,751291,3590Heating Oilmmbtu848,855840,271590,6600Gasolinemmbtu1,275,5241,214,405567,4550Dieselmmbtu123,734118,39859,7130Total Energy Usemmbtu3,046,0842,994,1842,282,6721,317,642Total CO2 Emissionstons230,892217,509136,6080	Totals									
Natural Gas mmbtu 405,536 401,751 291,359 0 Heating Oil mmbtu 848,855 840,271 590,660 0 Gasoline mmbtu 1,275,524 1,214,405 567,455 0 Diesel mmbtu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Electricity	MWh		114,982	122,871	226,629	386,065			
Heating Oil mmbu 848,855 840,271 590,660 0 Gasoline mmbu 1,275,524 1,214,405 567,455 0 Diesel mmbu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Natural Gas	mmbtu		405.536	401.751	291.359	0			
Gasoline mmbtu 1,275,524 1,214,405 567,455 0 Diesel mmbtu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Heating Oil	mmbtu		848.855	840.271	590.660	Ő			
Diesel mmbtu 123,734 118,398 59,713 0 Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Gasoline	mmbtu		1,275.524	1,214.405	567.455	Ő			
Total Energy Use mmbtu 3,046,084 2,994,184 2,282,672 1,317,642 Total CO2 Emissions tons 230,892 217,509 136,608 0	Diesel	mmbtu		123.734	118.398	59.713	Ő			
Total CO2 Emissions tons 230,892 217,509 136,608 0	Total Energy Use	mmbtu		3,046.084	2,994.184	2,282.672	1,317.642			
	Total CO2 Emissions	tons		230,892	217,509	136,608	0			

Table B - 19Total Energy Use and Emissions – Saco

Energy Use Table		City of								
		Scarborough								
Class / End-Use										
Residential		Share	2020	2030	2040	2050				
Electricity	MWh		76,577	80,218	140,146	235,203				
Heating	mmbtu		1,142,336	1,129,770	765,365	0				
Natural Gas	mmbtu	10%	114,234	112,977	76,536	0				
Heating Oil	mmbtu	90%	1,028,102	1,016,793	688,828	0				
Commercial										
Electricity	MWh		65,037	66,040	79,574	110,035				
Heating	mmbtu		212,848	210,507	142,608	0				
Natural Gas	mmbtu	30%	63,854	63,152	42,783	0				
Heating Oil	mmbtu	70%	148,994	147,355	99,826	0				
Process	mmbtu		59,125	59,125	58,533	0				
Natural Gas	mmbtu	40%	23,650	23,650	23,413	0				
Heating Oil	mmbtu	60%	35,475	35,475	35,120	0				
Industrial										
Electricity	MWh		27,789	28,157	33,698	91,652				
Heating	mmbtu		83,368	82,451	55,857	0				
Natural Gas	mmbtu	50%	41,684	41,226	27,928	0				
Heating Oil	mmbtu	50%	41,684	41,226	27,928	0				
Process	mmbtu		231,579	231,579	229,263	0				
Natural Gas	mmbtu	50%	115,789	115,789	114,631	0				
Heating Oil	mmbtu	50%	115,789	115,789	114,631	0				
Transportation										
Passenger Vehicles										
Gasoline	mmbtu		916,084	870,280	393,916	0				
Electricity	MWh		0	2,643	30,134	52,866				
Commercial Trucks										
Gasoline	mmbtu		388,640	371,929	186,547	0				
Electricity	MWh		0	253	3,065	5,893				
Buses										
Diesel	mmbtu		15,387	14,710	7,693	0				
Electricity	MWh		0	81	916	1,832				
Heavy-Duty Trucks										
Diesel	mmbtu		110,271	105,529	52,930	0				
Electricity	MWh		0	363	4,387	8,437				
Totals										
Electricity	MWh		169,403	177,756	291,920	505,919				
Natural Gas	mmbtu		359,211	356,794	285,292	0				
Heating Oil	mmbtu		1,370,044	1,356,638	966,334	0				
Gasoline	mmbtu		1,304,724	1,242,208	580,463	0				
Diesel	mmbtu		125,658	120,239	60,623	0				
Total Energy Use	mmbtu		3,737,811	3,682,558	2,889,035	1,726,701				
Total CO2 Emissions	tons	_	286,190	268,382	174,118	0				

Table B - 20 Total Energy Use and Emissions – Scarborough

Table B - 21	Total Energy	Use and Emissions	- South Portland
--------------	--------------	-------------------	------------------

Energy Use Table			City of South Portland						
Class / End-Use									
Residential		Share	2020	2030	2040	2050			
Electricity	MWh		59,915	63,694	120,245	202,579			
Heating	mmbtu		893,777	883,945	598,830	0			
Natural Gas	mmbtu	27%	241,320	238,665	161,684	0			
Heating Oil	mmbtu	73%	652,457	645,280	437,146	0			
Commercial									
Electricity	MWh		130,092	131,560	152,914	208,799			
Heating	mmbtu		425,754	421,071	285,255	0			
Natural Gas	mmbtu	55%	234,165	231,589	156,890	0			
Heating Oil	mmbtu	45%	191,589	189,482	128,365	0			
Process	mmbtu		118,265	118,265	117,082	0			
Natural Gas	mmbtu	55%	65,046	65,046	64,395	0			
Heating Oil	mmbtu	45%	53,219	53,219	52,687	0			
Industrial									
Electricity	MWh		51,368	51.909	60.686	166,498			
Heating	mmbtu		154,103	152.408	103.249	0			
Natural Gas	mmbtu	70%	107.872	106 686	72.274	0			
Heating Oil	mmbtu	30%	46.231	45 722	30,975	ů 0			
Process	mmbtu	5070	428.065	428.065	423 784	ů 0			
Natural Gas	mmbtu	70%	299.645	299 645	296 649	ů 0			
Heating Oil	mmbtu	30%	128,419	128,419	127,135	0			
Transportation									
Passenger Vehicles									
Gasoline	mmbtu		1.152.391	1.094.772	495.528	0			
Electricity	MWh		0	3.325	37.907	66.503			
				0,0_0	0.97.01	,			
Commercial Trucks									
Gasoline	mmbtu		272,682	260,957	130,887	0			
Electricity	MWh		0	178	2,150	4,135			
Buses									
Diesel	mmbtu		30,773	29,419	15,387	0			
Electricity	MWh		0	161	1,832	3,664			
Heavy-Duty Trucks									
Diesel	mmbtu		173,741	166,270	83,396	0			
Electricity	MWh		0	572	6,912	13,292			
Totals									
Electricity	MWh		241,374	251,399	382,646	665,471			
Natural Gas	mmbtu		948,048	941,631	751,893	0			
Heating Oil	mmbtu		1,071,916	1,062,123	776,308	0			
Gasoline	mmbtu		1,425,074	1,355,729	626,416	0			
Diesel	mmbtu		204,515	195,690	98,782	0			
Total Energy Use	mmbtu		4,473,361	4,413,195	3,559,371	2,271,252			
Total CO2 Emissions	tons	-	330,425	306,759	201,869	0			

Westbrook Class / End-Use Residential Share 2020 2030 2040 Electricity MWh 46,854 49,566 91,258 468,294 Natural Gas mmbu 50% 349,473 345,629 234,147 Heating Oil mmbu 50% 349,473 345,629 234,147 Commercial Electricity MWh 40,050 40,650 48,742 Heating Oil mmbu 50% 85,197 84,260 57,082 Heating Oil mmbu 35% 85,197 84,260 36,409 36,409 36,409 36,405 Natural Gas mmbu 35% 12,743 12,616 164 164 164 164 12,743 12,616 164 164 164 164 164 164 164 164 12,24 12,868 82,500 184,102 152,335 103,200 Natural Gas mmbu 184,029 152,335 103,200		f	City of	Energy Use Table				
Class / End-Use Share 2020 2030 2040 Electricity MWh 46,854 49,566 91,288 Heating mmbu 698,947 691,258 466,294 Natural Gas mmbu 50% 349,473 345,629 234,147 Heating Oil mmbu 50% 349,473 345,629 234,147 Commercial U Electricity MWh 40,050 48,742 Heating Oil mmbu 50% 85,197 84,260 57,082 Heating Oil mmbu 35% 45,875 45,371 30,736 Process mmbu 65% 23,666 23,466 23,666 23,429 Heating Oil mmbu 35% 12,743 12,743 12,616 Industrial Electricity MWh 51,343 51,606 58,417 Heating Oil mmbu 80% 123,224 121,868 82,560 Natural Gas mmbu 20% 30,806 </th <th></th> <th>ok</th> <th>Westbroo</th> <th></th> <th></th>		ok	Westbroo					
Residential Share 2020 2030 2040 Electricity MWh 46,854 49,566 91,288 Heating mmbu 50% 349,473 345,629 234,147 Heating Oil mmbu 50% 349,473 345,629 234,147 Heating Oil mmbu 50% 349,473 345,629 234,147 Commercial Electricity MWh 40,050 40,650 48,742 Hating mmbu 131,072 129,630 48,781 307,36 Process mmbu 35% 45,875 45,371 30,736 Process mmbu 36,409 36,409 36,405 36,405 Natural Gas mmbu 35% 12,743 12,616 Industrial Electricity MWh 51,343 51,696 58,417 Heating Oil mmbu 20% 30,806 30,467 20,640 Process mmbu 20% 308,065 342,288 338,865 </th <th></th> <th></th> <th></th> <th></th> <th></th> <th></th> <th>Class / End-Use</th>							Class / End-Use	
Electricity MWh 46,854 49,566 91,288 Heating mmbu 698,947 691,228 468,294 Natural Gas mmbu 50% 349,473 345,629 234,147 Heating Oil mmbu 50% 349,473 345,629 234,147 Commercial Electricity MWh 40,050 40,650 48,742 Heating mmbu 53% 85,197 84,260 57,082 Heating Oil mmbu 35% 45,875 45,371 30,736 Process mmbu 36,409 36,409 36,045 Natural Gas 12,743 12,743 12,616 Industrial Electricity MWh 51,343 51,696 58,417 Heating Oil mmbu 35% 12,743 12,743 12,616 Industrial Electricity MWh 51,343 51,696 58,417 Heating Oil mmbu 20% 30,806 30,467 20,640 Process	2050	2040	2030	2020	Share		Residential	
Heating mmbu 698,947 691,258 468,294 Natural Gas mmbu 50% 349,473 345,629 234,147 Heating Oil mmbu 50% 349,473 345,629 234,147 Commercial 234,147 345,629 234,147 Heating Oil mmbu 50% 349,473 345,629 234,147 Commercial 131,072 129,630 87,818 Natural Gas mmbu 65% 85,197 84,260 57,082 Heating Oil mmbu 35% 45,875 45,371 30,736 Process mmbu 65% 23,666 23,429 14,216 Industrial Electricity MWh 51,343 51,696 58,417 Heating Oil mmbu 80% 123,224 12,743 12,616 Industrial 303,407 20,640 30,407 20,640 Process mmbu 20% <td>153,691</td> <td>91,288</td> <td>49,566</td> <td>46,854</td> <td></td> <td>MWh</td> <td>Electricity</td>	153,691	91,288	49,566	46,854		MWh	Electricity	
Natural Gas mmbu 50% 349,473 345,629 234,147 Heating Oil mmbu 50% 349,473 345,629 234,147 Commercial Electricity MWh 40,050 40,650 48,742 Heating mmbu 131,072 129,630 87,818 Natural Gas 85,197 84,260 57,082 Heating Oil mmbu 35% 45,875 45,371 30,736 Process mmbu 35% 23,666 23,409 36,409 36,409 36,409 36,405 Natural Gas mmbu 35% 12,743 12,743 12,616 Industrial Electricity MWh 51,343 51,696 58,417 Heating Oil mmbu 154,029 152,335 103,200 Natural Gas mmbu 154,029 152,335 103,200 Natural Gas mmbu 20% 30,806 30,467 20,640 Process mmbu 20% 35,572 85,572 85,57	0	468,294	691,258	698,947		mmbtu	Heating	
Heating Oil mmbua 50% 349,473 345,629 234,147 Commercial Electricity MWh 40,050 40,650 48,742 Heating mmbua 131,072 129,630 87,818 Natural Gas mmbua 65% 85,197 84,260 57,082 Heating Oil mmbua 35% 45,875 45,371 30,736 Process mmbua 35% 23,666 23,666 23,429 Heating Oil mmbua 35% 12,743 12,743 12,616 Industrial Electricity MWh 51,343 51,696 58,417 Heating Oil mmbua 154,029 152,335 103,200 Natural Gas mmbua 20% 30,806 30,467 20,640 Process mmbua 20% 342,288 338,865 Heating Oil mmbua 20% 85,572 85,572 84,716 Transportation Electricity MWh 0 2,220 25,307 </td <td>0</td> <td>234,147</td> <td>345,629</td> <td>349,473</td> <td>50%</td> <td>mmbtu</td> <td>Natural Gas</td>	0	234,147	345,629	349,473	50%	mmbtu	Natural Gas	
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	0	234,147	345,629	349,473	50%	mmbtu	Heating Oil	
Electricity MWh $40,050$ $40,650$ $48,742$ Heating mmbu $131,072$ $122,630$ $87,818$ Natural Gas mmbu 55% $85,197$ $84,260$ $57,082$ Heating Oil mmbu 35% $45,875$ $45,371$ $30,736$ Process mmbu 35% $42,640$ $36,409$ $36,400$ $36,400$ $36,400$ $36,400$ $427,859$ $427,859$ $427,859$							Commercial	
Heating mmbu $131,072$ $129,630$ $87,818$ Natural Gas mmbu 65% $85,197$ $84,260$ $57,082$ Heating Oil mmbu 35% $45,875$ $45,571$ $30,736$ Process mmbu $36,409$ $36,409$ $36,409$ $36,409$ Natural Gas mmbu 65% $23,666$ $23,666$ $23,429$ Heating Oil mmbu 35% $12,743$ $12,743$ $12,616$ Industrial Electricity MWh $51,343$ $51,696$ $58,417$ Heating mmbu 35% $12,743$ $12,743$ $12,616$ Industrial Electricity MWh $51,343$ $51,696$ $58,417$ Heating mmbu 80% $123,224$ $121,868$ $82,560$ Natural Gas mmbu 20% $308,863$ $342,288$ $342,288$ $338,865$ Natural Gas mmbu 20% $85,572$ $85,572$ $83,572$ <	66,997	48,742	40,650	40,050		MWh	Electricity	
Natural Gas mmbu 65% 85,197 84,260 57,082 Heating Oil mmbu 35% 45,875 45,371 30,736 Process mmbu 36,409 36,409 36,409 36,401 Natural Gas mmbu 65% 23,666 23,429 12,743 12,743 12,743 Industrial Electricity MWh 51,343 51,696 58,417 Heating Oil mmbu 35% 12,743 12,743 10,200 Natural Gas mmbu 154,029 152,335 103,200 Natural Gas mmbu 20% 30,806 30,467 20,640 Process mmbu 20% 30,806 30,467 20,640 Process mmbu 20% 30,806 30,467 20,640 Process mmbu 20% 35,572 85,572 84,716 Transportation gasoline mmbu 20% 85,572 85,572 84,716 Electricity <td>0</td> <td>87,818</td> <td>129,630</td> <td>131,072</td> <td></td> <td>mmbtu</td> <td>Heating</td>	0	87,818	129,630	131,072		mmbtu	Heating	
Heating Oil mmbu 35% $45,875$ $45,371$ $30,736$ Process mmbu 65% $23,666$ $23,640$ $36,449$ Natural Gas mmbu 65% $23,666$ $23,666$ $23,429$ Heating Oil mmbu 35% $12,743$ $12,743$ $12,616$ Industrial Electricity MWh $51,343$ $51,696$ $58,417$ Heating mmbu $154,029$ $152,335$ $103,200$ Natural Gas mmbu 80% $123,224$ $121,868$ $82,560$ Heating Oil mmbu 20% $30,806$ $30,467$ $20,640$ Process mmbu 20% $30,806$ $34,27859$ $423,851$ Natural Gas mmbu 20% $35,572$ $85,572$ $85,572$ $84,716$ Transportation Paseenger Vehicles Gasoline mmbu 20% $25,307$ Commercial Trucks Gasoline mmbu $301,260$ $288,306$	0	57,082	84,260	85,197	65%	mmbtu	Natural Gas	
Process mmbu 36,409 36,409 36,409 36,045 Natural Gas mmbu 65% 23,666 23,666 23,429 Heating Oil mmbu 35% 12,743 12,743 12,616 Industrial Electricity MWh 51,343 51,696 58,417 Heating mmbu 154,029 152,335 103,200 Natural Gas mmbu 80% 123,224 121,868 82,560 Heating Oil mmbu 20% 30,806 30,467 20,640 Process mmbu 20% 342,288 342,288 338,865 Heating Oil mmbu 20% 85,572 85,572 84,716 Transportation Passenger Vehicles Gasoline mmbu 20% 85,572 85,306 144,605 Electricity MWh 0 196 2,376 80,2366 144,605 Electricity MWh 0 0 0 0 0 <td>0</td> <td>30,736</td> <td>45,371</td> <td>45,875</td> <td>35%</td> <td>mmbtu</td> <td>Heating Oil</td>	0	30,736	45,371	45,875	35%	mmbtu	Heating Oil	
Natural Gas mmbu 65% $23,666$ $23,666$ $23,429$ Heating Oil mmbu 35% $12,743$ $12,743$ $12,743$ $12,616$ Industrial Electricity MWh $51,343$ $51,696$ $58,417$ Heating mmbu $154,029$ $152,335$ $103,200$ Natural Gas mmbu 80% $123,224$ $121,868$ $82,560$ Heating Oil mmbu 20% $30,806$ $30,467$ $20,640$ Process mmbu $427,859$ $427,859$ $423,581$ Natural Gas mmbu 80% $342,288$ $338,865$ Heating Oil mmbu 20% $85,572$ $85,572$ $84,716$ Transportation Passenger Vehicles Gasoline mmbu $769,350$ $730,882$ $330,820$ Electricity MWh 0 196 $2,376$ Buses Diesel mmbu 0 0	0	36,045	36,409	36,409		mmbtu	Process	
Heating Oil mmbu 35% 12,743 12,743 12,616 Industrial Electricity MWh 51,343 51,606 58,417 Heating mmbu 154,029 152,335 103,200 Natural Gas mmbu 80% 123,224 121,868 82,560 Heating Oil mmbu 20% 30,806 30,467 20,640 Process mmbu 427,859 422,859 423,581 Natural Gas mmbu 80% 342,288 338,865 Heating Oil mmbu 20% 85,572 85,572 84,716 Transportation Passenger Vehicles 308,800 24,716 30,820 25,307 Commercial Trucks Gasoline mmbu 301,260 288,306 144,605 Electricity MWh 0 0 0 0 Buses Diesel mmbu 40,160 44,175 22,157 Electricity MWh 0 152 1,836 <t< td=""><td>0</td><td>23,429</td><td>23,666</td><td>23,666</td><td>65%</td><td>mmbtu</td><td>Natural Gas</td></t<>	0	23,429	23,666	23,666	65%	mmbtu	Natural Gas	
Industrial Electricity MWh 51,343 51,696 58,417 Heating mmbtu 154,029 152,335 103,200 Natural Gas mmbtu 80% 123,224 121,868 82,560 Heating Oil mmbtu 20% 30,806 30,467 20,640 Process mmbtu 427,859 427,859 423,581 Natural Gas mmbtu 80% 342,288 338,865 Heating Oil mmbtu 80% 342,288 338,865 Heating Oil mmbtu 20% 85,572 85,572 84,716 Transportation Passenger Vehicles Gasoline mmbtu 769,350 730,882 330,820 Electricity MWh 0 2,220 25,307 Commercial Trucks gasoline mmbtu 301,260 288,306 144,605 Electricity MWh 0 196 2,376 Buses Diesel mmbtu 46,160 44,175	0	12,616	12,743	12,743	35%	mmbtu	Heating Oil	
Electricity MWh 51,343 51,696 58,417 Heating mmbu 154,029 152,335 103,200 Natural Gas mmbu 80% 123,224 121,868 82,560 Heating Oil mmbu 20% 30,806 30,467 20,640 Process mmbu 427,859 427,859 423,581 Natural Gas mmbu 80% 342,288 338,865 Heating Oil mmbu 20% 85,572 85,572 84,716 Transportation Possenger Vehicles 330,820 25,307 84,716 Transportation Passenger Vehicles 330,820 25,307 Gasoline mmbu 769,350 730,882 330,820 Electricity MWh 0 2,220 25,307 Commercial Trucks Gasoline mmbu 301,260 288,306 144,605 Electricity MWh 0 0 0 0 0 Heavy-Duty Trucks Diesel							Industrial	
Heating mmbu 154,029 152,335 103,200 Natural Gas mmbu 80% 123,224 121,868 82,560 Heating Oil mmbu 20% 30,806 30,467 20,640 Process mmbu 427,859 427,859 423,581 Natural Gas mmbu 80% 342,288 342,288 338,865 Heating Oil mmbu 20% 85,572 85,572 84,716 Transportation Passenger Vehicles Gasoline mmbu 769,350 730,882 330,820 Electricity MWh 0 2,220 25,307 Commercial Trucks Gasoline mmbu 301,260 288,306 144,605 Electricity MWh 0 196 2,376 Buses Diesel mmbu 0 0 0 Diesel mmbu 46,160 44,175 22,157 Electricity MWh 0 152 1,836	162,229	58,417	51,696	51,343		MWh	Electricity	
Natural Gas mmbtu 80% 123,224 121,868 82,560 Heating Oil mmbtu 20% 30,806 30,467 20,640 Process mmbtu 427,859 423,581 423,581 423,581 Natural Gas mmbtu 80% 342,288 342,288 338,865 Heating Oil mmbtu 20% 85,572 85,572 84,716 Transportation Passenger Vehicles Gasoline mmbtu 769,350 730,882 330,820 Electricity MWh 0 2,220 25,307 Commercial Trucks Gasoline mmbtu 301,260 288,306 144,605 Electricity MWh 0 196 2,376 Buses Diesel mmbtu 0 0 0 Heavy-Duty Trucks Diesel mmbtu 46,160 44,175 22,157 Electricity MWh 0 152 1,836	0	103,200	152,335	154,029		mmbtu	Heating	
Heating Oil mmbu 20% $30,806$ $30,467$ $20,640$ Process mmbu $427,859$ $427,859$ $423,581$ Natural Gas mmbu 80% $342,288$ $3342,288$ $338,865$ Heating Oil mmbu 20% $85,572$ $85,572$ $84,716$ Transportation Passenger Vehicles Gasoline mmbu $769,350$ $730,882$ $330,820$ Electricity MWh 0 $2,220$ $25,307$ Commercial Trucks Gasoline mmbu $301,260$ $288,306$ $144,605$ Electricity MWh 0 196 $2,376$ Buses Diesel mmbu 0 0 0 Heavy-Duty Trucks mmbu $46,160$ $44,175$ $22,157$ Electricity MWh 0 152 $1,836$	0	82,560	121,868	123,224	80%	mmbtu	Natural Gas	
Process mmbu 427,859 427,859 423,581 Natural Gas mmbu 80% 342,288 342,288 338,865 Heating Oil mmbu 20% 85,572 85,572 84,716 Transportation Passenger Vehicles Gasoline mmbu 769,350 730,882 330,820 Electricity MWh 0 2,220 25,307 25,307 Commercial Trucks Gasoline mmbu 301,260 288,306 144,605 Electricity MWh 0 196 2,376 Buses Diesel mmbu 0 0 0 Heavy-Duty Trucks MWh 0 10 0 0 Electricity MWh 0 152 1,836	0	20,640	30,467	30,806	20%	mmbtu	Heating Oil	
Natural Gas mmbtu 80% 342,288 342,288 342,288 338,865 Heating Oil mmbtu 20% 85,572 85,572 84,716 Transportation Passenger Vehicles Gasoline mmbtu 769,350 730,882 330,820 Electricity MWh 0 2,220 25,307 Commercial Trucks Gasoline mmbtu 301,260 288,306 144,605 Electricity MWh 0 196 2,376 Buses Diesel mmbtu 0 0 0 Heavy-Duty Trucks MWh 0 0 0 Heavy-Duty Trucks mmbtu 46,160 44,175 22,157 Electricity MWh 0 152 1,836	0	423,581	427,859	427,859		mmbtu	Process	
Heating Oil mmbu 20% 85,572 85,572 84,716 Transportation Passenger Vehicles Gasoline mmbu 769,350 730,882 330,820 Electricity MWh 0 2,220 25,307 Commercial Trucks mmbu 301,260 288,306 144,605 Electricity MWh 0 196 2,376 Buses mmbu 0 0 0 0 Electricity MWh 0 0 0 0 Heavy-Duty Trucks mmbu 46,160 44,175 22,157 144,480 227.027 Totals Electricity MWh 0 152 1,836	0	338,865	342,288	342,288	80%	mmbtu	Natural Gas	
TransportationPassenger VehiclesGasolinemmbtu769,350730,882330,820ElectricityMWh02,22025,307Commercial TrucksGasolinemmbtu301,260288,306144,605ElectricityMWh01962,376BusesDieselmmbtu000ElectricityMWh000Heavy-Duty Trucksmmbtu46,16044,17522,157ElectricityMWh01521,836Totals	0	84,716	85,572	85,572	20%	mmbtu	Heating Oil	
Passenger VehiclesGasolinemmbu769,350730,882330,820ElectricityMWh02,22025,307Commercial TrucksGasolinemmbu301,260288,306144,605ElectricityMWh01962,376BusesDieselmmbu000ElectricityMWh000Heavy-Duty Trucksmmbu46,16044,17522,157ElectricityMWh01521,836Totals							Transportation	
Gasoline mmbu 769,350 730,882 330,820 Electricity MWh 0 2,220 25,307 Commercial Trucks Gasoline mmbtu 301,260 288,306 144,605 Electricity MWh 0 196 2,376 Buses Diesel mmbtu 0 0 0 0 Heavy-Duty Trucks MWh 0 0 0 0 0 Heavy-Duty Trucks mmbtu 46,160 44,175 22,157 1,836 Totals Electricity MWh 128,247 144,490 227,076							Passenger Vehicles	
ElectricityMWh02,22025,307Commercial Trucks Gasolinemmbtu301,260288,306144,605ElectricityMWh01962,376Buses Dieselmmbtu000ElectricityMWh000Heavy-Duty Trucks Dieselmmbtu46,16044,17522,157ElectricityMWh01521,836Totals	0	330,820	730,882	769,350		mmbtu	Gasoline	
Commercial Trucks Gasoline mmbtu 301,260 288,306 144,605 Electricity MWh 0 196 2,376 Buses Diesel mmbtu 0 0 0 Electricity MWh 0 0 0 0 Heavy-Duty Trucks MWh 0 0 0 0 Heavy-Duty Trucks mmbtu 46,160 44,175 22,157 Electricity MWh 0 152 1,836	44,398	25,307	2,220	0		MWh	Electricity	
Gasoline mmbu 301,260 288,306 144,605 Electricity MWh 0 196 2,376 Buses Diesel mmbu 0 0 0 0 Electricity MWh 0 0 0 0 0 Heavy-Duty Trucks Diesel mmbtu 46,160 44,175 22,157 Electricity MWh 0 152 1,836							Commercial Trucks	
Electricity MWh 0 196 2,376 Buses Diesel mmbtu 0 0 0 Electricity MWh 0 0 0 Heavy-Duty Trucks Diesel mmbtu 46,160 44,175 22,157 Electricity MWh 0 152 1,836	0	144,605	288,306	301,260		mmbtu	Gasoline	
Buses 0 0 0 Diesel mmbtu 0 0 0 Electricity MWh 0 0 0 Heavy-Duty Trucks Diesel mmbtu 46,160 44,175 22,157 Electricity MWh 0 152 1,836	4,568	2,376	196	0		MWh	Electricity	
Diesel mmbu 0 0 0 Electricity MWh 0 0 0 Heavy-Duty Trucks Diesel mmbu 46,160 44,175 22,157 Electricity MWh 0 152 1,836 Totals Electricity MWh 128,247 144,480 227,076							Buses	
Electricity MWh 0 0 0 Heavy-Duty Trucks Diesel mmbtu 46,160 44,175 22,157 Electricity MWh 0 152 1,836	0	0	0	0		mmbtu	Diesel	
Heavy-Duty Trucks Diesel mmbtu 46,160 44,175 22,157 Electricity MWh 0 152 1,836	0	0	0	0		MWh	Electricity	
Diesel mmbtu 46,160 44,175 22,157 Electricity MWh 0 152 1,836							Heavy-Duty Trucks	
Electricity MWh 0 152 1,836 Totals Electricity 138.247 144.480 227.044	0	22,157	44,175	46,160		mmbtu	Diesel	
Totals	3,532	1,836	152	0		MWh	Electricity	
Electricity MWA 120 247 144 400 227 077							Totals	
EACCHICHY NWN 130,24/ 144,400 22/,900	435,415	227,966	144,480	138,247		MWh	Electricity	
Natural Gas mmbtu 923,847 917,710 736,083	0	736,083	917,710	923,847		mmbtu	Natural Gas	
Heating Oil mmbtu 524,470 519,782 382,855	0	382,855	519,782	524,470		mmbtu	Heating Oil	
Gasoline mmbtu 1,070,610 1,019,188 475,425	0	475,425	1,019,188	1,070,610		mmbtu	Gasoline	
Diesel mmbtu 46,160 44,175 22,157	0	22,157	44,175	46,160		mmbtu	Diesel	
Total Energy Use mmbtu 3,036,924 2,993,965 2,394,568	1,486,073	2,394,568	2,993,965	3,036,924		mmbtu	Total Energy Use	
Total CO2 Emissions tons 218,585 204,375 135,782	0	135,782	204,375	218,585		tons	Total CO2 Emissions	

Table B - 22 Total Energy Use and Emissions – Westbrook

Energy Use Table		City of							
			Windham						
Class / End-Use									
Residential		Share	2020	2030	2040	2050			
Electricity	MWh		73,947	77,116	131,340	220,011			
Heating	mmbtu		1,103,099	1,090,965	739,076	0			
Natural Gas	mmbtu	10%	110,310	109,096	73,908	0			
Heating Oil	mmbtu	90%	992,789	981,868	665,169	0			
Commercial									
Electricity	MWh		38,933	39,586	48,228	66,753			
Heating	mmbtu		127,416	126,014	85,369	0			
Natural Gas	mmbtu	20%	25,483	25,203	17,074	0			
Heating Oil	mmbtu	80%	101,933	100,811	68,295	0			
Process	mmbtu		35,393	35,393	35,039	0			
Natural Gas	mmbtu	20%	7,079	7,079	7,008	0			
Heating Oil	mmbtu	80%	28,315	28,315	28,031	0			
Industrial									
Electricity	MWh		1,435	1,597	3,396	7,700			
Heating	mmbtu		4,305	4,257	2,884	0			
Natural Gas	mmbtu	30%	1,291	1,277	865	0			
Heating Oil	mmbtu	70%	3,013	2,980	2,019	0			
Process	mmbtu		11,958	11,958	11,838	0			
Natural Gas	mmbtu	30%	3,587	3,587	3,551	0			
Heating Oil	mmbtu	70%	8,370	8,370	8,287	0			
Transportation									
Passenger Vehicles									
Gasoline	mmbtu		749,506	712,031	322,288	0			
Electricity	MWh		0	2,163	24,654	43,253			
Commercial Trucks									
Gasoline	mmbtu		265,034	253,638	127,216	0			
Electricity	MWh		0	173	2,090	4,019			
Buses									
Diesel	mmbtu		0	0	0	0			
Electricity	MWh		0	0	0	0			
Heavy-Duty Trucks									
Diesel	mmbtu		43,596	41,721	20,926	0			
Electricity	MWh		0	143	1,734	3,335			
Totals									
Electricity	MWh		114,314	120,778	211,443	345,072			
Natural Gas	mmbtu		147,750	146,242	102,406	0			
Heating Oil	mmbtu		1,134,420	1,122,345	771,800	0			
Gasoline	mmbtu		1,014,540	965,669	449,504	0			
Diesel	mmbtu		43,596	41,721	20,926	0			
Total Energy Use	mmbtu		2,730,460	2,688,192	2,066,291	1,177,730			
Total CO2 Emissions	tons	_	211,694	199,204	126,236	0			

Table B - 23 Total Energy Use and Emissions –Windham

Energy Use Table		City of							
		Yarmouth							
Class / End-Use									
Residential		Share	2020	2030	2040	2050			
Electricity	MWh		33,896	35,381	60,551	101,397			
Heating	mmbtu		505,640	500,078	338,779	0			
Natural Gas	mmbtu	10%	50,564	50,008	33,878	0			
Heating Oil	mmbtu	90%	455,076	450,070	304,901	0			
Commercial									
Electricity	MWh		19,126	19,415	23,297	32,029			
Heating	mmbtu		62,596	61,907	41,939	0			
Natural Gas	mmbtu	20%	12,519	12,381	8,388	0			
Heating Oil	mmbtu	80%	50,076	49,526	33,551	0			
Process	mmbtu		17,388	17,388	17,214	0			
Natural Gas	mmbtu	20%	3,478	3,478	3,443	0			
Heating Oil	mmbtu	80%	13,910	13,910	13,771	0			
Industrial									
Electricity	MWh		10,887	10,987	12,666	34,873			
Heating	mmbtu		32,662	32,303	21,883	0			
Natural Gas	mmbtu	30%	9,799	9,691	6,565	0			
Heating Oil	mmbtu	70%	22,863	22,612	15,318	0			
Process	mmbtu		90,727	90,727	89,820	0			
Natural Gas	mmbtu	30%	27,218	27,218	26,946	0			
Heating Oil	mmbtu	70%	63,509	63,509	62,874	0			
Transportation									
Passenger Vehicles									
Gasoline	mmbtu		372,022	353,421	159,969	0			
Electricity	MWh		0	1,073	12,237	21,469			
Commercial Trucks									
Gasoline	mmbtu		62,011	59,344	29,765	0			
Electricity	MWh		0	40	489	940			
Buses									
Diesel	mmbtu		0	0	0	0			
Electricity	MWh		0	0	0	0			
Heavy-Duty Trucks									
Diesel	mmbtu		13,463	12,884	6,462	0			
Electricity	MWh		0	44	536	1,030			
Totals									
Electricity	MWh		63,909	66,941	109,777	191,739			
Natural Gas	mmbtu		103,577	102,776	79,219	0			
Heating Oil	mmbtu		605,435	599,627	430,416	0			
Gasoline	mmbtu		434,033	412,765	189,735	0			
Diesel	mmbtu		13,463	12,884	6,462	0			
Total Energy Use	mmbtu		1,374,632	1,356,521	1,080,500	654,404			
Total CO2 Emissions	tons		105,930	99,436	65,675	0			

Table B - 24 Total Energy Use and Emissions – Yarmouth

Technical Appendix C Solar Irradiance Modeling

Introduction

The amount of energy contained in the light from the sun at each point on the earth is measured by its irradiance (direct and diffused) and often expressed in terms of watts per square meter. As discussed in more detail below, solar irradiance on any solar panel is highest when there is no cloud cover, when the sun's azimuth is the equal to the aspect of the solar panel, when the sun's zenith as measured from the horizon is equal to 90° minus the slope of the solar panel, where the surfaces around the solar panel are highly reflective of sunlight, and where the panel is free from dirt, snow or other cover (soiling effect). The solar irradiance model incorporates each of these factors as well as solar PV panel manufacturer specifications (panel dimensions, peak power, module efficiency) as it calculates hourly and annual electricity generation.

Data

Solar irradiance (SI) data was obtained from the NREL's Typical Meteorological Year 3 (TMY3) model. This model contains 24-years of low uncertainty measurements that are derived from the National Solar Radiation Data Base (NSRDB). This database contains daily and seasonal variations that "represent a year of typical climatic conditions" for a giving location.¹ Data is compiled from ground-based weather stations.² This data provides the best available measurements of direct, diffuse, and global solar radiation based on historical accurate data.

¹ <u>https://www.nrel.gov/docs/fy08osti/43156.pdf</u>

² <u>https://www.nrel.gov/docs/fy08osti/43156.pdf</u>

The data used in our modeling is from the Portland International Jetport station (United States Air Force station identifier 726060). This location is categorized as a Class I site. A Class I site denotes "the lowest uncertainty data" available, which means that less than 25% of the global field exceeded an uncertainty of 11%.³ This database and station classification are used as the solar energy standards for the industry according to NREL.

There are many solar photovoltaic devices that can be installed on rooftops to convert solar irradiance into electricity. These may use different technologies and have different performance characteristics. For our purposes, we used a standard solar PV panel – Panel LG360Q1C-A5. This panel is representative of many that are being installed today in Maine. It offers peak power generation of 360 watts, with an overall module efficiency of 21% under standard testing conditions. We understand that panels are now being installed that exceed the performance standards of the LG360. Further, we fully expect advances in technology and panel design to produce solar PV panels/systems that offer substantial improvements over those being installed today. As a result, our estimates of solar generation per panel are likely to understate future generation capabilities.

Data Formatting

The solar irradiance database was combined with the sun's hourly location as well as average hourly weather conditions (albedo, temperature, wind speed, etc.) from the NREL's Physical Solar Model (PSM) for the years 1998 to 2017. The PSM weather conditions are based on National Aeronautics and Space Administration (NASA) Modern-Era Retrospective analysis for Research and Applications.⁴ The sun's azimuth location was calculated as it progressed east to west across the sky

³ <u>https://www.nrel.gov/docs/fy08osti/43156.pdf</u>

⁴ <u>https://gmao.gsfc.nasa.gov/reanalysis/MERRA-2/</u>

by taking 360° (north denoted as $360^{\circ}/0^{\circ}$) and dividing it by the total amount of hours in a day (24 hours) to yield 15° per hour.

The database also integrates formulas to account for solar array configurations (slope, aspect) relative to the sun (zenith and azimuth), panel specifications (peak power performance, module efficiency, etc.), as well as environmental conditions (e.g., temperature, soiling) to calculate the Total Solar Irradiance ("TSI") available at any giving location, time, and position/orientation of the solar panel.

Calculating Total Solar Irradiance (TSI)

We used the zenith and azimuth values from NREL's database, as well as the direct and diffused irradiance, to calculate the total solar irradiance or TSI in watts per meter squared. The calculations account for both the sun's and panel's locations and orientations as well as the amount of diffused irradiance blocked by a panel's backside at any giving slope.⁵ TSI is the sum of Direct Solar Irradiance plus Diffused Solar Irradiance. The set of equations are presented below:

Direct Solar Irradiance (I_o) [W/m²] I = I_o (Sin(Θ_s) Sin(β) Cos($\Psi_s - \alpha$) + Cos(Θ_s) Cos(β) Diffused Solar Irradiance (I_{DIFFO}) [W/m²] I_{DIFF} = I_{DIFFO} (180° - β) / 180° Total Solar Irradiance [W/m²]

 $I_{TOTAL} = I_0 + I_{DIFF}$

Symbols: α is defined as the panel's azimuth angle, β as the panel's tilt angle, θ_s as the sun's zenith angle, and Ψ_s as the sun's azimuth angle. Sin is a function used in trigonometry to calculate a right angle's length (hypotenuse) while Cos is the adjacent side's length divided by the length of the hypotenuse.

⁵ <u>https://www.coursera.org/lecture/photovoltaic-solar-energy/worked-problem-total-irradiance-goG51</u>

The TSI of a panel is then calculated by multiplying its area (expressed in square meters) by the amount of TSI per square meter as determined above.

Solar Irradiance per Panel

(panel width * panel length) * TSI per meter squared

Ambient air temperatures and windchill adjusted temperatures affect solar PV cell and module performance by reducing or increasing its efficiency and total energy output. Both the ambient temperature and windspeed data are included in NREL's database and were used during our modeling. The formula used to calculate windchill was derived from the National Oceanic and Atmospheric Administration (NOAA).⁶ The ideal operating temperature for a panel was based on manufacturer's specifications (typically 25° C).

Windchill

 $Wc = 35.74 + (0.6215 * T) - (35.75 * Ws^{0.16}) + (0.4275 * T * Ws^{0.16})$ Symbols: Wc is defined as windchill, T as ambient temperature, and Ws as wind speed.

Converting Fahrenheit to Celsius $(1^{\circ}F - 32) * 5/9 = 17.22^{\circ}C$

Once windchill was determined, panel efficiency was calculated by taking the panel's specifications and using the following formula to account for the impact of effective air temperature on the panel. The following formula example is based on the LG360Q1C-A5 solar panel specifications.

⁶ <u>https://www.weather.gov/media/epz/wxcalc/windChill.pdf</u>

*Temperature Effect on Efficiency*⁷

Peak Power

 $P_{m} (360 \text{ W}_{p}) (1 + \frac{(-0.30) * (40^{\circ}C - 25^{\circ}C)}{100}) \text{ or } 360 (1 + ((-0.30) * (40 - 25)/100))$

Symbols: Pm stands for peak power, Wp for the panel's peak power in watts, and C represents either air temperature or the panel's standard operating temperature in Celsius.

Our modeling determined that module temperature does not play a significant role in the panel efficiency for Maine. Over the course of an entire year, there were only 5 hours (1 hour in July and 4 in August) where the panel's efficiency dropped below its peak performance rating of 360-watts. Even in these five hours, the maximum loss in performance was only 0.47 watts. This represents about one-tenth of one percent of total panel generation. However, this formula does not account for the panel's self-generated/retained heat.

Next, we looked at soiling effects. Soiling refers to the environmental factors that reduce power production. These include dust, snow, dirt, and other particles that cover a solar panel's module, thus reducing the amount of solar irradiance that can be collected. Each building will have different soiling characteristics, especially with respect to snow and ice coverings. As a simplifying assumption, we standardized soiling effects across the entire region and adopted ReVision Energy's percentage-based model. This model takes the panel's TSI, divides it by 100 (conversion to a percentage-based format), and then multiplies it by the average soiling percentages for each month shown in Table C - 1. As the percentages suggest, the most significant reductions are due to snow and ice accumulation on the panels during the winter months. However, since these occur during periods of the year when solar generation is otherwise low, total losses due to soiling are about 8.39% over the entire year.

⁷ <u>https://www.youtube.com/watch?v=jizCsQqg_OY</u>

Soiling Effects

panel TSI/100 * (100 - monthly soiling percentage)

Table C	-1 N	Aonthly So	oiling Co	efficients			
Laur	E.L	M	Δ	M	I	I1	Δ

Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec
14.4	31.5	4	4	4	4	4	4	4	4	4	26.1

Reflected Irradiance (Albedo)

Albedo irradiance measures the amount of sunlight that is reflected from the ground and other neighboring objects onto the panel. This monthly coefficient imbedded in NREL's hourly interval database was used to calculate the potential solar irradiance associated with reflectivity from nearby surfaces (ground and objects). According to the Sandia National Laboratories, Table C - 2 are the numeric values (from 0 [low reflectivity] to 1 [high reflectivity]) observed when measuring the albedo on different man-made and natural surfaces. NREL's albedo measurement accounts for hourly, daily, and seasonal change (e.g., winter, spring, summer, and autumn).

Table C - 2 Surface's Reflected Irradiance (Albedo) Coefficients

Urban environment 0.14-0.22	Concrete 0.25-0.35
Grass 0.15-0.25 / Fresh grass 0.26	Red tiles 0.33
Fresh snow 0.82	Aluminum 0.85
Wet snow 0.55-0.75	Copper 0.74
Dry asphalt 0.09-0.15	New galvanized steel 0.35
Wet Asphalt 0.18	Very dirty galvanized steel 0.08

It should be noted that NREL's values are derived from coarse resolution (4km x 4km) and therefore do not account for micro-environmental conditions.⁸ The following formula assumes that reflected irradiance is interacting with a horizontal surface, accounts for only the first scattering of

⁸ <u>https://pvpmc.sandia.gov/modeling-steps/1-weather-design-inputs/plane-of-array-poa-irradiance/calculating-poa-irradiance/poa-ground-reflected/albedo/</u>

light, and only measures light coming from directly in front of the panel (reflected irradiance from behind the panel is excluded). Reflected irradiance accounts for 8.03% of the total annual irradiance (46.58 kWh annually) with 56.90% of that occurring in the months of January, February, March, and December. This high monthly concentration is due to these months having a higher albedo value due to the high reflectivity of snow.

(albedo coefficient (diffused + direct irradiance on a horizontal surface) / 2) + TSI on a panel

Electricity Conversion (DC to AC)

We accounted for energy loss associated with the conversion of electricity from DC (direct current) to AC (alternating current) by using the manufacturer's inverter system specifications. This model uses the California Energy Commission's (CEC) inverter curves and a standard inverter efficiency of 94.5%.⁹ This percentage is applied to the TSI after all other inputs have been incorporated.

Calculating Solar Array Spacing

To calculate solar array interrow spacing on flat rooftops, we modified the Folsom Labs' Modeling formula to represent Maine's latitude.¹⁰ This formula was used when modeling panel spacing on flat roofs where panels are not restricted to a sloped surface (e.g., gabled roof). The Folsom Lab formula takes the panel's height (opposite [O]) and multiplies it by 2.3, at 35° north to get the required spacing to avoid casting shadows from one row to the next (interrow shadowing).

<u>https://pvpmc.sandia.gov/modeling-steps/dc-to-ac-conversion/cec-inverter-test-protocol/</u>

¹⁰ https://www.folsomlabs.com/modeling

This multiplication value was converted to Maine's latitude (45° north) by dividing 2.3 by 35° and then multiplying that value by 45° to get 2.95 as the new multiplier.¹¹

The 2.95 value is multiplied by the panel's height (opposite [O]) to give the necessary row spacing. To calculate the panel's height, its slope in degrees is first converted to Radians and then using the Cosine is multiplied by the panel's length (hypotenuse [H]).

Converting Degrees to RADIANS

Degrees * PI()/180° (one degree = 0.017453)

Calculating Panel's Height COS(RADIANS) * Hypotenuse

To calculate the amount of space a panel utilizes (adjacent [A]) at a specified angle, the

panel's slope in Radians is multiplied by the hypotenuse using the Sine formula.

Calculating Panel's Length at Set Angle

SIN(RADIANS) * Hypotenuse



¹¹ The latitude for Portland is closer to 43° than to 45°. However, the use of the higher latitude value reduces by a small amount the number of panels that can be placed on a flat roof, because it increases interrow spacing. We used this higher value to account for the inevitable irregularities in building roofs that must be accounted for in all solar PV installations.

The panel's length or width (depending on which side the panel is placed on, long or short edge) is then added to the interrow spacing measurement to derive the new dimensions required to ensure proper interrow spacing requirements between arrays. This model assumes all flat roof panels are placed on their long edge side.

System Degradation

System degradation is calculated by taking the manufacturer's production guarantee (typically guaranteed as 80% production after 25-years of service) and dividing the loss by the amount of years of service. The solar panel used in this analysis (LG360Q1C-A5) offers a 25-year product warranty of at least 88.4% of its initial power output (first 5 years: 95%; after the 5th year: 0.4% annual degradation; and at 25 years: 88.4%).¹² Because the model focuses only at a single point in time, we did not factor in system degradation.¹³

Results

Once all configuration and environmental attributes were incorporated, we calculated solar irradiance for every hour over the course of an entire year for a single panel placed on a horizontal plane (without factoring shadows). Figure C - 1 illustrates the monthly TSI potential for one panel on a horizontal surface prior to factoring shadows from buildings, trees, topography and other obstructions. The irradiance has been converted to kWh of electric generation for a single LG 360 panel. The alterations between peaks and valleys is representative of the sun's seasonal change in

¹² https://www.lg.com/us/business/solar-panel/all-products/lg-LG360Q1C-A5

¹³ We fully expect the reduced performance suffered as a result of system degradation will be more than offset by the increased performance of solar panels installed over the next 30 years, as noted in an earlier section of this Appendix.

location (zenith and azimuth) relative to the earth's tilt and location along its orbital path around the sun. The bars show the expected monthly kWh generation.



Figure C - 1 Monthly Solar Irradiance per Panel (179.0 cm x 101.6 cm)

Figure C - 2 shows average hourly TSI expressed in terms of kWh on the same horizontally positioned solar panel for an entire year. The graph illustrates the typical bell curve associated with the sun's relative position to the earth. Generation starts low in the morning when the sun is on the eastern horizon, rises to its maximum point midday when the sun is at its highest point in the sky, and then tails off in the evening as the sun descends below the western horizon.

The amount of TSI varies from hour to hour and season to season. For example, the hours from 8AM to 4PM account for 85.64% of total electricity generation, while 5AM to 7AM account for only 5.31% and 5PM to 7PM account for the remaining 9.05%. Seasonal generation varies due to total sunlight hours available during a given month. For example, the month of July experiences

a maximum of 14 hours of sunlight per day, while the months of January, November, and December see only 8 hours.



Figure C - 2 Annual Daily Average Solar Irradiance by Hour per Panel

The graphs in Figure C - 3 show average hourly generation for each month for the same horizontal panel. We truncate the hours to include only the period from 5 am to 7 pm. Below each graph, we show the percent of total solar generation for three-time intervals – 5 am to 8 am, 8 am to 5 pm and 5 pm to 7 pm, as well as the percent of total annual generation accounted for in each month.

Figure C - 3 Total Monthly Solar Irradiance by Hour



[Note: The vertical axis represents kWh and the horizontal axis time (24-hr)]



kWh monthly which accounts for 6.67% annually



0500-0700 accounts for **3.53%**, 0800-1600 for **89.67%**, and 1700-1900 for the remaining **6.78%** producing **60.97 kWh** monthly which accounts for **10.12%** annually



0500-0700 accounts for **8.76%**, 0800-1600 for **75.39%**, and 1700-1900 for the remaining **15.85%** producing **59.83 kWh** monthly which accounts for **9.93%** annually



0500-0700 accounts for **0.55%**, 0800-1600 for **95.33%**, and 1700-1900 for the remaining **4.12%** producing **37.30 kWh** monthly which accounts for **6.19%** annually



0500-0700 accounts for **6.66%**, 0800-1600 for **81.51%**, and 1700-1900 for the remaining **11.83%** producing **55.26 kWh** monthly which accounts for **9.17%** annually



0500-0700 accounts for **8.71%**, 0800-1600 for **74.63%**, and 1700-1900 for the remaining **16.66%** producing **54.41 kWh** monthly which accounts for **9.03%** annually

1

February

Figure C - 3 Total Monthly Solar Irradiance by Hour - Continued



[Note: The vertical axis represents kWh and the horizontal axis time (24-hr)]





0500-0700 accounts for 6.66%, 0800-1600 for 86.24%, and 1700-1900 for the remaining 7.10% producing 58.07 kWh monthly which accounts for 9.64% annually



0500-0700 accounts for 0.84%, 0800-1600 for 98.60%, and 1700-1900 for the remaining 0.56% producing 33.35 kWh monthly which accounts for 5.54% annually



0500-0700 accounts for 7.29%, 0800-1600 for 80.89%, and 1700-1900 for the remaining 11.82% producing 62.89 kWh monthly which accounts for 10.44% annually



0500-0700 accounts for 3.32%, 0800-1600 for 94.18%, and 1700-1900 for the remaining 2.50% producing 47.92

kWh monthly which accounts for 7.95% annually



0500-0700 accounts for 0.00%, 0800-1600 for 99.90%, and 1700-1900 for the remaining 0.10% producing 26.71 kWh monthly which accounts for 4.43% annually

13

Model Validation

We validated our model by comparing "real-world" results (in 15-minute intervals) of a PV array installation to GridSolar's estimates for the same configuration (number of panels, slope, aspect, etc.). The real-world configuration is illustrated below (6 panels at 180° aspect and 40° slope, 8 panels at 270° aspect and 30° slope, as well as 8 panels at 90° aspect and 30° slope). The PV array system is installed on Dr. Silkman's house located in Scarborough, Maine. The panels used in both the PV installation and GridSolar's model are the LG360Q1C-A5.

	Aspect 180° and Slope 40°	
an 100		Aspec
ct 270° and Slo		t 90° and Slope
Aspe		30°

Figure	С-	5	Case	Study	PV	Array	Syst	em
0				~		~	~	

The panels with a 180° aspect and 40° slope and those with 90° aspect and 30° slope receive uninterrupted sunlight (no shadows from neighboring buildings or trees) year-round. The panels with aspect of 270° receive shadows from a neighboring house to the west. The shading is highly seasonal. On the first day of winter, when the sun is at its lowest position in the sky, the shading is from approximately 2 pm to sundown. On the first day of summer when the sun is at its highest position in the sky, the shading is from 5pm to sundown. On all other days, shading varies between these two extremes based on the season.

During 2019, the PV installation produced 9,550.22 kWh while the estimated model predicted 11,673.85 kWh in generation. This represents for a difference of 2,123.63 kWh or an additional 18.19% in estimated PV generation. However, the months in which GridSolar overestimates generation potential (January to March and September to December) coincide with the sun's relatively low zenith values (the sun's lower position just above the horizon) due to the earth's seasonal tilt (see Figure C - 6, Table C - 3, and Table C - 4). During these months the shadowing effect is much higher on the installed array system, as mentioned earlier, which GridSolar's model does not factor as it does not account for object shading. This largely explains the difference between the real-world generation and GridSolar's estimate.

Figure C - 6 Monthly Solar Irradiance per PV Array



[Note: The green is the real-world readings while the blue is GridSolar's predicted amounts]

Months

When analyzing the average hourly production (total annual production by hour divided by 365) the shadow effect becomes more evident as the hours between 2 pm (1400) and 7 pm (1900) (see Figure C - 7) has a total difference of 1,879.57 kWh.



Figure C - 7 Annual Daily Average Solar Irradiance by Hour per PV Array

This means that after factoring generation loss due to shadows, the difference in PV generation is 244.06 kWh annually. Once the difference is factored into the comparison, our model's accuracy is estimated to be 97.51% (real-world generation divided by GridSolar estimated generation after factoring shadows), or an error of 2.49%. This difference can be the result of several environmental factors (shadowing, temperature, soiling, etc.) and does not constitute a statistically significant difference. However, it is more realistic to estimate the model's overall accuracy at 90% to 95% in order to account for seasonal variations (cloud cover, temperature, etc.).

Figure C - 8 shows the hourly averages by month for Silkman's solar PV system compared to the GridSolar model. It is important to note that when analyzing hourly generation on a monthly basis that months with intense shadows have a larger difference in generation in the evening hours.

Figure C - 8 Total Monthly Solar Irradiance by Hour

[Note: The vertical axis represents kWh and the horizontal axis time (24-hr) as well as the green representing the realworld readings while the blue is GridSolar's predicted amounts]



0500-0700 accounts for 2.20% (0.00%), 0800-1600 for 97.80% (98.93%), and 1700-1900 for the remaining 0.00% (1.07%) producing 402.89 kWh (792.84 kWh) monthly which accounts for 4.22% (6.79%) annually

March



0500-0700 accounts for 3.31% (3.47%), 0800-1600 for 95.53% (89.88%), and 1700-1900 for the remaining 1.16% (6.65%) producing 940.92 kWh (1198.35 kWh) monthly which accounts for 9.85% (12.55%) annually

May



⁰⁵⁰⁰⁻⁰⁷⁰⁰ accounts for 5.54% (8.65%), 0800-1600 for 89.10% (75.74%), and 1700-1900 for the remaining



February

0500-0700 accounts for 4.46% (0.54%), 0800-1600 for 95.51% (95.44%), and 1700-1900 for the remaining 0.03% (4.02%) producing 551.04 kWh (740.77 kWh) monthly which accounts for 5.77% (6.35%) annually

April



0500-0700 accounts for 3.80% (6.59%), 0800-1600 for 97.80% (81.73%), and 1700-1900 for the remaining 3.12% (11.67%) producing 842.34 kWh (1063.59 kWh) monthly which accounts for 8.82% (9.11%) annually

June



0500-0700 accounts for 5.68% (8.60%), 0800-1600 for 86.61% (75.00%), and 1700-1900 for the remaining





0500-0700 accounts for **4.92% (8.53%)**, 0800-1600 for **88.07% (75.94%)**, and 1700-1900 for the remaining **7.01% (15.53%)** producing **1314.15 kWh (1264.32 kWh)** monthly which accounts for **13.76% (10.83%)** annually



0500-0700 accounts for **4.17% (6.59%)**, 0800-1600 for **94.13% (86.40%)**, and 1700-1900 for the remaining **1.70% (7.01%)** producing **937.64 kWh (1112.60 kWh)** monthly which accounts for **9.82% (9.53%)** annually

November



0500-0700 accounts for **6.00% (0.84%)**, 0800-1600 for **94.00% (98.61%)**, and 1700-1900 for the remaining **0.01% (0.55%)** producing **498.94 kWh (636.16 kWh)** monthly which accounts for **5.22% (5.45%)** annually

7.71% (16.40%) producing 1068.69 kWh (1048.20 kWh) monthly which accounts for 11.19% (8.98%) annually



0500-0700 accounts for **4.15% (7.20%)**, 0800-1600 for **91.00% (81.14%)**, and 1700-1900 for the remaining **4.86% (11.66%)** producing **1186.95 kWh (1208.68 kWh)** monthly which accounts for **12.43% (10.35%)** annually

October



0500-0700 accounts for **2.04%** (**3.29%**), 0800-1600 for **97.54%** (**94.24%**), and 1700-1900 for the remaining **0.42%** (**2.47%**) producing **523.63 kWh** (**915.67 kWh**) monthly which accounts for **5.48%** (**7.84%**) annually

December



0500-0700 accounts for **3.08% (0.00%)**, 0800-1600 for **96.92% (99.91%)**, and 1700-1900 for the remaining **0.00% (0.09%)** producing **313.14 kWh (541.88 kWh)** monthly which accounts for **3.28% (4.64%)** annually

September

Table C - 3 represents the annual total and percentage of generation by hour as well as hourly grouping percentages on a 24 hour-clock.

Time	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	Total
Real-World	5	67	342	632	942	1,199	1,314	1,318	1,238	1,034	712	407	225	96	18	9,550
GridSolar	9	178	422	734	999	1,144	1,218	1,301	1,297	1,253	1,164	911	608	328	100	11,674
Real-World	0.05%	0.70%	3.58%	6.61%	9.87%	12.55%	13.76%	13.81%	12.96%	10.83%	7.45%	4.27%	2.36%	1.01%	0.19%	N/A
GridSolar	0.08%	1.52%	3.62%	6.29%	8.55%	9.80%	10.43%	11.15%	11.11%	10.73%	9.97%	7.88%	5.21%	2.81%	0.86%	N/A
Real-World		4.34%						92.10%						3.56%		
GridSolar		5.22%						85.91%						8.87%		

 Table C - 3
 Annual Hourly Amounts and Percentages for PV Production

Table C - 4 represents the value of the sun's location (azimuth and zenith) on the 21st of each month on a 24 hour-clock.

Table C - 4Sun Azimuth and Zenith Positions

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Time	Azimuth	Zenith											
5	75							10.83					
6	90			7.90	17.36	23.13	24.17	21.38	16.42	10.37			
7	105			18.50	28.17	33.97	34.97	32.20	27.22	20.83	13.61		1.91
8	120		18.55	28.42	38.56	44.67	45.76	42.94	37.64	30.49	22.35	14.44	10.08
9	135	18.53	26.53	37.07	47.91	54.65	56.05	53.08	47.05	38.67	29.35	20.83	16.63
10	150	23.68	32.41	43.54	55.10	62.75	64.81	61.59	54.38	44.43	33.90	24.92	21.04
11	165	26.23	35.47	46.76	58.45	66.66	69.61	66.36	58.02	46.70	35.33	26.24	22.88
12	180	25.86	35.19	45.96	56.73	64.32	67.61	65.02	56.65	44.93	33.40	24.63	21.93
13	195	22.63	31.62	41.36	50.61	57.05	60.18	58.36	50.81	39.55	28.43	20.30	18.30
14	210	16.92	25.35	33.93	41.83	47.42	50.37	48.99	42.19	31.61	21.12	13.72	12.38
15	225	9.30	17.10	24.72	31.71	36.85	39.72	38.51	32.14	22.09	12.18	5.46	4.68
16	240	0.29	7.54	14.48	21.00	26.02	28.88	27.68	21.45	11.69	2.19		
17	255			3.76	10.17	15.32	18.23	16.93	10.60	0.90			
18	270					5.06	8.05	6.55					

Conclusions

Using the mathematical and formulaic systems as described above, it is possible to calculate the TSI for a solar panel at various configurations (slope and aspect). This is accomplished to a temporal resolution of hourly intervals by factoring weather, soiling, temperature, system specifications, etc. This model was compared to real-world readings obtained from a PV installation in Scarborough, Maine. After factoring in the shadow effects of the neighboring house, the model's accuracy was 97.51% in this case.

Technical Appendix D Geospatial Modeling of Buildings

Introduction

Technical Appendix D discusses the geographic information system (GIS) methods, data, results, and accuracy of the building attributes database. This database contains physical building attributes (e.g., number of stories and total square footage) as well as building classification (residential, commercial, or industrial) and electrical grid information (circuit, transformer, and substation designation). This database is then used to estimate current and future energy consumption by building, based on total square footage and building type and to calculate the impacts of such consumption on each circuit, transformer, and substation (see Appendix A for results).

Data

Table D-1 shows what data was used and their respective sources. The dataset was created using local municipality building footprints shapefiles (when available) as well as Microsoft's machine learning building footprint dataset derived from aerial imagery when municipality shapefiles were not available. The building attributes database also incorporated town parcel information (when available) to categorize each building by use type. Electrical grid data was provided by Central Maine Power (CMP), elevation data from the National Oceanic and Atmospheric Administration (NOAA), and county as well as town boundaries from the Maine Office of GIS (MEGIS).

	Dataset Name	File Format	Extension	Spatial Representation	Source
1	Point Cloud	LiDAR	.las	Point	NOAA
2	Building Footprints	Shapefile	.shp	Vector	Municipalities
3	Building Footprints	Shapefile	.shp	Vector	Microsoft
4	Parcel	Shapefile	.shp	Vector	Municipalities
5	Circuit	Shapefile	.shp	Vector	СМР
6	County and Town	Shapefile	.shp	Vector	MEGIS

Table D - 1 Datasets and Information

Modules and Data Formatting

Figure D-1 illustrates the simplified geospatial workflow used to create the building attributes database. The highlighted green blocks represent input data (as mentioned in Table D-1) while the yellow is the derived dataset. Each of these steps and methods are discussed below as well as presented with a more detailed workflow of the tools developed and used.





LiDAR (Light Detection And Ranging) is a technology that results in three-dimensional points representing elevation with stored coordinates. These LiDAR derived data points were used to develop a raster dataset that represents elevations at a resolution of 25 cm x 25 cm. This dataset, as well as the survey area boundary (e.g., municipal boundary) and building footprints, was then fed into the GridSolar developed geospatial tool to calculate building heights and other attributes (eave height, relative height, etc.). The steps in performing these calculations are shown in Figures D-2 and D-3.



Figure D - 2 GridSolar – Create Elevation and Building Attributes Data

The building footprints were assigned to CMP's distribution circuits based on a simple closest measurement algorithm. For areas where the circuit densities are high (such as the central business district Portland, Maine) manual corrections were made. Outside of these minor corrections, the model appears to have assigned circuit numbers to the appropriate building that they service. Each circuit is associated with a specific CMP substation as well as a transformer in that substation based on substation electrical one-line diagrams provided by CMP to GridSolar.

Building footprints were also assigned a county and town attribute field using a majority spatial relationship. This means that if a building's footprint was mostly in one county or town polygon than a neighboring one, it would be assigned that corresponding county and town name.

Building footprints were categorized as belonging to one of the three categories – residential, commercial or industrial using the municipality parcel data when available – see Table D-2 for an example of the types of structures in each building classification. This process assumes that any

structure that shares the same parcel with a building that contains tax information also shares the same attributes/classification. There are also four additional categories (Parking Lots, Private Lots, Other, and Fuel Tanks [primarily concentrated along South Portland's waterfront]). These were excluded from the energy consumption analysis, because they would skew results.

City	Residential (13, 2)	Commercial (14, 4)	Industrial (4, 1)
Portland	11 to 20 Family, 21 Plus	Bed and Breakfast,	Manufacturing,
	Family, 5 to 10 Family,	Benevolent and Charitable,	Multi-Use
	Apartment Rooms, Auxiliary	Communicational,	Industrial,
	Buildings, Commercial	Governmental, Hotel and	Transportational,
	Condos, Condominiums,	Motel, Land Banks, Literary	and
	Four Family, Multi-Use	and Scientific, Multi-Use	Warehouse/Storage
	Residential, Rooming	Commercial, Office Business,	
	Houses, Single Family, Three	Others Exempt by Law,	
	Family, and Two Family	Religious, Retail Service,	
		Vacant Land, and Wholesale	
South	Residential and 9039	Commercial, Exempt, Open	Industrial
Portland		Space, and 9038	

 Table D - 1
 Municipality Parcel Use Categorization Example for Portland and South Portland

Manual corrections were made to any structure that did not contain a building type designation. This was done using aerial imagery, Google Street View, as well as the analyst's familiarity with each town as a form of verification. Corrections were also made to building categories derived from the parcel data based on known building usage (e.g., commercial housing is categorized as commercial [legal use] when its energy consumption is of a residential structure [practical use]) identified by using aerial imagery, Google Street View, as well as our familiarity with each town. Next, only buildings with a footprint greater than or equal to 500 square feet were selected for analysis. This was done to exclude detached garages, sheds, and other types of outbuildings to which EUIs would not apply.

The building heights were then calculated using the previously mentioned raster elevation dataset. The total interior square footage for each building type was determined by first calculating each structure's height by subtracting each building's height above sea level (ASL) from the ground elevation ASL to obtain each building's measured height. Then, each building's eave and peak roof heights were defined and calculated using ArcGIS's Roof Extraction tool. This provided each building's height from the ground to the eave line, as it would exclude the roof height for non-flat roofs. Each building's structural height (from the eave line whenever present) was then divided by the defined stories intervals for each building type as shown in Table D-3. This value, representing total amount of stories per building, was then multiplied by the building's footprint to derive the total interior square footage for the entire structure.

Table D - 3 Building Story Intervals

Category	Story Intervals (m)	Story Intervals (ft)
Residential	3	10
Commercial	5	16
Industrial	8	26

Building attributes, such as the structure's total square footage, could not be obtained from municipal parcel data, as it was found that the local city data was inaccurate, not properly formatted, or was not available. This was verified through ground truthing performed by conducting site visits as well as using aerial imagery, Google Street View, and comparing city data to LiDAR derived results.



Results

The number of buildings and total square footage by building category are shown in Table D-4. These values were used to calculate energy consumption using estimated consumption rates (Energy Use Intensities or EUIs) per square-foot on an annual basis by building type as discussed in more detail in Technical Appendix A.

Table D - 4Building Total Square Footage

Catalogue	Number of	Percentage of	Total Square	Percentage of Total	Average Square
Category	Buildings	Buildings	Footage	Square Footage	Footage
Residential	107,456	92.04%	315,453,052	72.21%	2,936
Commercial	8,122	6.96%	99,198,201	22.71%	12,214
Industrial	1,176	1.01%	22,183,661	5.08%	18,864
Total	116,754	100.00%	436,834,914	100.00%	165,483

Only includes buildings \geq 500 square feet. Parking Garages, Private Lots, Tanks, and Other categories were excluded from the results above.

Model Validation

The results from the model were compared to real-world measurements and then modified to more accurately represent the Portland region's building square footage by structure type. This was done by creating a "ground-truth", "real-world", or "control sample" dataset. This dataset was comprised of seventy-five buildings that were randomly selected throughout the city of Portland, Maine. This dataset contained twenty-five buildings for each building type (residential, commercial, and industrial) to test the accuracy of GridSolar's physical building attributes dataset (number of stories and total square footage). The dataset contained each building's known characteristics (number of stories and total square footage) obtained through Google Street View and site visits. For residential buildings, when developing the real-world database, half-stories are assumed to only be 2/3 of that portion of the building's floor space. This dataset provided a way to "ground-truth" the model's results and refine the model's accuracy.

Through the control-sample, we determined that, depending on the building classification, we needed to modify the different floor (story) intervals assigned to the different building categories. These values were for residential buildings - 3 meters; commercial buildings - 5 meters, and industrial buildings - 8 meters. These story interval values were then used to divide the building's height, or eave height whenever present, to calculate the number of stories. The number of stories, in turn, was then multiplied by the building's footprint size to obtain total square footage.

Based on the results of this comparison, GridSolar's estimates of residential, commercial and industrials building square footages were 95%, 87%, and 99% respectively of the real-world values as shown in Table D-5.

Table D - 5 Model Accuracy for Building Attributes

Catagor	Number of Buildings	1.0000000000		
Calegory	in Control sample	леситасу		
Residential	25	95%		
Commercial	25	87%		
Industrial	25	99%		

Tables D-6, D-7, and D-8 show the calculations for each of the buildings in each of the building types. Please see the bolded accuracy in the bottom left of the following tables as it refers to the total of all buildings' square footage when analyzing GridSolar's and the Real-World's readings. The tables show the distribution of buildings by number of stories for each building type (residential, commercial, or industrial). Residential buildings have the expected one (63,247 or 58.86%) to two-stories (32,758 or 30.49%). The remaining buildings account for 10.65% with structures five-stories or more easily identified as places such as the Portland House (located at 45 Eastern Promenade in Portland, Maine) and Franklin Towers (located at 211 Cumberland Avenue in Portland, Maine).

Most commercial buildings are one-story in height (6,847 or 84.30%). Two-story buildings account for 12.20% (991) of all commercial buildings. The remaining 3.50% range from three to ten-stories in height (284 in total). These taller commercial buildings are located in downtown Portland

Industrial buildings are primarily comprised of one-story structures (1,152 or 97.96%) while two to four-story account for the remaining buildings (24 or 1.97%). The exception is for a single structure which is categorized as being eight-stories tall. This is identified as the Wyman Energy Center on Cousins Island in Yarmouth, Maine.
The model's overall accuracy, by factoring the percentage of buildings multiplied by the accuracy of that building type, is estimated at 93.39%.

No.	GIS ID	GridSolar	Real-World	GridSolar	Real-World	Difference	Accuracy
1	1205	2	1.5	2,395	3,593	-1,198	67%
2	11064	2	2	2,512	2,512	0	100%
3	11142	2	2	2,635	2,635	0	100%
4	11414	2	2	1,972	1,972	0	100%
5	11486	2	2	2,612	2,612	0	100%
6	11639	2	2	1,803	1,803	0	100%
7	11704	2	2	2,110	2,110	0	100%
8	11849	3	2.5	4,775	4,244	531	89%
9	11875	1	1	1,227	1,227	0	100%
10	11878	2	1.5	2,818	2,348	470	83%
11	12070	2	2	3,777	2,948	829	78%
12	12097	2	2.5	4,721	5,508	-787	86%
13	12213	2	1.5	2,789	2,324	465	83%
14	12286	2	1.5	2,752	2,293	459	83%
15	12287	3	2.5	5,088	4,523	565	89%
16	12463	3	2.5	4,215	3,747	468	89%
17	12491	3	2	7,507	5,005	2,502	67%
18	12582	3	2.5	4,059	3,608	451	89%
19	12631	2	2	2,359	2,359	0	100%
20	12761	1	1	1,543	1,543	0	100%
21	12831	4	3	5,817	4,362	1,455	75%
22	12900	2	1.5	2,106	1,755	351	83%
23	18870	3	3	6,657	6,657	0	100%
24	19425	2	1.5	1,964	1,637	327	83%
25	19496	2	3	6,083	8,387	-2,304	73%
	Total:	56	50.5	86,296	81,712	4,585	95%
	Average:	2.24	2.02	3,452	3,268	183	89%

Table D - 6Random Residential Building Stories and Square Footage Accuracy Test in Portland

Square Footage

Stories

No.	GIS ID	GridSolar	Real-World	GridSolar	Real-World	Difference	Accuracy
1	267	4	4	63,643	63,643	0	100%
2	281	4	4	41,702	41,702	0	100%
3	1229	1	1	54,319	54,319	0	100%
4	1275	1	1	6,707	6,707	0	100%
5	1731	2	3	17,090	25,636	-8,546	67%
6	1759	3	4	43,324	57,765	-14,441	75%
7	2022	1	1	6,487	6,487	0	100%
8	2184	3	3	316,192	219,267	96,925	69%
9	2192	2	2	14,879	14,879	0	100%
10	2490	3	3	28,305	28,305	0	100%
11	2523	3	3	59,991	59,991	0	100%
12	2571	2	2	28,625	28,625	0	100%
13	3121	2	3	31,835	47,753	-15,918	67%
14	3202	2	1	184,524	92,262	92,262	50%
15	3260	4	5	76,117	95,146	-19,029	80%
16	3633	1	1	18,236	18,236	1	100%
17	4753	2	1	67,764	33,882	33,882	50%
18	8304	1	1	1,355	1,355	0	100%
19	12811	1	1	47,847	47,847	1	100%
20	15203	3	3	119,265	119,265	0	100%
21	16832	1	1	13,766	13,766	0	100%
22	17792	1	1	7,697	7,697	1	100%
23	17835	2	2	15,357	15,357	0	100%
24	20293	2	2	9,840	9,840	0	100%
25	23329	4	4	122,499	100,799	21,700	82%
	Total:	55	57	1,397,366	1,210,529	186,837	87%
	Average:	2.2	2.28	55,895	48,421	7,473	90%

Table D - 7 Random Commercial Building Stories and Square Footage Accuracy Test in Portland

Square Footage

Stories

2). Northeast Bank on Pearl Street, Portland 3). Black Bear Medical 4). Tire Warehouse 8). Post Office on Forest Avenue in Portland (various stories) 9). Portland Fire Department on Congress Street, Portland 11). Portland Regency Hotel and Spa 13). Prop 15). Baxter Place on Commercial Street, Portland 16). Bunker Brewing 17). Metro 18). Global gas station 19). Seaside Healthcare 22). eDROP Maine 24). Moran's Market 25). Lincoln Middle School

No.	GIS ID	GridSolar	Real-World	GridSolar	Real-World	Difference	Accuracy
1	709	1	2	3,233	6,466	-3,233	50%
2	722	1	1	8,495	8,495	0	100%
3	733	1	2	10,041	15,612	-5,571	64%
4	753	1	1	31,356	31,356	0	100%
5	2021	2	3	146,737	193,855	-47,118	76%
6	2035	1	2	33,106	43,082	-9,976	77%
7	2053	1	1	12,619	12,619	0	100%
8	2203	2	4	16,443	32,886	-16,443	50%
9	2636	4	6	128,010	192,015	-64,005	67%
10	2659	2	4	6,657	13,314	-6,657	50%
11	10778	1	1	17,050	17,050	0	100%
12	11773	2	1	192,504	96,252	96,252	50%
13	11783	1	1	78,307	78,307	0	100%
14	13305	2	4	128,566	108,661	19,905	85%
15	13319	1	1	15,717	15,717	0	100%
16	15213	1	1	53,998	53,998	0	100%
17	15219	1	1	33,744	33,744	0	100%
18	15274	1	1	191,177	191,177	0	100%
19	18797	1	1	33,217	33,217	0	100%
20	19291	2	5	60,953	152,383	-91,430	40%
21	19334	1	3	60,170	126,201	-66,031	48%
22	19759	1	1	73,211	73,211	0	100%
23	21336	1	1	35,509	38,164	-2,655	93%
24	22329	2	1	467,465	233,733	233,733	50%
25	25729	1	1.5	61,128	85,965	-24,837	71%
	Total:	35	50.5	1,899,413	1,887,479	11,934	99%
	Average:	1.4	2.02	75,977	75,499	477	79%

Table D - 8 Random Industrial Building Stories and Square Footage Accuracy Test in Portland

Square Footage

Stories

1). Blue Lobster Urban Winery and Goodfire Brewing Company 2). Rosemont Baking Facility 3). Northern Burner Supply, mostly 1 story 4). Angela Adams Designs 5). half is two stories and the other half is 3 stories 6). Chase Leavitt Co. mostly one story, and some two stories 9). Fair Point Communications 10). Building next to Fair Point Communications 14). Some is 4 stories, and some is one story (B and H) 20). Residence Inn by Marriot Portland 21). Oakhurst Dairy on Forest Avenue in Portland (various stories) 23). Some small office space on the second floor 25). most is one story, and some is 2 stories (B&H)

Tables D-9, D-10, and D-11 provide breakdowns of all buildings in the Portland Region by type, by the number of stories, and by total square footage. Table D-12 provides the same data for all the buildings combined.

	Total				Total Square	Percentage of	Percentage of
Stories	Buildings	Min	Max	Average	Footage	Buildings	sq.ft
1	63,247	500.01	43,720.55	1,540.87	97,455,099.67	58.86%	30.89%
2	32,758	1,000.02	150,445.72	4,033.74	132,137,235.92	30.49%	41.89%
3	9,961	916.83	120,076.96	6,475.06	64,498,095.22	9.27%	20.45%
4	1,345	2,001.34	250,310.82	12,355.53	16,618,189.12	1.25%	5.27%
5	121	3,034.93	200,994.93	20,659.00	2,499,738.46	0.11%	0.79%
6	9	17,547.98	118,441.79	63,619.96	572,579.61	0.01%	0.18%
7	10	34,425.54	109,524.87	59,983.16	599,831.63	0.01%	0.19%
8	1	91,648.58	91,648.58	91,648.58	91,648.58	0.00%	0.03%
9	0	0.00	0.00	0.00	0.00	0.00%	0.00%
10	1	128,511.68	128,511.68	128,511.68	128,511.68	0.00%	0.04%
11	1	152,612.06	152,612.06	152,612.06	152,612.06	0.00%	0.05%
12	1	511,440.47	511,440.47	511,440.47	511,440.47	0.00%	0.16%
13	1	188,069.83	188,069.83	188,069.83	188,069.83	0.00%	0.06%
Total	107,456	N/A	N/A	N/A	315,453,052.25	100.00%	100.00%

Table D - 9 Residential Buildings with Footprints Equal to or Greater than 500 Square Feet

	Total				Total Square	Percentage of	Percentage of
Stories	Buildings	Min	Max	Average	Footage	Buildings	sq.ft
1	6,847	500.06	227,129.92	6,719.72	46,009,936.54	84.30%	46.38%
2	991	1,084.59	732,171.06	27,349.98	27,103,831.71	12.20%	27.32%
3	194	2,695.27	2,795,411.82	76,843.66	14,907,670.98	2.39%	15.03%
4	60	2,546.25	585,181.22	93,483.12	5,608,987.03	0.74%	5.65%
5	15	6,505.21	252,635.29	113,699.21	1,705,488.14	0.18%	1.72%
6	5	49,818.17	354,738.59	186,908.93	934,544.63	0.06%	0.94%
7	3	41,389.92	200,724.44	146,773.80	440,321.40	0.04%	0.44%
8	2	62,112.76	82,352.72	72,232.74	144,465.48	0.02%	0.15%
9	3	6,423.70	1,856,024.89	677,706.07	2,033,118.22	0.04%	2.05%
10	2	111,042.10	198,794.81	154,918.45	309,836.91	0.02%	0.31%
11	0	0.00	0.00	0.00	0.00	0.00%	0.00%
12	0	0.00	0.00	0.00	0.00	0.00%	0.00%
13	0	0.00	0.00	0.00	0.00	0.00%	0.00%
Total	8,122	N/A	N/A	N/A	99,198,201.03	100.00%	100.00%

Table D - 10 Commercial Buildings with Footprints Equal to or Greater than 500 Square Feet

	Total				Total Square	Percentage of	Percentage of
Stories	Buildings	Min	Max	Average	Footage	Buildings	sq.ft
1	1,152	502.61	1,039,699.86	15,907.46	18,325,398.97	97.96%	82.61%
2	17	1,071.23	371,912.45	69,305.19	1,178,188.16	1.45%	5.31%
3	5	1,670.17	1,525,822.98	397,942.10	1,989,710.50	0.43%	8.97%
4	1	22,920.70	22,920.70	22,920.70	22,920.70	0.09%	0.10%
5	0	0.00	0.00	0.00	0.00	0.00%	0.00%
6	0	0.00	0.00	0.00	0.00	0.00%	0.00%
7	0	0.00	0.00	0.00	0.00	0.00%	0.00%
8	1	667,442.81	667,442.81	667,442.81	667,442.81	0.09%	3.01%
9	0	0.00	0.00	0.00	0.00	0.00%	0.00%
10	0	0.00	0.00	0.00	0.00	0.00%	0.00%
11	0	0.00	0.00	0.00	0.00	0.00%	0.00%
12	0	0.00	0.00	0.00	0.00	0.00%	0.00%
13	0	0.00	0.00	0.00	0.00	0.00%	0.00%
Total	1,176	N/A	N/A	N/A	22,183,661.15	100.00%	100.00%

Table D - 11 Industrial Buildings with Footprints Equal to or Greater than 500 Square Feet

	Total				Total Square	Percentage of	Percentage of
Stories	Buildings	Min	Max	Average	Footage	Buildings	sq.ft
1	71,246	500.01	1,039,699.86	2,270.87	161,790,435.19	61.02%	37.04%
2	33,766	1,000.02	732,171.06	4,750.91	160,419,255.80	28.92%	36.72%
3	10,160	916.83	2,795,411.82	8,011.37	81,395,476.70	8.70%	18.63%
4	1,406	2,001.34	585,181.22	15,825.10	22,250,096.86	1.20%	5.09%
5	136	3,034.93	252,635.29	30,920.78	4,205,226.60	0.12%	0.96%
6	14	17,547.98	354,738.59	107,651.73	1,507,124.24	0.01%	0.35%
7	13	34,425.54	200,724.44	80,011.77	1,040,153.03	0.01%	0.24%
8	4	62,112.76	667,442.81	225,889.22	903,556.87	0.00%	0.21%
9	3	6,423.70	1,856,024.89	677,706.07	2,033,118.22	0.00%	0.47%
10	3	111,042.10	198,794.81	146,116.19	438,348.58	0.00%	0.10%
11	1	152,612.06	152,612.06	152,612.06	152,612.06	0.00%	0.03%
12	1	511,440.47	511,440.47	511,440.47	511,440.47	0.00%	0.12%
13	1	188,069.83	188,069.83	188,069.83	188,069.83	0.00%	0.04%
Total	116,754	N/A	N/A	N/A	436,834,914.43	100.00%	100.00%

Table D - 12 Summary of All Buildings with Footprints Equal to or Greater than 500 Square Feet

Conclusions

The GridSolar model provides a reasonably accurate estimate of building square footage for different building types. The model uses LiDAR, parcel data, and building footprint data and performs with an overall combined estimated regional accuracy of 93.39%.

Some reasons for model errors have to do with the following: data overlap (e.g., LiDAR being captured prior to building development), tall ceiling buildings (e.g., Maine Mall is mainly a one- and two-story tall building but would be categorized as a five-story structure for the central parts of it based on its relative height), ArcGIS's Roof Extraction tool falsely identifying gabled/hipped roofs from flat roofs (this was mitigated by using the eave measurement whenever possible), and that the model assumes that all areas within a building footprint has the same amount of stories (does not account for variation of stories within the same building footprint).

However, despite these forms of error, the model's accuracy when analyzing Portland's total square footage is estimated to be 92.63% accurate and regionally 93.39%. This model provides an accurate representation of the total square footage for individual structures by category type (residential, commercial, and industrial) that are spatially related to a geographic region (county and city) as well as a circuit, transformer, and substation.

Technical Appendix E Geospatial Modeling of Building Roofs

Introduction

Technical Appendix E discusses the geographic information system (GIS) methods, data, results, and accuracy of the building roof attributes database. This database contains physical building roof attributes (size, slope, and aspect) as well as building classification (residential, commercial, or industrial) and electrical grid information (circuit, transformer, and substation designation). This database is used to perform future photovoltaic (PV) electricity generation production analysis by building to model the impacts rooftop solar PV system buildout will have on each circuit, transformer, and substation in the Portland Region (see Appendix A for results).

Data

Table E-1 shows the data that was used as well as its associated sources for the building rooftop solar PV model. The dataset was created using local municipality building footprints shapefiles (when available) and Microsoft's machine learning building footprint dataset derived from aerial imagery when the municipality data was not available. The building attribute database also incorporated town parcel information (where available) to categorize each building by use type (residential, commercial or industrial). Manual assignment of building use type was done when parcel data was not available using aerial imagery, Google Street View, as well as our familiarity with each town. Electrical grid data was provided by Central Maine Power (CMP), elevation data from National Oceanic and Atmospheric Administration (NOAA), and county as well as town boundaries from the Maine Office of GIS (MEGIS). Solar irradiance data was obtained through the National Renewable Energy Laboratory (NREL) and is further explained in Appendix C.

	Dataset Name	File Format	Extension	Spatial Representation	Source
1	Point Cloud	Lidar	.las	Point	NOAA
2	Building Footprints	Shapefile	.shp	Vector	Municipalities
3	Building Footprints	Shapefile	.shp	Vector	Microsoft
4	Parcel	Shapefile	.shp	Vector	Municipalities
5	Circuit	Shapefile	.shp	Vector	CMP
6	County and Town	Shapefile	.shp	Vector	MEGIS
7	Solar Irradiance	Table	.CSV	Text	NREL

Table E - 1 Datasets and Information

Model

The purpose of the geospatial modeling of building rooftops is to determine the number of solar PV panels that can be placed on the roofs of the almost 100,000 buildings in the Portland Area. Figure E-1 illustrates the simplified geospatial workflow used to create the building roof attributes database. The highlighted green blocks represent input data (as mentioned in Table E-1) while the yellow is the derived dataset. Each of these steps and methods are discussed in greater detail below as well as presented with a more detailed workflow of the tools developed and used.



Figure E - 1 Simplified Geospatial Model and Workflow to Create the Roof Attributes Dataset

The model is comprised of five modules as shown in Table E-2. The first module defines the outline of each roof of each building and computes certain key attributes. The second module breaks down each rooftop into what we refer to as "planes", each portion of which has the same slope and aspect. The third module converts the planes into polygons that can be integrated into the GIS database. The fourth module focuses on each polygon to clean it of possible errors and map it to specific geospatial coordinates. Finally, the fifth module uses certain economic parameters to identify only those polygons that are suitable for the installation of solar PV panels. Each of these modules is described in detail in the following sections.

Module Name	Overview
Building Rooftop Elevation and Attributes	Develops elevation data within each building
	footprint which is later used to determine slope,
	aspect, and size for each roof segment.
Building Rooftop Plane Slope and Aspect	Defines the slope and aspect for each pixel,
Generator	groups similar pixels by regions, and then
	generates polygon boundaries.
Define Slope and Aspect Polygons	Takes the previously generated slope and aspect
	polygons and redefines their ranges according
	to a median spatial relationship of the define
	points within each polygon.
Slope and Aspect Polygon Cleaning and	Cleans polygons by identifying those with
Merging	irregular shapes and sizes as well as merges
	slope and aspect polygons into a single dataset.
Identification of Suitable Rooftops	Selects suitable slopes (ranging from 0° to 50 °)
-	and aspect (ranging from 90 ° to 270°) and size
	(combined suitable polygons by building that
	can accommodate 8 panels) based on economic
	factor.

Table E - 2Module Components

Modules and Data Formatting

LiDAR (Light Detection And Ranging) is a technology that results in three-dimensional

points representing elevations with stored coordinates. These LiDAR derived data points were used

to develop a raster dataset that represents elevations at a resolution of 25 cm x 25 cm. The digital

surface model (DSM) was created using an interpolation type of binning method, average cell assignment, and a linear void fill technique. The first module – the elevation and building attributes model is shown in the flowchart in Figure E-2.





The derived elevation dataset and building footprints were fed into GridSolar's developed geospatial tool, parceled by municipality, to calculate slope and aspect for each building's roof segments. Next, elevation data was extracted using building footprints. These footprints had an internal setback of 3 feet to incorporate the standard guidelines for panel placement from the edge of a roof to provide adequate egress access for fire fighters in the event of structural fires. Next, all elevation values went through a slope and aspect generator tool, the components of which are shown in Figure E-3. These were reclassified according to the defined groups and cleaned using the majority filter as well as the boundary clean tool. After the datasets were cleaned, the region group and nibble tool were utilized before finally being converted to both polygons and points. The point values were reduced by 75%, by selecting every fourth point in the table, to increase processing time.



The slope tool identifies the gradient or steepness for each cell of a raster¹ while the aspect tool identifies the compass direction of downhill slope faces.² The majority filter replaces cells in a raster based on the majority of their contiguous neighboring cells³ while the boundary clean tool smooths the boundary between zones by expanding or shrinking it.⁴ The region group, for each cell in the output, identifies the connected region to which that cell belongs.⁵ The nibble tool replaces cells of a raster corresponding to a mask with the values of the nearest neighbors.⁶

The derived point dataset (with values) and polygon regions for each slope and aspect section were then spatially joined using the median of all point values that fell within each polygon. This was done in order to ensure the proper assignment of slope and aspect values to each polygon through a statistically relevant method.

¹ <u>https://pro.arcgis.com/en/pro-app/tool-reference/3d-analyst/slope.htm</u>

² https://pro.arcgis.com/en/pro-app/tool-reference/3d-analyst/aspect.htm

³ <u>https://pro.arcgis.com/en/pro-app/tool-reference/spatial-analyst/boundary-clean.htm</u>

⁴ <u>https://pro.arcgis.com/en/pro-app/tool-reference/spatial-analyst/boundary-clean.htm</u>

⁵ <u>https://pro.arcgis.com/en/pro-app/tool-reference/spatial-analyst/region-group.htm</u>

⁶ https://pro.arcgis.com/en/pro-app/tool-reference/spatial-analyst/nibble.htm



Figure E - 4 GridSolar – Define Slope and Aspect Polygons

After the slope and aspect polygons are assigned their corresponding values, GridSolar's geospatial module merges the two datasets (slope and aspect) as well as cleans errors. This is done by first calculating each polygon's perimeter area ratio (PAR) defined as the polygon length / polygon area. This allows the model to filter out irregular shapes (PAR equal to or greater than 2) introduced from elevation and misidentification errors. These polygons are then merged into the nearest polygon through a simplification and spatial join process. Next, the original slope points are redefined using the slope polygon value before being used to assign slope values to aspect polygons through a median spatial join for aspects that do not overlap with slope polygons labeled as flat. This is done because the slope tool accurately defines flat roofs, but the aspect tool performs better at defining sloped roof planes. Finally, the two datasets are merged where aspect polygons do not overlap flat roofs, thus removing all other slope polygons that are not categorized as flat.

After the datasets were cleaned and merged, a filter system based on economic parameters was applied in order to select only suitable slope and aspect regions. The filter system starts by first selecting slope between the ranges of 0° and 50 ° and aspect between 90 ° and 270° as well as polygons greater than or equal to 3.5 square meters (minimum size required to fit a panel). Polygons

on roof panels with slope greater than 500 or that lie north of due east and due west are not economically viable for the installation of solar PV.



Figure E - 5 GridSolar – Slope and Aspect Polygon Cleaning and Merging

Next, these suitable polygons are aggregated by building footprint and then filtered to determine if the aggregate of the building roof planes is large enough to accommodate an 8-panel solar array (the minimum number of panels considered by ReVision Energy to be economically viable).⁷ These polygons are then exported as the final suitable roof facets for solar installations.

It is important to note that the roof size is based on the building footprint, which is a twodimensional plane and does not account for surface area available when factoring the steepness of a roof's slope (the hypotenuse). Therefore, the area available is a conservative estimate rather than a maximum. On the other hand, the model also does not account for reductions in available sunlight due to shading or tree canopy coverage.⁸ In addition, the model will also not include suitable building rooftops for new buildings, if the LiDAR data was captured before the building was constructed.

⁷ Phone interview with Becca Austin of ReVision Energy.

⁸ Due to the irregularity of a tree's surface area, it is likely that the LiDAR would not pick up these sections of roof so they would not be included.



Figure E-7 indicates the grouping of each aspect into a specific aspect value (e.g., 22.5° to 67.5° was categorized as 45°) as well as which ones are considered unsuitable (red equals unsuitable [282.5° to 67.5°] or suitable (green indicates suitable aspects [67.5° to 282.5°]).



Figure E - 7 Aspect Ranges

Figure E-8 indicates the grouping of each slope into a specific slope value (e.g., 25° to 35° was categorized as 30°) as well as which ones are considered unsuitable (red equals unsuitable slope [55° to 90°] or suitable (green indicates suitable slope [0° to 55°]). Roofs with a slope less than or equal to 17.31° were considered flat. These were assigned a slope value of 25° consistent with industry practice to maximize energy generation. Further, those panels would be mounted to a rack system, while panels with higher slope values would be installed on a flush-mount system.





Results

We calculated the total number of panels for each suitable roof plane for each building. These were then aggregated for each individual building. For flat roofs, we assumed that only onethird of the available surface area is useable due to inter-row spacing requirements. To calculate solar array row spacing for flat roofs, the Folsom Labs' Modeling formula was modified to represent Maine's latitude.⁹ The original formula took the panel's height (opposite [O]) and multiplies it by 2.3, at 35° north, to get the required spacing to avoid casting shadows from one row to the next (interrow shadowing). This multiplication value was converted to Portland, Maine area's latitude (45°

⁹ https://www.folsomlabs.com/modeling

north) by dividing 2.3 by the ratio of 45° to 35° that yielded 2.95 as the new multiplier, as shown below.

Converting Spacing Multiplier to 45° Latitude

 $2.3/35^{\circ} = 0.065$ $0.065 * 45^{\circ} = 2.95$

The 2.95 value is multiplied by the panel's height (opposite [O]) to give the necessary row spacing. This calculation is based on the panel placed along its long edge. This resulted in the necessary space requirement per panel (physical space and inter-row spacing) was just less than three-times as much as the panel's physical size. This is why flat roofs are assumed to only have one-third the available space for panels.

After all roof segments were mapped with their corresponding slope and aspect attributes assigned, the total energy production could be calculated using the hourly profile discussed in Appendix C.

Figures E-9 to E-11 represent the number of solar panels per building for each building category. As discussed in the *Data Formatting* section of this report, any building with less than 8 panels was excluded based on economic grounds.







Figure E - 10 Number of Commercial Buildings by PV Array Size

Figure E - 11 Number of Industrial Buildings by PV Array Size



Table E-12 shows the number of solar panels that can be installed on each type of building in the Portland Area and at each Slope/Aspect combination.¹⁰ Table E-13 shows the same breakdown by total annual electricity generation, measured in MWh. Table E-14 presents the results by percentage, while Table E-15 provides the totals across all buildings for each of the prior three tables.

¹⁰ The slope level of 25° is used for flat roofs where panels are installed at 25° and oriented to an aspect of 180°.

 Table E - 12
 Number of Panels by Building Type by Slope/Aspect Combination

Aspect in Degrees 90 135 180 270 Total 225 20 27,887 112,719 85,155 115,141 39,821 380,723 Slope in Degrees N/A N/A 84,015 25 N/A 84,015 N/A 49,166 582,902 30 40,889 190,639 128,572 173,636 40 38,188 168,591 43,619 523,214 121,697 151,119 50 37,507 9,674 10,479 48,647 40,172 146,479 Total 117,444 520,596 456,945 480,068 142,281 1,717,333

Residential Buildings

Commercial Buildings

Aspect in Degrees

		90	135	180	225	270	Total
S	20	11,225	42,528	28,472	29,832	11,400	123,457
gree	25	N/A	N/A	480,705	N/A	N/A	480,705
ם De	30	5,442	33,862	24,148	30,254	10,700	104,407
pe ir	40	3,122	14,272	10,031	12,942	4,092	44,459
Slo	50	620	4,954	3,612	4,335	1,262	14,783
	Total	20,410	95,616	546,968	77,363	27,455	767,811

Industrial Buildings

		90	135	180	225	270	Total
oe in Degrees	20	707	4,913	3,492	4,788	1,261	15,161
	25	N/A	N/A	227,899	N/A	N/A	227,899
	30	570	2,923	5,406	4,068	1,320	14,287
	40	162	767	416	1,830	449	3,624
Slo	50	76	1,649	611	677	250	3,263
	Total	1,515	10,252	237,824	11,363	3,279	264,234

Table E - 13 Electricity Generation by Building Type and Slope/Aspect Combination (MWh)

			Asp	ect in Deg	rees		
		90	135	180	225	270	Total
oe in Degrees	20	15,434	67,326	51,957	67,453	21,393	51,162
	25	N/A	N/A	51,162	N/A	N/A	223,562
	30	21,288	111,691	77,768	98,863	24,470	334,080
	40	18,248	94,902	71,544	79,194	19,580	334,629
Sloj	50	4,747	26,616	21,566	21,066	4,040	78,036
	Total	54,981	273,968	252,469	245,551	65,452	892,420

Residential Buildings

Commercial Buildings

Aspect in Degrees

		90	135	180	225	270	Total
es	20	6,212	25,401	17,372	17,476	6,124	72,586
gree	25	N/A	N/A	292,730	N/A	N/A	292,730
ם ח	30	2,833	19,839	14,606	17,226	5,325	59,830
pe ii	40	1,492	8,034	5,897	6,782	1,837	316,772
Sloj	50	281	2,710	2,077	2,273	527	7,868
	Total	10,539	53,280	330,610	41,489	13,288	449,206

Industrial Buildings

		90	135	180	225	270	Total
es	20	392	2,935	2,130	2,805	677	8,939
gree	25	N/A	N/A	138,782	N/A	N/A	138,782
n De	30	297	1,712	3,270	2,316	657	8,252
pe ii	40	78	432	244	959	201	140,696
Slo	50	34	902	351	355	104	1,747
	Total	766	5,081	144,428	6,081	1,536	157,892

Table E - 14 Percentage of Annual PV Generation by Building Type

		Aspect in Degrees					
		90	135	180	225	270	Total
S	20	1.59%	6.94%	5.35%	6.95%	2.20%	23.03%
oe in Degree	25	N/A	N/A	5.27%	N/A	N/A	5.27%
	30	2.19%	11.51%	8.01%	10.19%	2.52%	34.42%
	40	1.88%	9.78%	7.37%	8.16%	2.02%	29.21%
Sloj	50	0.49%	2.74%	2.22%	2.17%	0.42%	8.04%
	Total	6.15%	30.97%	28.22%	27.47%	7.16%	100.00%

Residential Buildings

Commercial Buildings

Aspect in Degrees

		90	135	180	225	270	Total
es	20	1.36%	5.56%	3.80%	3.82%	1.34%	15.88%
gree	25	N/A	N/A	64.05%	N/A	N/A	64.05%
l De	30	0.62%	4.34%	3.20%	3.77%	1.17%	13.10%
oe ir	40	0.33%	1.76%	1.29%	1.48%	0.40%	5.26%
SloJ	50	0.06%	0.59%	0.45%	0.50%	0.12%	1.72%
	Total	2.37%	12.25%	72.79%	9.57%	3.03%	100.00%

Industrial Buildings

		90	135	180	225	270	Total
1 Degrees	20	0.25%	1.84%	1.33%	1.76%	0.42%	5.60%
	25	N/A	N/A	86.94%	N/A	N/A	86.94%
	30	0.19%	1.07%	2.05%	1.45%	0.41%	5.17%
pe ir	40	0.05%	0.27%	0.15%	0.60%	0.13%	1.20%
Sloj	50	0.02%	0.57%	0.22%	0.22%	0.07%	1.10%
	Total	0.51%	3.75%	90.69%	4.03%	1.03%	100.00%

 Table E - 15
 Total Number of Panels, Generation and Relative Percentages

		90	135	180	225	270	Total
S	20	39,820	160,160	117,118	149,760	52,482	519,340
oe in Degree	25	N/A	N/A	792,620	N/A	N/A	792,620
	30	46,902	227,423	158,126	207,959	61,186	701,596
	40	41,473	183,630	132,144	165,891	48,160	571,298
Sloj	50	11,175	55,250	41,730	45,184	11,187	164,526
	Total	139,370	626,463	1,241,738	568,794	173,015	2,749,380

Aspect in Degrees

		90	135	180	225	270	Total
es	20	22,038	95,662	71,459	87,734	28,194	305,087
gree	25	N/A	N/A	482,674	N/A	N/A	482,674
De	30	24,418	133,243	95,644	118,405	30,452	402,162
pe ii	40	19,817	103,367	77,686	86,935	21,618	309,423
Sloj	50	5,062	30,229	23,995	23,695	4,671	87,652
	Total	71,335	362,501	751,458	316,769	84,935	1,586,998

		90	135	180	225	270	Total
es	20	1.39%	6.03%	4.50%	5.53%	1.78%	19.23%
gree	25	N/A	N/A	30.41%	N/A	N/A	30.41%
ם De	30	1.54%	8.40%	6.03%	7.46%	1.92%	25.35%
je ir	40	1.25%	6.51%	4.90%	5.48%	1.36%	19.50%
Sloj	50	0.32%	1.90%	1.51%	1.49%	0.29%	5.51%
	Total	4.50%	22.84%	47.35%	19.96%	5.35%	100.00%

Model Validation

The model's accuracy was tested against a constructed control sample of known rooftops (manually mapped using aerial imagery and elevation data) and assigned their corresponding attributes (slope and aspect) by referencing the building's LiDAR data. The control sample consisted of 215 roof segments with 107 considered suitable based on their slope and aspect as discussed in the prior section. This control sample consisted of residential, commercial, and industrial structures of varying degrees in slope, aspect, shape, and size.

Table E-17 provides a summary of the accuracy of defining each attribute category (sloped and flat roofs) based on a pass or fail system. Either the attribute equals the known "real-world" value, or it does not. This is important as the model's errors originate from either the misidentification of a roof plane (which is either the degree up or down from the roof segment's known state) or from the roof segment being dropped from the model entirely.

The accuracy of sloped and flat roofs (both aspect and slope attributes) was calculated by taking the total of misidentified roof segments (either labeled as a different slope and/or aspect or not categorized at all) and dividing it by the total number of slope or aspect in that category.

Accuracy	Slope	Aspect	Size
Flat Roofs	100.00%	100.00%	96.13%
Slope Roof	84.62%	89.74%	98.05%
Overall	88.79%	92.52%	96.48%

Roof Attribute	Accuracy
	Roof Attribute

All errors introduced when analyzing the aspect attributes were from those roofs being dropped from the modeling system rather than being misidentified. When analyzing slope, four errors were from misidentification, while the remining eight were from the modeling system dropping those roof segments. This is a crucial distinction, because the roof segments which were dropped are smaller than 16.61 square meters (median value of 9.12 square meters) in size and only account for 1.27% of suitable sloped roofs area and 0.07% of the overall suitable surface area. This is because when the model is presented with a small roof segments with complex angles, it will drop the results rather than introduce them into the system in order to reduce the probability of categorizing unsuitable roof segments as suitable. The percentage of slope errors introduced by misidentification (plus or minus one category from its current state) accounts for only 3.74% and does not statistically impact the model due to its low frequency.

In conclusion, the model does an accurate job in categorizing and summarizing the surface space available for suitable conditions. When the model fails to identify these suitable spaces, it removes them from the dataset. Based on the control sample, the model does not do this in reverse, i.e., misidentifying unsuitable roof segments and categorizing them as suitable. It is, therefore, reasonable to conclude that the model represents a conservative estimate of the amount of rooftop space available for installing solar PV systems.



Figure E - 13 Control Sample - Manually Mapped Roof Segments



Figure E - 14 Generated Suitable Roof Segments and Control Sample

50 100

200 US Feet





-

RID IGN, and I

Conclusions

In conclusion, the rooftop geospatial modeling provides a reasonably accurate representation of the minimum roof space available for the installation of rooftop solar PV panels on all buildings in the Portland Area. The model has an overall accuracy of modeling slope at 88.79%, aspect at 92.52%, and size at 96.48%. The model indicates that 79.98% of residential buildings can support PV installations (1,717,334 panels and 970,307 MWh), 36.37% of commercial buildings can support PV installations (767,811 panels and 457,057 MWh), and 22.12% of industrial buildings can support PV installations (264,234 panels and 159,634 MWh).

The PV array sizes for installations between 8 and 10 panels include 3,028 residential, 113 commercial, and 20 industrial buildings; between 10 and 20 panels include 18,627 residential, 693 commercial, and 78 industrial buildings; between 20 and 30 panels include 13,465 residential, 566 commercial, and 50 industrial buildings; between 30 and 40 panels include 7,865 residential, 446 commercial, 35 industrial buildings; between 40 and 50 panels include 4,991 residential, 348 commercial, 39 industrial buildings; and for installation greater than 50 panels include 10,408 residential, 77 commercial, and 1 industrial buildings.

Technical Appendix F Geospatial Vehicle Distribution

Introduction

Technical Appendix F discusses the geographic information system (GIS) methods, data, results, and accuracy of the distribution of Maine's vehicles by class (passenger, commercial, and heavy-duty), by municipality, and by building category (residential, commercial, and industrial). This data was assigned to the building attribute database discussed in Appendix D, which contains each structure's physical roof attributes, classification, and electrical grid information.

Data

Table F-1 shows the data used as well as its associated sources for the vehicle distribution modeling. Vehicle registration data (vehicle make, model, city of registration, and miles driven per year) was provided by the Maine Secretary of State Office (SSO). The building attribute database was created by GridSolar (see Appendix D for more detail). The vehicles were assigned to this database (see *Data Formatting* for more detail).

The number of public transportation buses and their garage locations for Portland and South Portland were obtained from each municipality's transportation departments. Public school bus numbers and their garage locations were either obtained from each city's Public-School Department or using aerial imagery and garage site visits.

	Dataset Name	File Format	Extension	Spatial Representation	Source
1	Vehicle Registration	Table	.CSV	Town ID	SSO
2	Building Attributes	Feature Class	.shp	Vector	GridSolar
3	Public Transportation	Table	.CSV	N/A	Portland and South Portland
4	Public School Buses	Table	.CSV	N/A	Portland and GridSolar

Table F - 1 Datasets and Information

Data Formatting

According to the Federal Highway Administration (FHA), vehicles are subdivided into eight weight classes (1 to 8) and duty classifications (light, medium, and heavy) as illustrated in Table F-2.¹ This classification system was used to categorize all commercial diesel vehicles in order to isolate heavy-duty vehicles (weight classes 7 and 8), which include freightliners and dump-trucks.

In order to assign each vehicle a weight class and duty classification, all commercially registered diesel vehicles were isolated. Next, duplicate manufacturer makes and models were removed to obtain only unique vehicle identifiers. This produced 812 such vehicles in the state. The resulting vehicles were then assigned to its corresponding weight class and duty classification according to the FHA system. Once this index table was created, it was joined to the primary vehicle database based on similar make and model fields. This was then used to isolate weight classes 7 and 8 to calculate the number of freightliners and heavy-duty vehicles.

¹ <u>https://afdc.energy.gov/data/10380</u>

US Truck Weight Class	Duty Classification	Weight Limit
Class 1	Light	0–6,000 pounds (0–2,722 kg)
Class 2	Light	6,001–10,000 pounds (2,722–4,536 kg)
Class 3	Medium	10,001–14,000 pounds (4,536–6,350 kg)
Class 4	Medium	14,001–16,000 pounds (6,351–7,257 kg)
Class 5	Medium	16,001–19,500 pounds (7,258–8,845 kg)
Class 6	Medium	19,501–26,000 pounds (8,846–11,793 kg)
Class 7	Heavy	26,001–33,000 pounds (11,794–14,969 kg)
Class 8	Heavy	33,001 pounds (14,969 kg) +

 Table F - 1
 Vehicle Weight Classes and Categories - Federal Highway Administration

All registered vehicles were then broken into three primary groups: passenger, commercial, and heavy-duty (dump-trucks and freightliners) as well as public transportation buses and school buses. These vehicles have different spatial assignments to building according to their functions. The primary categories were filtered by city, vehicle use type (passenger, commercial, and heavyduty), and vehicles registered in the year 2019 to calculate the number of vehicles by type for each city.

The average annual mileage per vehicle type (passenger, commercial, and heavy-duty) by city was calculated by selecting vehicles that had registered mileage for the years 2015 to 2019 and taking average annual miles driven. This produced the number of annual miles each vehicle drove on average over the course of the last 4 years. (See Table F-3). All the vehicles averages were then summed and divided by the total number of vehicles. This average was used to calculate the amount of fuel consumed, using an average miles per gallon assumption, that provided the base metric to calculate the amount of energy required to convert fuel-based vehicles to electric vehicle alternatives. Total fuel consumption was used to calculate how much CO_2 is produced.

Vehicle Types	Avg. Annual Mileage	Avg. MPG
Passenger	10,000	25
Commercial	16,000	12
Public Transportation	28,000	6
Public School Buses	28,000	6
Heavy-Duty Trucks	28,000	6

 Table F - 3
 Average Mileage and Average Miles Per Gallon by Vehicles Type

Both passenger and commercial vehicles are distributed to each building category by square footage (total city square footage divided by total number of vehicles per city, by building type). This is done to reflect the underlying vehicle charging models for passenger and commercial (nonheavy duty) vehicles. That model assumes each vehicle charges at all three locations (residential, commercial, and industrial in relative percentages of 75%, 19% and 6%, respectively). Heavy-duty vehicles were assigned to either commercial or industrial buildings. The locations of those buildings were chosen from a number of physical locations in the municipalities that currently support vehicle garages (e.g., commercial and industrial buildings at the corner of Read Street and Canco Road or along Presumpscot Street, both in Portland). This was done to avoid distributing heavy-duty vehicles to commercial and industrial buildings that would not otherwise have these vehicles (e.g., freightliners and dump-trucks are not garaged along downtown Congress Street in Portland). Public transportation and public-school buses were designated to buildings according to their garaged locations and are assumed to charge at these addresses.

Results

Table F-4 shows the total number of vehicles by category that were assigned to buildings footprints in each municipality.

City	Passenger	Commercial	Heavy Duty	School Buses	Public Transportation
Brunswick	16,116	840	82	27	0
Buxton	5,252	423	25	0	0
Cape Elizabeth	8,153	371	9	13	0
Chebeague Island	383	19	1	0	0
Cumberland	7,378	396	15	24	0
Durham	3,876	292	23	4	0
Falmouth	11,092	915	9	22	0
Freeport	7,712	555	19	11	0
Gorham	14,598	1,497	131	30	0
Gray	7,588	607	24	15	0
Long Island	66	3	0	0	0
New Gloucester	3,658	295	17	0	0
North Yarmouth	3,516	309	22	0	0
Old Orchard Beach	7,752	353	9	9	0
Portland	48,855	3,724	194	32	44
Pownal	1,536	126	7	3	0
Raymond	4,383	362	6	24	0
Saco	18,615	2,067	168	25	0
Scarborough	19,032	2,113	172	24	0
South Portland	24,003	1,559	151	26	7
Westbrook	15,982	1,644	72	28	0
Windham	15,569	1,435	68	24	0
Yarmouth	7,728	345	21	15	0

Table F - 4Vehicles Types by City

Notes:

Buxton vehicle totals are estimates since no data was available. Vehicle amounts were estimated using towns with similar population and economic sectors with the following formula (Buxton Vehicle Count / Town Population) * New Gloucester Population. Saco vehicle totals are estimates since no data was available. Vehicle amounts were estimated using towns with similar population and economic sectors with the following formula (Scarborough Vehicle Count / Town Population) * Saco Population

Model Validation

Unfortunately, there is no effective means to ground-truth the above allocations of vehicles

to buildings, other than municipal and school buses. What we know to be true is that the proper

number of vehicles per municipality have been assigned, as the total number of vehicles per city was obtained from the SSO and represents vehicle registration up until the year 2019.